

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.50	12.92	43.43	1.78	18.26	11.37	1.26	72784.78
1	6.27	11.96	48.24	1.88	18.66	10.99	1.26	75581.39
2	6.43	11.87	58.06	2.41	18.58	11.23	1.26	74401.21
3	6.40	11.79	55.36	2.41	17.57	11.28	1.27	74278.56
4	6.38	11.69	59.24	2.28	18.40	11.14	1.27	75026.76
5	7.32	11.25	53.02	2.09	19.47	10.59	1.29	75363.37
6	7.56	12.02	56.56	2.41	18.82	10.74	1.29	76532.53
7	10.25	11.73	47.76	3.37	17.02	11.31	1.29	73324.60
8	13.17	11.40	38.75	3.48	17.11	11.17	1.29	71206.41
9	14.11	11.60	41.93	3.52	16.80	11.29	1.28	69896.06
10	11.92	11.34	41.72	3.24	16.20	11.31	1.29	69627.21
11	9.04	11.58	43.12	2.59	16.62	11.24	1.28	69670.74
12	9.90	11.60	40.35	2.95	16.49	11.31	1.27	68168.65
13	9.75	11.43	39.35	2.62	16.96	11.31	1.27	68896.81
14	11.78	11.40	46.17	2.81	16.42	11.40	1.29	68755.63
15	15.80	11.37	48.40	3.69	16.57	11.33	1.29	69675.44
16	14.51	11.90	42.73	2.93	16.94	11.27	1.29	71077.15
17	6.20	12.12	45.06	2.12	17.25	11.32	1.27	71141.61
18	6.21	13.04	31.35	1.80	17.89	11.08	1.27	72656.75
19	5.19	12.22	40.43	1.62	18.13	11.28	1.29	71787.21
20	6.22	11.79	45.01	1.77	18.41	11.18	1.27	73128.39
21	5.07	12.37	54.08	1.23	18.35	11.68	1.27	70070.79
22	4.98	11.96	49.96	1.53	16.61	11.33	1.27	73973.11
23	6.33	11.65	58.17	2.14	16.49	11.38	1.28	74182.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.64	11.83	47.01	2.44	17.50	11.23	1.28	72133.65
最大值	15.80	13.04	59.24	3.69	19.47	11.68	1.30	76532.53
發生時間	15	18	4	15	5	21		6
最小值	4.98	11.25	31.35	1.23	16.20	10.59	1.25	68168.65
發生時間	22	5	18	21	10	5		12
零點偏移(率)	-0.02 %	-0.00 %	-0.03 %	-0.00 %		-0.08	-0.01	0.20 %
全幅偏移(率)	2.08 %	0.47 %	-0.04 %	-0.06 %		0.00	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.05	11.61	43.31	0.68	18.81	10.12	0.94	82402.20
1	7.51	12.19	60.03	0.99	18.37	10.73	0.94	83359.22
2	7.58	12.48	55.34	1.23	18.36	10.98	0.94	81244.40
3	7.48	12.35	56.51	1.58	17.16	10.99	0.94	81010.92
4	7.66	12.42	53.28	2.11	16.28	11.05	0.94	81718.31
5	9.03	11.81	53.87	1.78	18.12	10.43	0.94	81661.53
6	9.94	11.47	54.82	2.31	16.80	10.63	0.92	79168.88
7	9.02	11.94	57.81	1.79	16.91	10.68	0.94	79337.96
8	8.87	11.90	56.64	2.00	16.81	10.59	0.94	79986.59
9	10.84	11.97	47.94	2.45	16.51	10.58	0.94	79637.91
10	6.36	12.14	50.04	2.28	16.45	10.66	0.93	78384.53
11	7.33	12.47	52.35	1.85	16.88	10.48	0.94	79247.90
12	9.53	14.20	49.44	1.94	16.59	10.56	0.93	78738.79
13	7.64	11.16	36.23	2.53	17.43	9.80	0.94	78213.40
14	7.54	11.44	37.22	2.11	16.92	10.02	0.94	76654.93
15	7.14	11.65	44.07	1.45	17.77	9.80	0.94	78424.96
16	9.05	12.24	48.02	0.76	19.03	9.63	0.94	80367.92
17	8.52	11.25	54.67	0.79	19.41	9.77	0.94	79838.94
18	5.53	11.57	63.40	0.61	19.41	9.87	0.94	83267.04
19	8.30	11.52	48.57	1.00	18.49	10.00	0.93	81503.82
20	5.62	12.12	52.85	0.80	18.64	10.66	0.93	73358.31
21	6.07	11.39	48.13	0.69	19.18	9.86	0.94	80164.84
22	8.34	11.84	42.68	1.36	18.34	9.93	0.94	80953.06
23	7.66	11.60	49.15	1.19	17.13	10.35	0.94	81036.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.90	11.95	50.68	1.51	17.74	10.34	0.94	79986.77
最大值	10.84	14.20	63.40	2.53	19.41	11.05	0.94	83359.22
發生時間	9	12	18	13	17	4		1
最小值	5.53	11.16	36.23	0.61	16.28	9.63	0.92	73358.31
發生時間	18	13	13	18	4	16		20
零點偏移(率)	-0.13 %	-0.04 %	-0.04 %	-0.01 %		-0.09	-0.01	0.00 %
全幅偏移(率)	1.68 %	-0.82 %	0.51 %	-0.16 %		0.03	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.33	11.69	53.64	2.97	18.77	9.93	1.36	76546.03
1	4.98	12.02	61.86	3.09	18.43	10.51	1.36	75763.70
2	5.13	12.34	61.81	3.16	18.38	10.76	1.34	75892.81
3	5.46	12.38	60.67	3.23	16.50	10.98	1.36	74742.27
4	6.02	12.32	59.43	3.26	16.62	10.94	1.37	75715.13
5	6.42	12.13	62.64	3.30	17.19	10.75	1.37	75250.24
6	6.44	12.21	61.79	3.17	16.99	10.85	1.38	75074.18
7	5.82	11.68	52.39	3.69	16.37	11.01	1.36	76455.75
8	8.06	11.04	55.13	3.57	17.13	10.68	1.34	74217.21
9	8.15	10.80	53.83	3.45	18.20	10.32	1.36	75365.05
10	4.93	8.48	37.99	3.83	16.50	10.15	1.33	71737.81
11	6.74	10.83	39.55	3.14	18.39	9.82	1.31	72225.48
12	8.69	11.95	37.03	3.32	19.66	9.40	1.35	75556.26
13	8.03	10.84	40.15	3.26	18.63	9.85	1.36	73725.94
14	8.70	10.89	43.80	3.35	18.69	9.86	1.36	73912.86
15	9.03	10.62	41.74	3.43	18.45	9.84	1.32	73819.46
16	9.43	11.08	45.12	2.63	18.19	9.77	1.34	74764.88
17	9.64	11.45	47.98	1.70	18.03	9.86	1.36	73182.46
18	9.51	13.48	44.89	1.84	18.46	9.68	1.31	74437.00
19	8.65	13.25	44.51	1.78	17.94	9.51	1.34	73607.82
20	9.48	11.63	47.93	1.72	18.31	9.76	1.32	72632.49
21	9.47	11.93	46.73	1.63	18.70	9.80	1.31	74234.13
22	9.46	11.74	52.70	1.76	17.47	10.02	1.32	74139.26
23	10.24	11.45	52.25	2.46	17.11	9.87	1.32	72776.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.66	11.59	50.23	2.86	17.88	10.16	1.34	74407.30
最大值	10.24	13.48	62.64	3.83	19.66	11.01	1.39	76546.03
發生時間	23	18	5	10	12	7		0
最小值	4.93	8.48	37.03	1.63	16.37	9.40	1.30	71737.81
發生時間	10	10	12	21	7	12		10
零點偏移(率)	-0.39 %	-0.00 %	-0.01 %	0.00 %		-0.11	-0.01	-0.20 %
全幅偏移(率)	2.82 %	-0.61 %	-0.43 %	0.10 %		0.22	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								