

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月21日

報表日期: 114年04月21日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.02	3.30	47.98	1.15	17.94	10.60	1.37	82935.88
1	7.50	3.94	54.64	0.71	19.09	10.62	1.38	83028.20
2	8.01	5.26	61.46	0.95	18.48	10.48	1.37	80203.17
3	10.59	2.21	56.10	0.60	18.27	10.10	1.37	80899.40
4	8.82	3.59	56.59	1.45	17.03	10.61	1.37	80010.86
5	11.56	1.87	58.09	0.75	18.74	11.04	1.34	80497.12
6	12.67	7.90	26.28	1.48	17.22	10.50	1.34	78963.56
7	13.18	4.42	49.76	1.14	17.84	9.72	1.32	78229.88
8	9.87	3.34	55.67	1.36	15.95	10.58	1.33	76832.48
9	8.19	3.81	55.39	0.94	16.72	10.75	1.35	77895.92
10	7.89	1.65	49.26	0.91	16.91	10.97	1.34	75591.96
11	7.69	4.75	56.19	0.41	18.60	10.07	1.33	80737.95
12	11.72	4.45	52.89	0.69	17.36	10.49	1.35	80521.86
13	10.80	7.06	32.97	1.40	16.59	10.96	1.34	78495.64
14	4.69	1.58	53.15	0.58	17.48	11.50	1.34	73649.53
15	4.64	1.64	61.30	0.49	17.28	10.89	1.35	78278.21
16	8.76	3.89	42.55	1.29	16.55	10.76	1.34	79845.27
17	10.37	3.35	48.12	0.87	17.67	10.68	1.34	77013.56
18	13.35	6.79	38.70	1.30	17.61	10.25	1.34	79545.45
19	2.51	2.50	50.07	0.42	17.87	10.57	1.34	74403.00
20	4.40	8.65	45.75	0.69	18.31	9.96	1.34	78942.72
21	7.84	5.80	44.62	0.93	18.01	10.05	1.33	79751.84
22	4.21	3.01	55.04	0.59	18.13	10.58	1.34	78556.52
23	8.86	6.70	56.69	1.15	16.60	11.05	1.34	77904.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.67	4.23	50.39	0.93	17.59	10.57	1.35	78863.93
最 大 值	13.35	8.65	61.46	1.48	19.09	11.50	1.39	83028.20
發生時間	18	20	2	6	1	14		1
最 小 值	2.51	1.58	26.28	0.41	15.95	9.72	1.31	73649.53
發生時間	19	14	6	11	8	7		14
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	-0.00 %		-0.27		0.30 %
全幅偏移(率)	0.00 %	-0.46 %	0.14 %	0.46 %		0.14		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月21日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.40	7.85	54.48	3.00	14.58	11.03	1.09	82262.64
1	8.16	4.42	56.64	2.44	14.79	11.40	1.09	78982.06
2	9.82	3.53	47.08	2.49	16.44	10.41	1.08	83342.61
3	8.66	1.24	55.19	2.30	16.90	10.24	1.07	83010.75
4	9.04	3.50	58.82	2.56	16.93	10.15	1.06	85243.83
5	9.76	13.81	57.17	2.71	16.62	10.14	1.08	84556.42
6	8.69	0.94	60.19	1.53	16.13	11.12	1.09	85275.40
7	9.30	3.73	56.50	2.23	16.33	10.51	1.09	85095.08
8	8.93	1.75	53.26	2.77	15.62	10.59	1.09	83408.52
9	8.77	1.57	50.96	2.41	16.61	10.37	1.09	83181.98
10	8.78	1.82	54.33	1.87	17.57	10.02	1.10	85624.59
11	8.36	4.78	53.49	2.13	16.80	10.48	1.09	79793.10
12	8.85	4.22	47.25	1.79	18.07	10.11	1.10	81630.20
13	8.91	10.40	51.41	1.86	17.82	10.22	1.09	85654.52
14	8.99	6.70	60.05	2.27	16.82	10.74	1.09	83907.94
15	10.02	4.74	57.11	3.16	15.51	10.88	1.09	83301.27
16	10.39	4.12	55.73	2.75	16.14	10.50	1.09	85349.48
17	8.44	5.60	53.56	2.64	16.09	10.39	1.09	82846.67
18	8.51	4.86	43.09	2.65	17.43	9.47	1.09	81878.15
19	8.57	1.85	45.79	1.93	18.64	9.48	1.09	84365.36
20	9.16	4.06	47.29	2.59	17.72	9.67	1.10	86862.66
21	9.34	3.15	50.35	2.62	16.94	9.92	1.10	85647.48
22	9.07	3.51	55.57	3.43	15.99	10.75	1.10	85187.29
23	7.50	3.61	63.88	2.84	15.57	10.92	1.10	83202.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.98	4.41	53.72	2.46	16.59	10.40	1.09	83733.76
最 大 值	10.39	13.81	63.88	3.43	18.64	11.40	1.10	86862.66
發生時間	16	5	23	22	19	1		20
最 小 值	7.50	0.94	43.09	1.53	14.58	9.47	1.06	78982.06
發生時間	23	6	18	6	0	18		1
零點偏移(率)	-0.06 %	-0.00 %	-0.01 %	0.00 %		-0.01		-0.10 %
全幅偏移(率)	0.00 %	-0.88 %	-0.14 %	0.21 %		0.11		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

