

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.00	11.66	60.56	2.91	16.30	11.47	1.13	73096.47
1	9.68	11.46	62.63	2.00	19.14	10.99	1.13	74104.86
2	10.79	11.87	60.35	2.39	18.11	11.04	1.13	75171.82
3	7.71	11.79	60.89	2.20	18.15	11.38	1.12	73557.34
4	8.63	11.94	67.01	1.82	19.30	11.36	1.15	71937.97
5	6.61	10.84	48.38	1.97	19.47	10.30	1.16	80469.26
6	10.14	11.07	62.03	1.98	19.56	10.36	1.13	79151.55
7	10.21	11.20	54.15	2.19	18.44	10.85	1.13	75619.22
8	9.58	10.91	54.22	1.79	20.12	10.37	1.13	77553.15
9	12.69	11.09	52.50	2.11	19.78	10.59	1.13	76095.42
10	8.87	11.43	60.15	1.80	20.06	10.18	1.13	79763.55
11	10.27	11.34	52.37	2.75	17.90	10.86	1.13	76039.78
12	10.67	11.30	53.78	2.39	18.81	10.91	1.13	74608.50
13	9.73	11.41	52.84	2.82	17.62	11.14	1.13	73679.39
14	10.13	11.37	51.38	2.75	17.72	11.10	1.12	73695.74
15	10.83	11.35	50.25	2.50	18.28	11.01	1.11	74747.74
16	9.41	11.29	56.12	2.15	18.54	10.94	1.13	75441.53
17	10.65	11.12	50.88	2.44	18.00	10.85	1.13	76131.40
18	8.51	7.75	52.03	2.79	17.29	11.21	1.13	73684.18
19	13.87	2.15	47.89	5.03	15.63	11.34	1.13	73992.70
20	9.04	1.00	54.08	3.51	14.04	11.95	1.14	71214.77
21	9.31	0.71	50.65	3.64	14.29	11.77	1.13	72383.18
22	4.17	1.27	50.39	3.62	14.39	11.78	1.13	72428.76
23	9.28	1.11	54.33	3.12	16.97	11.49	1.13	72388.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.62	9.10	54.99	2.61	17.83	11.05	1.13	74873.19
最 大 值	13.87	11.94	67.01	5.03	20.12	11.95	1.22	80469.26
發生時間	19	4	4	19	8	20		5
最 小 值	4.17	0.71	47.89	1.79	14.04	10.18	1.10	71214.77
發生時間	22	21	19	8	20	10		20
零點偏移(率)	0.00 %	-0.00 %	-0.03 %	-0.01 %		0.02	-0.01	0.20 %
全幅偏移(率)	-1.08 %	-0.29 %	-0.02 %	0.08 %		-0.08	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月15日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.24	11.73	57.20	3.09	18.34	10.32	1.28	74777.64
1	9.08	11.44	50.30	2.93	20.70	9.50	1.27	75555.30
2	7.39	11.85	50.74	3.28	18.62	10.17	1.23	69195.31
3	9.32	11.49	45.85	3.34	18.91	9.81	1.26	72149.22
4	8.53	11.57	43.54	3.15	18.64	9.65	1.27	74471.24
5	9.22	11.49	52.45	3.33	18.71	10.06	1.26	72626.07
6	9.13	11.73	55.44	3.33	18.41	10.32	1.26	72295.92
7	10.11	10.29	53.47	3.39	18.80	9.63	1.27	75456.60
8	9.84	10.69	55.92	2.00	19.07	10.12	1.28	75741.61
9	9.15	10.55	56.81	1.59	19.05	10.19	1.28	76386.23
10	9.17	10.46	58.50	1.56	18.80	10.09	1.29	76371.89
11	9.09	10.52	55.91	1.54	17.58	10.30	1.28	76314.95
12	10.99	10.87	61.68	1.57	17.61	10.47	1.27	74535.26
13	12.01	10.49	58.90	1.67	17.85	10.28	1.27	75050.66
14	7.60	10.35	54.93	1.57	18.10	10.07	1.27	75511.88
15	9.32	10.87	55.81	1.54	18.59	9.94	1.27	78126.26
16	9.68	10.36	51.46	1.49	18.09	9.93	1.27	78301.46
17	10.18	12.14	51.81	2.85	17.22	9.78	1.27	76054.24
18	9.74	10.46	50.24	1.21	18.15	9.83	1.25	75768.59
19	8.35	11.42	51.57	2.29	16.81	10.23	1.23	74854.37
20	11.04	11.41	52.45	3.04	17.53	9.99	1.23	75219.91
21	9.22	11.55	56.98	2.98	17.55	10.20	1.23	75386.21
22	11.30	11.40	58.04	3.25	17.91	10.01	1.24	75551.35
23	8.57	11.33	53.71	3.22	18.75	9.83	1.27	76637.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.43	11.10	53.90	2.47	18.32	10.03	1.26	75097.50
最 大 值	12.01	12.14	61.68	3.39	20.70	10.47	1.30	78301.46
發生時間	13	17	12	7	1	12		16
最 小 值	7.39	10.29	43.54	1.21	16.81	9.50	1.23	69195.31
發生時間	2	7	4	18	19	1		2
零點偏移(率)	-0.09 %	0.01 %	-0.02 %	-0.01 %		0.00	-0.01	0.00 %
全幅偏移(率)	-0.17 %	-0.01 %	-0.06 %	0.07 %		0.15	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								