

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.80	13.71	59.00	1.54	16.55	11.87	1.29	75484.92
1	7.18	13.71	59.68	1.38	18.41	11.66	1.29	77494.31
2	10.14	13.60	53.54	2.80	16.34	11.81	1.31	75352.00
3	4.30	13.95	58.11	1.90	16.32	12.11	1.31	72674.51
4	12.01	13.81	60.90	2.34	16.44	11.97	1.29	74993.65
5	8.01	13.49	52.53	2.01	17.40	11.82	1.29	72540.73
6	9.81	13.41	51.05	1.88	18.02	11.64	1.27	76912.56
7	10.35	13.55	65.14	2.50	16.91	11.89	1.27	76896.98
8	8.44	12.69	52.21	2.03	18.15	10.96	1.29	82899.06
9	10.63	11.33	62.38	1.55	19.40	10.54	1.31	85470.85
10	9.45	11.48	47.19	2.64	16.83	11.30	1.29	81209.56
11	9.92	11.45	48.02	2.27	17.69	10.99	1.29	83046.24
12	8.35	11.52	45.65	2.05	17.50	11.14	1.29	82341.92
13	8.43	11.56	41.94	2.56	16.32	11.43	1.29	81553.06
14	9.33	11.79	43.25	2.16	17.19	11.49	1.29	78797.09
15	12.17	11.54	36.70	2.13	17.65	11.06	1.30	81185.03
16	6.64	11.87	41.91	1.69	18.24	11.09	1.30	81425.04
17	10.95	11.70	41.35	2.87	16.79	11.05	1.29	81324.06
18	7.66	11.43	55.91	1.84	17.50	11.09	1.27	79984.58
19	10.97	11.83	59.78	3.14	15.10	11.65	1.27	80129.51
20	6.29	12.17	53.06	1.65	16.76	11.69	1.27	78790.59
21	11.32	12.24	44.48	1.85	17.12	11.66	1.27	77308.54
22	8.87	11.76	36.16	2.02	17.02	11.22	1.27	79951.17
23	10.24	11.62	42.89	2.01	16.95	11.18	1.27	81334.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.18	12.38	50.53	2.12	17.19	11.43	1.29	79129.20
最大值	12.17	13.95	65.14	3.14	19.40	12.11	1.31	85470.85
發生時間	15	3	7	19	9	3		9
最小值	4.30	11.33	36.16	1.38	15.10	10.54	1.26	72540.73
發生時間	3	9	22	1	19	9		5
零點偏移(率)	-0.06 %	0.01 %	-0.02 %	-0.01 %		-0.06	-0.01	0.40 %
全幅偏移(率)	-1.24 %	-1.06 %	-0.29 %	-0.28 %		0.09	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.83	11.63	30.19	1.76	18.54	9.90	1.02	78924.29
1	7.49	11.73	38.69	2.66	18.22	10.15	1.02	78330.31
2	11.16	11.98	46.60	2.17	18.49	10.36	1.02	76389.70
3	9.13	11.95	41.81	2.07	18.19	10.01	1.02	79520.47
4	11.36	12.49	47.52	2.54	18.27	10.23	1.01	82406.65
5	8.18	12.46	59.99	2.36	17.63	10.90	0.99	79957.25
6	7.12	13.23	58.89	2.11	15.27	11.73	0.99	79709.08
7	11.27	12.78	52.50	1.24	17.70	10.25	0.98	82131.84
8	7.64	11.68	48.94	1.11	18.65	10.27	1.01	82231.68
9	7.49	12.05	47.34	1.28	19.61	10.04	1.02	83626.65
10	6.27	11.74	40.75	1.96	17.81	10.32	1.02	79448.91
11	13.43	11.87	50.09	2.48	17.49	10.58	1.02	81075.75
12	6.49	11.81	52.55	1.58	17.79	10.52	1.01	81927.46
13	12.63	11.95	50.40	1.56	17.49	10.70	1.02	80688.61
14	8.11	12.06	49.57	2.59	15.97	10.77	1.02	78583.01
15	8.23	11.66	41.90	1.70	17.26	10.43	1.02	79821.87
16	12.42	11.45	42.78	1.75	17.37	10.24	1.02	80705.55
17	9.18	11.34	37.57	1.45	17.33	10.14	1.00	81283.77
18	6.84	11.38	43.59	2.02	16.59	10.26	0.98	79459.17
19	10.79	11.63	43.48	2.10	16.74	10.31	0.97	80342.75
20	8.54	11.70	50.64	1.27	17.68	10.29	0.99	82749.76
21	7.63	12.01	46.56	1.66	16.73	10.72	0.98	79067.39
22	9.43	12.01	50.96	1.31	17.38	10.39	0.97	81090.27
23	14.85	11.74	46.64	1.70	16.55	10.47	0.99	78890.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.40	11.93	46.66	1.85	17.53	10.42	1.00	80348.43
最大值	14.85	13.23	59.99	2.66	19.61	11.73	1.02	83626.65
發生時間	23	6	5	1	9	6		9
最小值	6.27	11.34	30.19	1.11	15.27	9.90	0.97	76389.70
發生時間	10	17	0	8	6	0		2
零點偏移(率)	-0.08 %	-0.01 %	-0.04 %	-0.01 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	-0.24 %	-1.81 %	-0.39 %	-0.05 %		0.08	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.43	11.82	52.97	2.87	18.26	9.58	1.39	76924.60
1	8.64	12.53	55.48	2.89	20.03	9.48	1.39	77679.31
2	5.92	12.36	67.29	3.08	17.21	10.76	1.38	68039.18
3	5.05	11.68	50.44	2.82	17.57	10.08	1.37	72613.46
4	6.92	11.33	46.18	2.98	17.44	9.75	1.39	75727.89
5	10.98	13.21	47.10	3.44	16.69	9.92	1.40	75865.12
6	8.73	12.23	46.55	2.84	18.01	9.53	1.41	80082.25
7	12.30	11.80	47.34	3.19	18.08	9.68	1.43	80670.29
8	7.20	11.71	47.06	1.73	17.99	9.72	1.43	76996.01
9	9.38	11.69	53.33	1.49	17.01	10.14	1.43	77695.74
10	8.83	11.38	44.25	1.41	17.79	9.90	1.43	75740.76
11	9.22	12.38	44.65	1.65	16.51	9.97	1.41	74620.48
12	9.08	11.36	44.23	1.46	16.74	9.99	1.41	74210.38
13	7.34	13.35	38.32	2.54	16.95	9.57	1.41	73675.47
14	9.54	11.80	44.90	1.53	16.30	9.86	1.41	72515.18
15	8.99	11.73	44.09	1.33	17.46	9.49	1.41	74304.18
16	9.77	11.96	37.73	1.40	18.57	9.02	1.41	77344.27
17	10.19	12.22	37.93	1.55	17.48	9.33	1.42	74463.95
18	9.31	12.29	48.33	1.56	17.68	9.31	1.41	75520.20
19	7.66	12.00	43.26	2.22	16.88	9.78	1.42	74433.05
20	9.31	11.19	48.16	2.70	17.57	9.83	1.42	74966.55
21	9.13	13.11	48.00	2.92	17.08	9.69	1.43	74916.65
22	9.63	11.79	44.11	1.84	17.28	9.58	1.41	75084.82
23	7.92	10.84	47.91	2.63	17.67	9.61	1.43	75639.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.69	11.99	47.07	2.25	17.51	9.73	1.41	75405.39
最大值	12.30	13.35	67.29	3.44	20.03	10.76	1.43	80670.29
發生時間	7	13	2	5	1	2		7
最小值	5.05	10.84	37.73	1.33	16.30	9.02	1.36	68039.18
發生時間	3	23	16	15	14	16		2
零點偏移(率)	-0.04 %	-0.01 %	-0.06 %	-0.01 %		-0.05	-0.01	0.00 %
全幅偏移(率)	0.79 %	-0.19 %	-0.06 %	0.01 %		0.10	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								