

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.76	3.63	60.38	3.18	14.45	12.29	1.45	70200.34
1	0.35	3.69	62.67	2.48	16.29	12.41	1.50	68271.70
2	0.15	3.77	62.47	2.41	16.12	12.33	1.47	68885.85
3	0.08	6.14	55.06	2.95	14.88	12.58	1.42	68673.84
4	0.46	3.46	56.45	3.03	14.48	12.22	1.42	71979.08
5	3.71	4.36	62.18	2.68	15.51	12.02	1.44	67975.46
6	11.19	3.62	51.02	3.66	14.19	12.44	1.46	69640.65
7	8.59	3.14	55.89	2.88	15.67	12.15	1.46	71089.66
8	9.02	3.30	70.21	2.64	16.16	12.25	1.46	70585.37
9	9.71	3.24	46.64	2.86	15.95	12.06	1.45	72243.07
10	9.02	3.49	48.46	3.35	14.75	12.39	1.42	70269.29
11	9.27	4.21	55.19	3.71	13.73	12.57	1.43	68988.70
12	9.21	4.16	61.18	3.32	14.61	12.55	1.43	68659.70
13	10.08	5.39	52.18	3.67	14.41	12.40	1.41	70022.31
14	10.82	10.66	50.63	4.38	12.57	12.63	1.44	69840.92
15	10.44	3.19	53.31	4.19	12.84	12.64	1.47	69541.52
16	11.20	3.35	54.72	4.74	12.16	12.74	1.46	69546.34
17	11.03	2.29	55.08	4.11	13.28	12.54	1.46	69834.82
18	8.89	2.21	57.71	3.64	13.99	12.45	1.44	70693.86
19	12.51	2.33	56.75	3.51	14.00	12.28	1.41	71606.95
20	9.77	2.03	53.36	3.53	13.94	12.26	1.41	71916.76
21	8.53	3.34	50.66	3.61	13.64	12.39	1.43	71496.07
22	9.16	5.17	58.03	2.69	15.66	11.77	1.46	75311.66
23	6.78	5.94	49.47	3.64	13.46	12.40	1.46	71182.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.74	4.00	55.82	3.37	14.45	12.36	1.44	70352.33
最大值	12.51	10.66	70.21	4.74	16.29	12.74	1.58	75311.66
發生時間	19	14	8	16	1	16		22
最小值	0.08	2.03	46.64	2.41	12.16	11.77	1.40	67975.46
發生時間	3	20	9	2	16	22		5
零點偏移(率)	-0.01 %	-0.01 %	0.00 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	3.16 %	0.51 %	-0.61 %	0.29 %		0.14	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.22	5.83	61.21	1.65	17.90	10.58	1.38	82923.84
1	4.18	6.05	55.51	0.88	20.62	10.22	1.38	85225.48
2	8.85	7.41	52.15	1.53	19.43	10.14	1.36	86414.33
3	8.65	6.27	59.72	1.88	18.15	10.86	1.36	81473.80
4	3.58	6.88	63.09	1.57	17.93	11.43	1.36	76934.74
5	8.47	5.07	50.75	1.60	18.68	10.20	1.35	87471.23
6	0.18	10.49	74.59	1.51	17.27	11.50	1.37	75434.32
7	0.83	4.84	54.16	1.64	16.92	11.20	1.38	78891.95
8	3.77	3.96	44.05	1.26	19.27	9.98	1.38	85288.55
9	6.87	4.27	55.54	1.61	18.04	10.31	1.38	86265.54
10	8.43	3.66	49.77	1.56	18.76	10.38	1.38	85045.95
11	4.29	5.59	49.35	1.51	18.10	10.62	1.39	82182.87
12	9.61	3.92	61.55	2.03	17.86	10.85	1.38	81256.03
13	10.00	4.05	50.86	2.16	17.04	10.51	1.38	83664.65
14	10.82	6.63	54.08	2.56	15.41	10.60	1.38	81726.67
15	9.21	1.98	53.98	2.38	15.77	10.64	1.37	80745.23
16	10.38	1.74	53.42	2.52	16.11	10.53	1.41	82499.87
17	10.64	1.81	52.16	2.13	16.70	10.34	1.43	82312.47
18	10.38	2.07	48.13	2.45	17.21	10.15	1.41	81531.61
19	9.94	1.67	54.27	1.89	17.58	10.28	1.38	83404.90
20	10.17	3.77	60.20	1.55	18.50	10.30	1.38	85780.68
21	11.47	2.63	45.61	2.51	15.92	10.55	1.38	83980.70
22	9.40	1.93	53.72	2.01	16.96	10.35	1.38	85962.12
23	10.22	5.06	54.38	2.19	16.62	10.68	1.38	81726.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.90	4.48	54.68	1.86	17.61	10.55	1.38	82839.34
最大值	11.47	10.49	74.59	2.56	20.62	11.50	1.43	87471.23
發生時間	21	6	6	14	1	6		5
最小值	0.18	1.67	44.05	0.88	15.41	9.98	1.33	75434.32
發生時間	6	19	8	1	14	8		6
零點偏移(率)	-0.02 %	-0.02 %	-0.01 %	0.00 %		-0.06	0.00	0.00 %
全幅偏移(率)	0.91 %	0.93 %	-0.30 %	0.25 %		-0.03	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.25	2.08	62.51	1.82	17.14	10.71	1.75	82015.61
1	7.03	3.41	52.47	1.60	17.63	10.71	1.75	82916.31
2	11.12	2.25	59.54	1.98	17.46	10.56	1.74	83209.21
3	8.59	1.93	64.20	1.87	17.45	10.60	1.74	85144.29
4	7.57	4.42	61.05	1.94	19.11	10.03	1.75	88135.34
5	7.28	1.91	57.00	1.79	18.36	10.33	1.74	86311.77
6	13.55	3.57	63.62	2.18	17.27	10.79	1.73	83901.28
7	11.25	3.47	52.62	1.76	18.48	9.98	1.76	81335.37
8	9.87	1.81	58.38	1.73	17.31	10.85	1.76	81703.81
9	7.10	1.58	65.53	1.68	17.63	10.82	1.77	82505.45
10	7.15	1.82	50.82	1.59	17.52	10.33	1.79	85185.15
11	3.55	1.47	64.75	1.87	15.97	11.14	1.80	79968.63
12	3.66	1.30	59.75	1.59	16.78	11.00	1.80	81672.18
13	11.37	2.48	69.83	2.77	14.82	11.44	1.80	79437.62
14	9.94	4.93	58.18	2.93	14.14	11.05	1.80	82037.64
15	7.16	3.42	58.87	4.18	13.52	11.42	1.78	79384.78
16	7.78	3.20	61.94	2.48	14.73	11.05	1.80	81759.05
17	8.79	2.03	65.96	2.06	16.06	10.92	1.80	83515.47
18	6.43	2.29	62.40	1.86	16.18	10.89	1.81	83130.07
19	5.84	2.76	56.44	1.81	15.72	10.76	1.78	84064.04
20	5.42	2.93	61.92	2.28	14.45	10.97	1.76	83637.24
21	7.74	3.90	57.83	2.57	13.91	11.17	1.74	81763.36
22	1.86	4.26	60.76	2.80	14.47	12.08	1.76	69362.31
23	7.57	5.19	53.41	2.25	15.63	10.67	1.80	84064.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.74	2.85	59.99	2.14	16.32	10.84	1.77	82340.04
最大值	13.55	5.19	69.83	4.18	19.11	12.08	1.82	88135.34
發生時間	6	23	13	15	4	22		4
最小值	1.86	1.30	50.82	1.59	13.52	9.98	1.67	69362.31
發生時間	22	12	10	10	15	7		22
零點偏移(率)	-0.02 %	-0.02 %	-0.07 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	0.77 %	0.27 %	-0.74 %	0.21 %		0.03	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								