

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.12	6.74	50.91	0.78	18.74	11.12	1.36	78846.07
1	11.28	9.08	50.80	0.94	18.43	11.36	1.38	77272.01
2	11.41	3.39	53.50	0.91	18.80	11.13	1.40	78480.51
3	9.75	2.98	44.90	0.98	19.15	10.98	1.40	79648.61
4	9.87	2.96	53.62	0.94	18.48	11.24	1.40	78720.00
5	2.30	4.44	52.43	0.65	18.73	11.26	1.41	77479.10
6	8.82	1.46	54.77	0.92	18.30	11.52	1.41	76068.21
7	8.14	1.82	52.16	0.89	18.07	11.26	1.41	78041.83
8	9.89	4.36	56.04	1.11	17.86	11.83	1.44	74269.88
9	8.44	1.56	52.52	0.78	18.83	11.24	1.44	77983.09
10	10.35	4.92	46.45	1.10	17.09	11.62	1.45	76295.03
11	13.32	10.25	48.02	1.45	16.52	11.97	1.41	73307.89
12	8.88	1.20	60.96	0.62	19.16	11.30	1.45	77662.74
13	8.36	1.75	51.98	0.91	17.55	11.93	1.45	73504.83
14	6.02	2.80	68.69	0.86	17.55	12.69	1.46	67980.89
15	8.21	2.21	64.46	0.75	19.08	11.50	1.46	75924.69
16	10.47	2.65	59.39	2.11	18.84	11.19	1.46	78240.40
17	10.47	1.88	50.72	1.14	19.06	10.86	1.42	80808.60
18	10.69	2.75	51.93	1.08	18.05	11.34	1.45	78102.71
19	7.29	0.81	48.85	0.40	20.18	10.78	1.45	80759.20
20	8.85	0.85	54.70	0.55	19.65	11.05	1.41	78773.73
21	8.17	1.72	57.95	0.42	20.27	10.89	1.40	79652.60
22	7.88	1.06	54.75	0.33	20.48	10.85	1.44	79508.01
23	9.08	1.03	59.01	0.41	20.29	10.89	1.44	79907.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.09	3.11	54.15	0.88	18.72	11.33	1.43	77384.90
最大值	13.32	10.25	68.69	2.11	20.48	12.69	1.57	80808.60
發生時間	11	11	14	16	22	14		17
最小值	2.30	0.81	44.90	0.33	16.52	10.78	1.35	67980.89
發生時間	5	19	3	22	11	19		14
零點偏移(率)	-0.22 %	-0.00 %	0.00 %	0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	-2.80 %	-0.12 %	-0.09 %	-0.06 %		0.24	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.19	7.04	55.47	2.41	15.88	10.51	1.39	64428.16
1	8.86	1.49	60.31	2.02	17.47	10.61	1.38	63370.59
2	11.38	1.24	57.33	3.02	16.11	10.39	1.38	64762.32
3	9.53	2.60	56.22	3.21	15.71	10.36	1.38	64158.91
4	10.49	3.13	51.26	2.74	16.19	10.20	1.41	65762.43
5	8.37	3.64	51.74	2.73	15.66	10.29	1.41	63039.64
6	6.41	8.09	51.32	2.30	14.96	10.88	1.41	59962.18
7	5.52	1.32	56.08	1.82	16.20	10.95	1.42	64611.45
8	10.60	3.06	53.41	2.22	15.33	11.05	1.42	64714.67
9	8.59	2.01	59.05	2.29	14.93	11.29	1.42	62205.98
10	5.23	1.99	57.22	2.23	14.10	11.30	1.40	63335.24
11	10.23	4.22	64.76	2.79	15.01	11.30	1.43	60488.81
12	6.64	1.04	67.77	3.05	15.45	11.35	1.42	63348.11
13	0.70	1.10	62.69	1.86	15.13	11.26	1.38	63692.25
14	0.24	4.13	61.56	2.02	14.81	11.67	1.38	59711.46
15	4.69	1.51	55.06	2.15	14.74	11.27	1.37	64934.26
16	9.31	2.17	55.62	1.88	16.65	10.58	1.38	66294.78
17	10.16	6.34	56.61	2.17	15.01	11.07	1.42	65457.62
18	6.77	5.37	62.73	1.85	16.42	10.91	1.37	64112.86
19	10.90	3.90	65.85	1.68	17.73	10.52	1.41	67685.77
20	10.00	4.09	62.55	1.66	18.04	10.43	1.43	67931.02
21	7.87	3.57	63.04	1.26	18.65	10.84	1.39	64775.07
22	11.47	5.02	45.64	1.46	18.14	9.87	1.37	69804.21
23	8.67	2.99	49.09	1.40	18.31	9.81	1.38	68088.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.08	3.38	57.60	2.18	16.11	10.78	1.40	64444.84
最大值	11.47	8.09	67.77	3.21	18.65	11.67	1.50	69804.21
發生時間	22	6	12	3	21	14		22
最小值	0.24	1.04	45.64	1.26	14.10	9.81	1.36	59711.46
發生時間	14	12	22	21	10	23		14
零點偏移(率)	-0.04 %	-0.00 %	-0.00 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	-0.76 %	-0.02 %	0.19 %	0.04 %		0.15	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.83	1.32	62.44	2.08	15.11	11.27	1.27	83748.19
1	8.28	5.78	56.41	2.25	14.86	11.01	1.25	84755.49
2	7.84	8.63	53.24	2.54	14.77	10.58	1.24	85790.66
3	9.38	3.19	51.59	2.73	14.43	10.49	1.22	82956.00
4	8.53	2.78	54.79	2.70	13.95	10.89	1.23	83002.65
5	7.03	1.50	57.79	2.32	14.95	10.51	1.24	86253.20
6	7.72	4.59	53.30	2.99	13.45	11.04	1.25	81700.33
7	9.52	7.16	58.75	2.37	13.88	11.37	1.30	80439.68
8	7.99	9.49	61.36	2.07	14.35	11.55	1.28	84062.56
9	9.07	6.83	52.77	1.71	15.15	10.60	1.30	84838.82
10	8.71	10.20	61.52	2.41	13.94	10.98	1.27	81525.48
11	7.52	3.45	61.69	1.78	14.75	11.11	1.30	82127.43
12	7.21	4.17	61.91	1.58	15.24	10.92	1.26	84724.69
13	6.25	5.28	71.86	1.68	15.33	11.41	1.26	80993.70
14	3.32	3.83	66.24	1.29	15.78	11.15	1.26	83058.43
15	7.34	17.69	57.89	1.68	14.95	10.79	1.26	85424.88
16	11.71	2.22	51.95	1.79	15.05	10.41	1.25	83194.64
17	5.86	1.35	62.64	1.70	14.73	11.06	1.29	83124.55
18	8.02	1.17	62.62	1.51	15.56	11.00	1.29	85791.62
19	6.33	4.56	59.60	1.13	17.67	10.38	1.25	90686.67
20	7.38	1.11	57.79	1.22	18.13	10.28	1.25	89842.05
21	8.90	1.64	58.11	1.22	16.46	11.05	1.30	86714.09
22	5.59	7.77	62.25	1.29	17.04	10.80	1.27	87120.96
23	10.87	1.95	55.77	1.49	15.72	10.91	1.25	85480.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.80	4.90	58.93	1.90	15.22	10.90	1.26	84473.22
最大值	11.71	17.69	71.86	2.99	18.13	11.55	1.37	90686.67
發生時間	16	15	13	6	20	8		19
最小值	3.32	1.11	51.59	1.13	13.45	10.28	1.20	80439.68
發生時間	14	20	3	19	6	20		7
零點偏移(率)	-0.01 %	0.00 %	-0.20 %	-0.03 %		0.03	0.00	0.00 %
全幅偏移(率)	0.02 %	0.08 %	0.01 %	0.02 %		0.48	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								