

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.89	11.33	56.75	0.81	19.29	11.25	1.07	77260.89
1	9.84	11.37	51.32	1.30	18.40	11.28	1.07	77696.67
2	4.19	10.89	53.15	1.06	17.37	11.45	1.07	76142.58
3	8.22	10.65	56.07	1.04	17.70	11.26	1.05	77630.80
4	2.40	13.46	64.61	1.07	17.31	12.11	1.05	73133.54
5	4.96	12.94	52.19	2.09	16.57	11.79	1.05	77783.35
6	5.49	13.64	56.77	1.32	17.53	11.51	1.05	78336.16
7	8.14	11.11	57.03	1.71	16.84	11.76	1.06	76977.14
8	7.40	3.51	54.71	1.11	17.45	11.64	1.06	74397.77
9	6.35	3.82	60.37	0.74	18.04	11.61	1.09	74942.31
10	2.45	3.66	48.59	1.00	17.00	11.61	1.08	74736.62
11	0.69	3.83	63.99	0.47	17.71	11.79	1.07	74576.61
12	1.79	4.37	48.42	1.07	16.83	11.50	1.08	75744.11
13	3.10	5.08	50.53	1.68	16.15	11.76	1.08	73134.66
14	6.62	4.66	59.98	0.87	17.96	11.37	1.07	75711.60
15	8.13	6.59	49.34	1.34	16.68	11.63	1.07	74143.93
16	4.40	7.68	54.21	0.91	17.50	11.68	1.07	73847.19
17	4.80	6.80	62.03	0.45	18.87	11.22	1.08	78437.02
18	6.12	7.73	45.85	0.95	17.12	11.48	1.08	76971.47
19	0.85	9.51	68.87	0.58	18.27	12.14	1.07	73358.59
20	5.95	8.68	45.58	0.86	18.10	11.30	1.05	79835.54
21	8.89	12.54	49.25	1.29	16.33	11.74	1.06	76651.72
22	6.34	10.56	48.80	1.78	15.82	11.78	1.07	74491.10
23	6.29	9.82	57.88	0.95	17.81	11.52	1.09	77914.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.43	8.51	54.85	1.10	17.44	11.59	1.07	75994.00
最大值	9.84	13.64	68.87	2.09	19.29	12.14	1.10	79835.54
發生時間	1	6	19	5	0	19		20
最小值	0.69	3.51	45.58	0.45	15.82	11.22	1.05	73133.54
發生時間	11	8	20	17	22	17		4
零點偏移(率)	-0.05 %	-0.01 %	-0.01 %	-0.00 %		-0.04		0.00 %
全幅偏移(率)	0.00 %	0.01 %	-0.41 %	0.41 %		-0.15		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.80	8.45	49.70	1.92	18.09	10.63	1.10	80078.52
1	4.91	7.17	55.80	1.93	18.61	10.32	1.10	80601.58
2	5.39	7.63	44.82	1.51	19.53	9.67	1.10	84182.59
3	8.44	8.68	46.76	1.42	19.18	9.76	1.10	85351.04
4	7.34	6.94	50.74	1.99	17.66	10.32	1.10	83319.31
5	6.71	6.36	59.44	1.30	19.18	9.75	1.10	85642.50
6	4.83	9.06	45.14	2.10	16.60	10.42	1.10	80810.98
7	7.70	10.89	45.29	1.74	18.74	10.01	1.10	81148.70
8	8.08	3.17	45.61	1.34	19.39	9.41	1.10	87344.22
9	7.67	5.10	50.06	1.50	17.68	10.20	1.10	81268.12
10	1.13	6.28	45.87	1.51	17.81	10.06	1.11	77434.10
11	0.06	2.51	50.66	0.96	18.47	9.91	1.13	82124.63
12	0.71	8.71	41.62	2.37	16.54	10.23	1.11	77387.46
13	1.03	7.44	61.07	0.83	20.17	9.54	1.10	82952.12
14	9.34	7.26	49.59	1.78	18.71	9.44	1.10	88147.60
15	10.25	5.51	51.12	2.41	17.08	10.30	1.10	83439.80
16	8.66	4.00	60.59	1.13	19.26	9.84	1.10	84976.61
17	9.08	4.53	43.32	1.36	19.14	9.97	1.10	83859.74
18	7.12	3.99	59.15	0.74	19.50	10.08	1.10	82157.45
19	8.41	6.56	52.25	1.25	19.02	9.71	1.11	85952.15
20	9.64	5.09	60.22	1.09	19.54	9.60	1.10	85869.50
21	9.31	5.96	48.66	1.87	17.83	10.20	1.09	83549.82
22	7.24	5.73	51.30	2.23	16.89	10.54	1.08	81978.61
23	4.57	6.66	58.76	0.76	20.36	10.07	1.10	82154.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.39	6.40	51.15	1.54	18.54	10.00	1.10	82988.83
最大值	10.25	10.89	61.07	2.41	20.36	10.63	1.14	88147.60
發生時間	15	7	13	15	23	0		14
最小值	0.06	2.51	41.62	0.74	16.54	9.41	1.08	77387.46
發生時間	11	11	12	18	12	8		12
零點偏移(率)	-0.05 %	-0.01 %	-0.02 %	0.00 %		-0.17		0.00 %
全幅偏移(率)	-4.06 %	-0.29 %	-1.32 %	0.48 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.91	9.59	54.77	0.79	16.96	10.82	1.02	81155.78
1	1.90	9.94	55.61	1.53	15.52	11.27	1.02	77506.39
2	2.56	10.97	54.72	1.13	16.47	10.65	1.05	79964.96
3	0.89	9.47	52.16	1.08	15.65	10.98	1.06	76374.27
4	1.25	12.38	51.04	0.82	17.17	10.06	1.07	83104.41
5	2.21	9.39	53.15	0.86	16.35	10.39	1.07	80246.23
6	3.48	9.12	55.17	0.95	16.16	10.25	1.05	79007.78
7	1.13	8.61	60.47	0.53	17.38	10.41	1.09	71875.95
8	1.43	5.43	51.64	0.57	18.46	9.43	1.06	79602.11
9	5.94	3.01	59.59	1.17	16.85	9.44	1.10	82765.46
10	7.10	7.43	48.35	1.85	14.28	10.68	1.10	74291.82
11	4.82	4.67	47.50	1.69	14.23	10.95	1.06	73169.16
12	2.21	5.88	43.95	0.81	16.07	10.41	1.06	73007.40
13	0.00	3.77	42.59	0.80	15.56	10.53	1.07	72380.98
14	1.39	4.11	50.06	0.53	16.08	10.96	1.10	71352.28
15	6.80	6.62	45.74	1.99	16.04	10.44	1.10	76953.89
16	5.10	3.19	45.76	1.46	15.92	10.71	1.10	76513.35
17	0.47	2.10	49.13	0.78	16.00	10.50	1.08	79768.98
18	0.33	2.71	62.30	0.41	17.51	10.80	1.06	81009.89
19	0.71	5.95	45.62	0.45	17.08	10.69	1.08	83658.12
20	1.24	6.89	49.54	0.74	16.36	10.89	1.10	82772.07
21	8.68	13.61	53.34	1.15	15.85	11.18	1.10	80511.80
22	3.18	6.95	56.44	1.14	15.44	11.29	1.08	80121.09
23	1.18	9.21	56.10	0.76	16.63	11.28	1.07	80007.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.75	7.12	51.86	1.00	16.25	10.63	1.07	78213.39
最大值	8.68	13.61	62.30	1.99	18.46	11.29	1.12	83658.12
發生時間	21	21	18	15	8	22		19
最小值	0.00	2.10	42.59	0.41	14.23	9.43	1.02	71352.28
發生時間	13	17	13	18	11	8		14
零點偏移(率)	-0.01 %	0.00 %	-0.23 %	-0.02 %		-0.06		0.00 %
全幅偏移(率)	0.04 %	0.06 %	-0.53 %	0.34 %		0.03		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								