

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.50	2.65	63.28	1.41	18.68	11.54	1.06	80894.99
1	11.19	3.20	56.34	3.05	19.22	11.29	1.06	82300.04
2	9.61	4.58	52.54	2.42	17.69	11.52	1.06	81899.28
3	10.57	4.15	54.91	1.78	17.34	11.63	1.06	81313.87
4	8.75	4.05	58.52	1.32	17.36	11.62	1.05	81117.44
5	8.98	2.44	50.93	2.01	15.26	11.90	1.04	79768.73
6	8.80	3.44	48.87	2.68	15.47	11.86	1.02	79254.83
7	9.98	3.24	54.78	2.82	15.37	12.26	1.03	77652.30
8	8.77	3.15	50.86	1.74	16.91	11.52	1.05	81795.68
9	6.81	3.20	47.34	2.19	15.40	11.96	1.06	76448.83
10	6.74	3.12	42.60	2.43	15.39	11.79	1.04	77612.47
11	8.27	3.56	47.11	2.30	15.41	11.94	1.03	75464.17
12	6.82	5.05	58.15	1.45	16.47	11.74	1.06	77881.73
13	1.65	3.70	66.49	0.76	17.30	12.06	1.06	73627.26
14	0.14	4.90	44.57	0.58	18.62	12.55	1.07	72205.60
15	0.83	4.34	32.15	0.70	19.27	11.52	1.05	80114.12
16	10.08	4.24	33.99	2.21	16.97	11.30	1.04	83607.52
17	10.59	5.39	37.84	1.94	17.04	11.65	1.05	81308.55
18	8.51	2.57	37.88	2.18	16.18	11.86	1.05	80580.11
19	8.29	4.11	42.27	1.58	17.65	11.42	1.04	82587.35
20	8.32	2.31	42.84	2.06	17.13	11.55	1.02	81853.60
21	8.85	2.44	54.28	2.00	17.14	11.49	1.02	82711.43
22	10.07	3.21	64.82	1.74	16.95	11.81	1.04	79980.79
23	10.04	2.98	57.97	1.57	17.18	11.79	1.05	80050.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.05	3.58	50.06	1.87	16.97	11.73	1.05	79667.95
最 大 值	11.19	5.39	66.49	3.05	19.27	12.55	1.09	83607.52
發生時間	1	17	13	1	15	14		16
最 小 值	0.14	2.31	32.15	0.58	15.26	11.29	1.02	72205.60
發生時間	14	20	15	14	5	1		14
零點偏移(率)	-0.04 %	-0.07 %	-0.08 %	-0.05 %		-0.05		0.00 %
全幅偏移(率)	0.00 %	-0.52 %	-0.15 %	0.11 %		0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月01日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.35	2.00	58.08	1.29	18.87	10.74	0.99	81872.30
1	9.71	2.27	52.23	1.79	18.43	10.68	0.99	82680.52
2	9.99	3.24	53.22	1.42	18.23	10.57	0.99	84140.99
3	10.47	4.44	49.36	1.98	16.62	11.15	1.00	80659.45
4	12.07	4.33	51.37	2.98	15.73	11.33	1.01	79348.77
5	10.02	1.44	48.30	3.10	14.95	11.40	1.00	78550.99
6	8.32	1.97	49.48	1.45	15.19	11.34	1.00	83746.09
7	9.92	4.46	51.10	2.23	15.47	11.31	0.99	80232.43
8	9.18	0.94	62.95	1.65	17.03	11.06	0.98	81081.26
9	9.34	1.20	65.02	2.69	15.62	11.26	0.98	80784.53
10	9.56	4.46	60.59	2.37	16.45	11.13	0.98	80726.04
11	9.14	3.36	57.06	1.37	17.18	11.04	1.01	80950.29
12	8.03	2.36	62.24	1.24	16.52	11.72	1.00	75921.04
13	8.98	2.07	60.28	0.75	18.59	10.97	1.00	80023.63
14	10.10	4.88	31.65	1.23	18.43	10.58	0.99	82841.50
15	9.75	1.89	36.72	2.62	15.69	11.31	1.00	79938.40
16	8.59	3.41	43.57	1.47	16.69	11.03	0.99	81584.76
17	8.91	1.63	37.79	1.86	16.52	10.90	1.00	82063.75
18	8.66	1.57	40.74	1.64	17.27	10.81	0.99	82645.19
19	8.86	1.73	36.80	1.40	18.39	10.38	1.01	84695.47
20	9.61	1.54	38.65	1.96	17.27	10.56	0.98	84161.37
21	9.83	1.83	51.79	1.36	18.19	10.41	0.97	84867.94
22	9.39	2.15	68.54	1.44	18.36	10.77	0.98	81852.77
23	9.31	2.65	48.17	1.23	18.92	10.63	0.97	82902.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.55	2.58	50.65	1.77	17.11	10.96	0.99	81594.65
最 大 值	12.07	4.88	68.54	3.10	18.92	11.72	1.02	84867.94
發生時間	4	14	22	5	23	12		21
最 小 值	8.03	0.94	31.65	0.75	14.95	10.38	0.96	75921.04
發生時間	12	8	14	13	5	19		12
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.02 %		-0.09		-0.10 %
全幅偏移(率)	0.13 %	0.44 %	0.14 %	0.74 %		-0.27		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

