

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.13	3.28	64.87	2.86	15.66	12.46	1.40	67401.85
1	7.62	3.93	52.44	2.77	16.21	12.59	1.39	66560.78
2	5.42	3.32	65.44	2.52	16.14	12.19	1.36	70249.95
3	5.15	3.75	60.51	2.72	15.93	12.42	1.36	68212.67
4	9.88	4.00	45.37	3.49	14.80	12.29	1.36	70116.00
5	6.09	3.13	63.25	2.95	15.22	12.38	1.35	70331.05
6	3.50	2.84	54.17	3.10	14.72	12.59	1.37	67711.95
7	3.75	2.68	58.17	2.86	15.26	12.56	1.37	67052.77
8	4.47	2.72	66.63	2.70	15.61	12.45	1.40	68142.33
9	6.62	2.90	52.23	2.47	16.65	12.05	1.40	70225.93
10	5.97	2.76	57.56	2.47	16.40	11.97	1.33	70546.48
11	8.81	3.12	51.02	2.78	15.97	12.12	1.39	69828.73
12	4.98	2.80	55.58	3.15	14.70	12.31	1.41	69763.19
13	3.94	6.46	50.02	3.99	13.21	12.68	1.39	67967.87
14	10.66	13.05	48.79	5.45	11.79	13.04	1.38	65275.60
15	12.15	16.03	54.09	7.15	12.52	12.85	1.41	66962.31
16	9.54	3.58	49.53	4.83	12.47	13.15	1.41	64826.07
17	9.77	1.59	61.56	4.08	13.39	12.67	1.41	68250.04
18	10.43	2.04	46.07	4.07	13.56	12.65	1.40	67759.55
19	9.09	1.95	45.53	3.51	14.78	12.29	1.39	69547.13
20	8.48	2.54	50.37	2.78	15.75	11.98	1.38	71024.04
21	4.73	4.10	51.85	3.11	14.61	12.65	1.36	66710.20
22	3.25	3.26	64.41	3.21	14.59	13.01	1.34	63462.49
23	9.98	3.69	53.22	3.34	14.90	12.58	1.33	67181.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.18	4.15	55.11	3.43	14.78	12.50	1.38	68129.58
最大值	12.15	16.03	66.63	7.15	16.65	13.15	1.41	71024.04
發生時間	15	15	8	15	9	16		20
最小值	3.25	1.59	45.37	2.47	11.79	11.97	1.33	63462.49
發生時間	22	17	4	9	14	10		22
零點偏移(率)	0.00 %	-0.12 %	-0.05 %	-0.02 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.03 %	1.28 %	-0.54 %	0.24 %		0.03	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.17	3.83	52.69	2.20	18.16	10.06	1.51	80180.56
1	8.80	5.12	43.62	2.13	20.00	9.82	1.50	82990.49
2	6.14	1.26	55.17	1.90	18.72	10.21	1.49	81857.20
3	6.37	1.94	47.84	1.62	20.00	9.94	1.49	87700.75
4	6.81	2.35	39.12	1.77	20.35	9.55	1.50	87274.69
5	9.53	4.87	47.33	2.42	18.75	9.77	1.51	85268.01
6	4.46	4.24	50.02	1.53	18.84	10.24	1.55	79079.82
7	6.09	4.74	42.82	1.98	18.61	9.69	1.56	83071.69
8	5.98	14.22	48.12	2.21	19.08	9.60	1.54	80106.68
9	8.53	3.55	45.10	2.23	19.17	9.88	1.50	82295.22
10	5.66	4.16	40.19	1.86	19.26	9.70	1.51	83946.46
11	6.54	5.11	47.97	2.47	16.29	10.40	1.53	81033.42
12	9.93	7.00	51.28	4.02	15.09	10.67	1.49	77953.16
13	11.06	13.76	50.37	3.72	13.68	11.08	1.50	76809.22
14	11.05	9.77	49.81	2.97	15.43	10.55	1.51	78590.98
15	10.32	5.61	48.12	2.56	15.57	10.46	1.50	77564.23
16	8.34	7.73	39.21	2.78	14.86	10.07	1.48	75378.66
17	10.14	8.14	44.41	2.69	16.87	9.78	1.49	80475.08
18	8.57	7.12	39.75	2.87	17.17	9.64	1.50	80217.52
19	10.28	2.80	31.59	3.05	16.71	9.86	1.51	78788.24
20	8.67	2.28	43.63	2.33	17.09	10.62	1.51	78154.36
21	8.32	5.50	39.73	2.03	18.05	9.71	1.52	83096.17
22	10.52	2.54	46.76	2.44	16.75	10.24	1.52	82496.46
23	6.47	2.38	48.29	2.01	16.77	10.30	1.54	77949.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.28	5.42	45.54	2.41	17.55	10.08	1.51	80928.28
最大值	11.06	14.22	55.17	4.02	20.35	11.08	1.57	87700.75
發生時間	13	8	2	12	4	13		3
最小值	4.46	1.26	31.59	1.53	13.68	9.55	1.46	75378.66
發生時間	6	2	19	6	13	4		16
零點偏移(率)	-0.02 %	-0.07 %	-0.02 %	-0.05 %		-0.07	0.00	0.00 %
全幅偏移(率)	0.58 %	0.55 %	-0.82 %	0.21 %		-0.09	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.98	3.48	61.02	2.46	16.33	10.74	1.38	83497.19
1	7.41	3.75	66.05	2.04	18.60	10.51	1.38	84396.11
2	9.88	4.73	63.37	2.29	18.84	10.29	1.38	84582.35
3	6.34	4.27	59.05	1.87	17.50	10.96	1.39	80541.92
4	7.88	5.33	60.51	1.96	18.37	10.42	1.39	86198.36
5	9.65	4.35	56.48	2.10	17.34	10.50	1.38	87578.92
6	9.53	3.31	60.19	2.35	16.57	10.60	1.38	85065.82
7	5.61	4.15	54.51	1.50	17.40	10.65	1.38	88143.40
8	4.37	4.68	58.68	1.64	18.82	9.85	1.38	82751.46
9	4.34	7.57	43.31	2.83	17.00	10.35	1.38	80341.62
10	3.12	5.02	59.37	1.48	17.64	10.25	1.38	82920.85
11	6.89	7.58	53.76	2.05	16.26	10.19	1.38	84057.14
12	10.00	11.90	50.75	3.37	14.42	10.65	1.37	78733.45
13	12.41	8.67	47.62	8.63	12.04	11.46	1.33	64811.08
14	5.89	3.10	54.16	4.94	13.41	11.06	1.36	75794.02
15	16.69	10.54	64.25	3.83	13.41	11.60	1.38	76980.65
16	8.73	7.75	47.83	2.80	14.13	10.50	1.37	80369.94
17	9.34	4.02	54.91	2.07	16.72	10.18	1.36	81171.16
18	4.01	7.78	49.63	2.01	15.60	10.61	1.36	75820.27
19	7.39	7.22	45.30	1.99	17.13	9.77	1.36	83477.95
20	4.19	4.09	57.70	1.66	15.88	10.80	1.36	77834.30
21	2.72	7.39	61.64	2.06	16.46	11.48	1.38	76040.49
22	7.00	5.07	49.27	2.71	15.42	11.25	1.36	74668.03
23	7.09	5.51	66.02	2.36	15.37	11.52	1.36	74266.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.48	5.89	56.06	2.62	16.28	10.67	1.37	80418.46
最大值	16.69	11.90	66.05	8.63	18.84	11.60	1.41	88143.40
發生時間	15	12	1	13	2	15		7
最小值	2.72	3.10	43.31	1.48	12.04	9.77	1.27	64811.08
發生時間	21	14	9	10	13	19		13
零點偏移(率)	-0.13 %	-0.11 %	-0.06 %	-0.07 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.78 %	1.27 %	-0.81 %	0.21 %		-0.02	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								