

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月22日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.88	2.31	61.03	1.24	20.01	10.85	1.05	84661.22
1	8.44	2.43	42.14	1.86	19.18	10.90	1.05	85053.87
2	9.87	2.01	46.41	2.36	19.51	10.82	1.06	85603.21
3	9.48	3.79	50.68	2.55	16.93	11.46	1.06	82711.64
4	8.78	7.01	55.91	1.66	19.24	10.78	1.06	85810.61
5	7.75	3.51	52.21	1.33	18.08	11.05	1.05	85687.47
6	5.69	5.46	43.95	2.24	16.56	11.20	1.05	81385.56
7	8.19	5.93	38.05	3.06	16.53	10.51	1.04	83242.68
8	7.55	1.59	46.86	2.42	16.50	10.79	1.05	80627.16
9	9.44	2.22	54.47	2.30	16.72	10.91	1.06	82327.47
10	6.93	5.14	52.54	1.21	18.39	10.15	1.05	87763.51
11	10.64	4.86	53.23	2.32	17.06	10.54	1.05	87457.60
12	10.75	9.22	30.78	3.15	16.81	10.66	1.06	84304.34
13	10.20	3.32	32.77	1.73	16.33	10.75	1.04	81481.77
14	11.09	3.47	37.05	2.47	15.35	11.23	1.04	78668.41
15	9.08	4.35	34.82	3.01	15.53	11.41	1.04	76229.82
16	8.06	3.31	40.51	2.76	16.51	11.17	1.05	80866.32
17	8.85	3.55	46.20	2.39	16.40	11.48	1.05	80104.64
18	9.11	2.44	57.60	2.19	16.66	11.46	1.05	83278.86
19	9.17	4.20	36.87	2.24	16.71	11.64	1.06	81808.22
20	9.17	3.55	42.09	1.89	17.82	11.31	1.06	83488.63
21	6.68	3.37	44.20	2.47	16.42	11.66	1.06	81987.96
22	6.82	4.21	67.55	1.68	17.37	12.00	1.06	78237.86
23	5.71	4.02	62.02	1.48	17.81	12.04	1.06	77215.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.60	3.97	47.08	2.17	17.27	11.12	1.05	82500.20
最 大 值	11.09	9.22	67.55	3.15	20.01	12.04	1.06	87763.51
發生時間	14	12	22	12	0	23		10
最 小 值	5.69	1.59	30.78	1.21	15.35	10.15	1.03	76229.82
發生時間	6	8	12	10	14	10		15
零點偏移(率)	-0.08 %	0.00 %	-0.01 %	-0.01 %		-0.07		0.00 %
全幅偏移(率)	0.26 %	0.27 %	-0.58 %	0.20 %		0.04		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

