

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.87	1.70	59.30	1.62	20.16	11.63	1.41	72322.20
1	0.71	2.48	69.64	1.84	18.87	12.42	1.45	67429.24
2	0.83	3.51	55.18	2.67	15.56	12.38	1.42	70045.32
3	8.81	13.52	61.06	4.15	13.34	12.77	1.42	69512.47
4	7.76	6.64	69.28	4.55	13.28	12.94	1.41	68018.53
5	11.11	10.66	59.21	4.34	13.61	12.71	1.39	68770.59
6	7.48	3.28	68.34	3.02	15.69	12.32	1.38	71028.51
7	5.91	1.70	61.01	2.74	16.08	12.18	1.38	71998.36
8	9.27	2.96	54.80	3.77	14.06	12.57	1.36	70340.67
9	6.06	4.15	71.02	2.87	15.43	12.21	1.37	71981.99
10	7.70	2.58	60.67	3.67	14.37	12.51	1.40	69933.04
11	9.37	9.84	59.39	4.12	13.68	12.72	1.43	67900.03
12	11.26	1.89	62.98	3.52	15.27	12.27	1.40	70940.69
13	7.72	2.64	56.41	4.00	14.19	12.62	1.38	69102.04
14	9.57	1.15	72.19	3.05	15.70	12.11	1.38	71768.62
15	10.46	2.77	58.38	4.92	13.60	12.59	1.38	68817.06
16	9.04	1.83	56.37	3.42	15.36	12.42	1.42	69411.17
17	7.68	5.27	65.86	3.38	15.06	12.17	1.42	71344.51
18	6.90	3.93	62.13	3.45	14.56	12.45	1.41	70002.21
19	5.41	5.06	69.51	3.50	14.21	12.57	1.41	69565.63
20	5.92	4.26	58.72	3.06	15.02	12.25	1.40	70809.80
21	8.17	12.48	52.56	3.77	13.82	12.71	1.40	68174.10
22	9.73	6.29	68.22	3.41	14.53	12.42	1.43	69088.33
23	10.90	15.25	52.17	4.43	13.20	12.64	1.44	67842.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.61	5.24	61.85	3.47	14.94	12.44	1.40	69839.48
最大值	11.26	15.25	72.19	4.92	20.16	12.94	1.51	72322.20
發生時間	12	23	14	15	0	4		0
最小值	0.71	1.15	52.17	1.62	13.20	11.63	1.35	67429.24
發生時間	1	14	23	0	23	0		1
零點偏移(率)	-0.10 %	-0.01 %	-0.04 %	-0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.52 %	-0.62 %	-0.28 %	0.20 %		0.01	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.77	3.61	53.66	1.08	19.15	10.13	1.41	66055.92
1	4.89	3.03	59.78	0.77	20.28	9.98	1.42	66474.76
2	6.60	0.88	64.71	1.40	19.32	9.99	1.43	68010.71
3	9.66	1.30	61.40	1.83	18.28	10.01	1.43	67887.82
4	9.69	3.99	72.70	1.50	18.29	10.58	1.42	65126.77
5	10.12	1.32	59.03	1.73	17.77	10.37	1.41	67397.67
6	7.45	1.57	68.98	1.38	18.58	10.54	1.37	64272.14
7	4.75	0.85	62.93	1.08	18.91	10.41	1.37	65921.37
8	5.36	1.50	53.79	1.52	17.75	10.42	1.38	66744.85
9	10.42	6.01	61.63	2.08	18.48	10.02	1.38	67035.27
10	9.73	4.99	56.66	2.26	17.39	10.17	1.41	64242.29
11	9.36	4.84	57.51	1.76	18.94	9.91	1.40	62736.37
12	9.48	5.34	51.19	1.87	18.22	9.82	1.35	64121.97
13	8.17	3.62	63.30	1.57	18.41	10.09	1.35	62840.79
14	6.47	12.09	64.79	1.52	18.05	9.89	1.37	61577.72
15	5.35	7.87	48.04	1.79	16.80	10.00	1.35	60837.72
16	3.22	3.32	57.58	1.23	18.09	10.32	1.37	60847.36
17	1.67	1.88	77.22	0.97	18.87	11.04	1.41	58247.54
18	5.76	2.11	53.81	0.72	20.63	9.78	1.42	63802.02
19	10.48	5.02	49.18	1.76	18.99	9.45	1.41	66560.19
20	11.84	11.92	51.15	2.14	17.95	9.94	1.41	62280.48
21	11.08	11.32	53.61	2.09	19.03	9.35	1.43	64161.45
22	9.54	14.30	49.38	1.79	18.73	9.06	1.42	61703.64
23	11.38	11.64	57.18	8.79	18.99	8.64	1.38	69108.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.84	5.18	58.72	1.86	18.58	10.00	1.40	64499.82
最大值	11.84	14.30	77.22	8.79	20.63	11.04	1.49	69108.83
發生時間	20	22	17	23	18	17		23
最小值	1.67	0.85	48.04	0.72	16.80	8.64	1.33	58247.54
發生時間	17	7	15	18	15	23		17
零點偏移(率)	-0.02 %	-0.01 %	-0.03 %	-0.00 %		-0.11	0.00	0.00 %
全幅偏移(率)	0.94 %	-1.38 %	-0.34 %	0.15 %		0.04	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.94	2.75	66.52	1.40	17.87	10.99	1.80	83215.88
1	2.28	1.41	55.14	1.36	19.13	10.54	1.80	86917.90
2	2.59	4.23	52.70	1.36	18.44	10.45	1.80	87616.04
3	10.62	1.57	60.50	2.16	16.79	10.84	1.80	86461.10
4	7.88	1.56	61.05	1.74	17.60	10.73	1.81	85830.31
5	8.89	2.37	62.28	1.84	17.29	10.59	1.80	87620.90
6	8.90	2.58	61.79	2.03	17.16	10.77	1.80	84328.32
7	10.85	6.27	55.27	2.12	16.07	10.68	1.83	88175.48
8	6.56	1.83	62.54	1.84	16.94	10.57	1.85	86202.83
9	6.42	1.77	65.39	1.86	16.24	10.98	1.85	85817.28
10	4.63	4.54	57.67	1.92	15.69	10.82	1.85	84908.62
11	3.01	2.63	66.33	1.94	16.39	10.97	1.87	82850.49
12	1.91	2.69	61.08	1.49	17.99	10.64	1.87	84281.74
13	1.64	3.01	64.13	1.67	16.09	10.97	1.85	82012.20
14	4.40	2.70	62.67	1.75	16.72	10.89	1.86	83037.99
15	2.63	1.92	63.76	1.61	16.41	10.98	1.85	82037.77
16	2.03	5.23	62.77	1.75	15.68	11.08	1.86	83191.37
17	1.10	14.33	59.34	4.43	16.93	10.64	1.85	87641.05
18	1.14	5.45	65.52	1.82	16.08	11.06	1.83	85941.86
19	3.57	5.85	65.44	1.71	16.86	11.20	1.85	83281.97
20	2.05	8.56	60.46	1.57	17.18	10.91	1.86	84713.88
21	3.20	7.24	63.01	1.73	16.53	11.02	1.87	85110.74
22	8.01	5.82	62.97	1.80	16.68	10.96	1.85	85682.52
23	7.06	14.89	57.51	2.21	15.48	11.20	1.87	84422.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.76	4.63	61.49	1.88	16.84	10.85	1.84	85054.20
最大值	10.85	14.89	66.52	4.43	19.13	11.20	1.94	88175.48
發生時間	7	23	0	17	1	19		7
最小值	1.10	1.41	52.70	1.36	15.48	10.45	1.80	82012.20
發生時間	17	1	2	1	23	2		13
零點偏移(率)	-0.02 %	-0.01 %	-0.01 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	2.22 %	-0.09 %	-0.64 %	0.29 %		0.21	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								