

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.48	12.38	52.87	3.45	17.95	11.80	1.34	72521.04
1	8.87	0.89	57.72	3.17	19.87	11.63	1.33	73529.33
2	7.03	1.38	52.72	3.30	18.66	11.70	1.33	73876.97
3	11.48	4.56	49.87	3.55	17.61	11.67	1.33	75217.51
4	7.30	4.67	61.47	3.60	17.77	12.42	1.36	68809.53
5	10.89	1.56	54.28	3.63	18.61	11.67	1.38	73459.97
6	9.41	0.99	55.49	3.24	19.35	11.34	1.39	76191.33
7	7.79	2.78	47.68	3.39	17.87	11.70	1.38	74597.91
8	6.44	1.68	56.83	3.38	18.51	11.83	1.38	73769.58
9	6.07	1.23	53.57	3.26	18.94	11.54	1.39	75242.90
10	5.61	1.98	51.11	3.33	18.12	11.75	1.44	74208.57
11	5.73	1.30	58.54	3.19	18.75	11.58	1.44	75061.32
12	2.39	4.19	57.35	3.49	17.20	12.13	1.43	71598.62
13	6.52	2.70	51.26	3.28	18.10	11.57	1.42	74867.65
14	10.20	10.82	53.05	3.70	17.18	11.77	1.43	74016.12
15	11.22	5.37	52.53	3.44	17.87	11.22	1.42	77781.02
16	8.97	4.05	51.78	3.52	17.14	11.94	1.41	72990.24
17	10.17	2.14	57.22	3.38	18.21	11.73	1.42	73824.67
18	7.39	4.33	53.65	3.38	17.89	11.83	1.44	73548.83
19	8.12	13.99	51.41	3.36	17.78	11.75	1.45	74246.32
20	10.44	7.08	48.69	3.66	17.19	11.80	1.43	73991.10
21	10.73	2.86	51.06	3.72	17.22	11.91	1.42	73730.13
22	10.56	3.85	59.38	3.31	18.49	11.53	1.43	75507.63
23	7.68	2.87	60.52	3.25	19.10	11.63	1.43	73805.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.35	4.15	54.17	3.42	18.14	11.73	1.40	74016.40
最大值	11.48	13.99	61.47	3.72	19.87	12.42	1.52	77781.02
發生時間	3	19	4	21	1	4		15
最小值	2.39	0.89	47.68	3.17	17.14	11.22	1.33	68809.53
發生時間	12	1	7	1	16	15		4
零點偏移(率)	-0.02 %	0.00 %	-0.04 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	3.63 %	-0.04 %	0.10 %	0.09 %		0.23	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.12	4.57	49.17	1.56	18.04	10.23	1.26	62195.15
1	9.13	3.31	55.52	1.53	18.93	10.08	1.26	66512.98
2	10.77	0.93	55.62	2.07	17.18	10.43	1.25	65481.62
3	9.34	1.28	55.34	1.91	17.23	10.65	1.25	64734.66
4	10.55	0.89	58.40	1.75	18.33	10.24	1.25	67388.08
5	10.70	2.45	52.16	2.15	16.72	10.79	1.25	65244.67
6	9.38	3.45	57.17	2.09	16.94	10.67	1.25	63710.81
7	10.28	8.15	56.55	2.29	16.18	10.71	1.25	64876.48
8	9.66	1.53	55.71	2.07	17.20	10.61	1.25	65644.74
9	9.59	2.11	57.27	2.08	17.46	10.59	1.28	65879.95
10	9.17	1.75	56.28	1.75	17.71	10.34	1.31	67642.82
11	8.49	2.53	61.66	2.21	15.49	10.96	1.26	64768.69
12	8.98	5.28	62.88	2.20	15.35	11.06	1.25	64833.29
13	8.80	12.59	55.12	2.30	15.72	10.42	1.28	63329.82
14	10.30	4.29	62.26	3.07	14.86	10.53	1.29	62366.86
15	11.04	7.49	50.52	3.61	14.00	10.61	1.28	60670.79
16	10.41	9.86	52.06	2.79	14.86	10.66	1.25	63006.82
17	9.87	2.36	51.12	2.88	15.13	10.73	1.25	62657.07
18	10.45	3.45	60.35	1.89	18.05	10.14	1.26	65739.46
19	10.01	6.49	59.73	2.42	16.00	10.66	1.29	64310.11
20	9.44	6.80	59.01	2.51	15.98	10.66	1.31	63914.70
21	11.41	0.99	62.15	2.55	16.42	10.62	1.31	65362.80
22	9.55	4.51	67.25	2.12	16.61	10.51	1.31	65248.16
23	10.79	7.06	63.72	2.22	16.50	10.48	1.31	63421.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.84	4.34	57.38	2.25	16.54	10.56	1.27	64539.24
最大值	11.41	12.59	67.25	3.61	18.93	11.06	1.33	67642.82
發生時間	21	13	22	15	1	12		10
最小值	8.12	0.89	49.17	1.53	14.00	10.08	1.23	60670.79
發生時間	0	4	0	1	15	1		15
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.00 %		-0.06	0.00	0.00 %
全幅偏移(率)	1.26 %	-0.00 %	0.29 %	0.06 %		-0.03	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.26	2.74	60.28	2.23	15.68	11.03	1.67	83403.60
1	8.24	1.69	58.28	2.17	16.77	10.85	1.68	84806.03
2	11.85	2.18	58.14	2.40	15.80	10.82	1.68	85048.06
3	9.43	1.51	59.61	2.09	16.35	10.84	1.68	85566.71
4	10.49	6.30	55.27	2.35	16.51	10.43	1.67	87379.20
5	8.30	5.71	49.95	2.19	16.36	10.24	1.67	82228.62
6	9.50	3.20	52.98	2.22	16.01	10.53	1.67	81864.37
7	13.69	2.22	56.41	2.73	14.52	10.98	1.67	89671.80
8	7.47	1.40	59.56	2.15	16.30	10.74	1.68	85122.58
9	9.29	6.21	56.64	2.79	15.26	10.61	1.68	84515.49
10	14.86	9.93	60.66	3.55	14.14	11.20	1.70	82376.49
11	7.60	3.02	61.18	3.11	14.11	11.25	1.71	82683.15
12	6.18	2.59	62.41	2.81	13.99	11.23	1.72	81428.17
13	10.11	8.50	59.59	3.27	13.50	11.14	1.71	79467.35
14	5.86	8.29	57.37	6.14	11.77	11.30	1.68	77290.07
15	7.01	7.09	55.80	3.60	13.08	10.83	1.70	78889.14
16	9.41	9.00	57.07	4.11	12.52	11.24	1.70	79422.75
17	9.56	4.33	56.60	3.72	12.71	11.08	1.70	79194.08
18	6.94	1.86	58.15	3.14	13.59	11.12	1.70	79549.20
19	8.52	3.16	60.96	2.99	14.78	10.78	1.69	81507.74
20	11.22	13.72	51.77	3.32	14.70	10.75	1.67	80083.59
21	11.16	3.06	57.84	3.20	14.95	10.76	1.67	80898.78
22	9.47	1.65	56.81	3.26	14.28	10.96	1.67	79930.14
23	1.30	10.36	57.18	2.11	15.45	10.66	1.67	81458.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.07	4.99	57.52	2.99	14.71	10.89	1.68	82241.08
最大值	14.86	13.72	62.41	6.14	16.77	11.30	1.72	89671.80
發生時間	10	20	12	14	1	14		7
最小值	1.30	1.40	49.95	2.09	11.77	10.24	1.66	77290.07
發生時間	23	8	5	3	14	5		14
零點偏移(率)	-0.04 %	-0.00 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.62 %	-0.00 %	-0.46 %	0.07 %		0.28	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								