

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年10月16日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.02	3.47	47.39	1.72	17.66	11.60	1.02	81242.74
1	9.05	5.28	52.18	1.90	19.18	11.06	1.02	84737.73
2	7.33	3.49	55.08	2.21	16.80	12.18	1.02	77868.64
3	4.75	3.87	70.09	1.49	18.87	11.87	1.04	78098.52
4	8.89	4.09	55.28	1.77	19.22	10.78	1.02	87178.60
5	6.16	5.81	46.66	1.84	18.71	10.89	0.99	85107.86
6	10.13	5.12	52.76	3.03	15.95	11.68	0.99	82956.65
7	11.20	4.73	64.02	2.84	16.00	11.54	0.99	83612.36
8	10.95	4.54	62.61	2.66	16.19	11.79	1.00	81560.06
9	10.09	4.83	58.25	2.12	17.32	11.60	1.02	82183.32
10	7.71	4.50	49.95	1.83	17.35	11.47	1.03	82677.31
11	8.35	4.95	47.69	1.67	17.60	11.59	1.02	80798.16
12	7.74	5.07	56.69	2.14	17.22	11.85	1.02	80005.95
13	9.86	4.89	49.53	2.40	17.09	11.46	1.00	83438.43
14	9.80	5.05	54.20	2.22	17.11	11.92	1.01	79283.29
15	11.42	4.84	46.78	3.45	17.06	11.54	1.02	82739.17
16	10.97	5.10	50.89	2.37	17.71	11.37	1.01	83144.12
17	9.64	4.72	60.46	0.95	18.59	11.07	1.00	85681.99
18	11.02	5.95	50.51	2.47	17.44	11.37	1.01	84070.17
19	14.16	5.35	47.06	4.14	15.77	11.92	1.01	81396.58
20	4.65	5.15	54.56	2.11	19.33	11.58	1.02	80542.01
21	5.38	2.78	47.02	2.09	19.35	12.04	1.02	76282.36
22	6.72	4.04	48.41	1.98	19.54	11.66	1.02	79279.35
23	6.26	4.63	56.22	1.68	18.80	11.66	1.02	80074.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.80	4.68	53.51	2.21	17.74	11.56	1.01	81831.65
最 大 值	14.16	5.95	70.09	4.14	19.54	12.18	1.08	87178.60
發生時間	19	18	3	19	22	2		4
最 小 值	4.65	2.78	46.66	0.95	15.77	10.78	0.98	76282.36
發生時間	20	21	5	17	19	4		21
零點偏移(率)	-0.07 %	-0.01 %	-0.17 %	-0.05 %		-0.03		0.00 %
全幅偏移(率)	0.83 %	0.10 %	-0.42 %	0.27 %		0.36		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年10月16日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	11.51	3.89	58.26	3.89	15.23	11.42	1.69	77808.76
1	8.08	3.58	58.74	3.92	15.64	11.49	1.70	76158.29
2	9.47	3.56	63.28	3.73	16.45	11.12	1.69	79099.64
3	9.83	2.97	45.45	3.70	16.36	10.72	1.69	78373.77
4	9.77	2.30	49.54	3.74	15.86	10.90	1.69	77648.15
5	12.13	2.48	54.17	4.16	14.88	11.20	1.70	79183.51
6	11.97	4.84	56.55	4.38	14.63	11.28	1.70	78823.49
7	12.64	4.40	57.87	4.10	14.34	11.25	1.72	73841.40
8	11.38	8.18	56.48	4.22	14.96	11.05	1.75	74175.86
9	12.29	3.25	57.90	4.09	15.64	10.93	1.77	75840.42
10	12.11	3.04	58.99	1.87	16.43	11.59	1.71	74952.29
11	8.92	3.50	57.70	2.19	15.69	11.21	1.71	74700.86
12	8.19	3.20	57.81	3.27	15.54	10.90	1.72	74682.76
13	9.78	3.21	57.40	3.27	15.60	10.92	1.70	73918.68
14	10.87	4.04	52.23	3.58	15.64	10.80	1.70	74254.56
15	10.72	4.03	50.10	3.45	16.44	10.43	1.75	75481.05
16	11.50	3.13	54.65	3.04	17.35	10.08	1.71	80001.69
17	11.95	1.51	57.04	2.01	17.49	10.46	1.69	83853.34
18	13.11	2.12	54.26	3.30	16.87	10.53	1.70	81251.99
19	10.88	2.10	61.60	3.36	15.79	11.08	1.72	80076.91
20	4.20	2.97	53.08	2.30	15.88	10.52	1.74	80089.83
21	5.29	3.77	60.45	1.59	17.56	10.55	1.73	80151.27
22	5.66	4.39	49.90	2.29	17.58	10.59	1.73	81748.36
23	3.60	3.98	54.11	2.99	16.22	11.11	1.73	75928.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.83	3.52	55.73	3.27	16.00	10.92	1.71	77585.23
最 大 值	13.11	8.18	63.28	4.38	17.58	11.59	1.78	83853.34
發生時間	18	8	2	6	22	10		17
最 小 值	3.60	1.51	45.45	1.59	14.34	10.08	1.69	73841.40
發生時間	23	17	3	21	7	16		7
零點偏移(率)	-0.10 %	-0.02 %	-0.01 %	0.00 %		-0.02		-0.10 %
全幅偏移(率)	0.02 %	0.10 %	-0.63 %	0.02 %		0.06		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								