

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.17	5.31	54.67	2.33	18.33	11.55	1.46	76022.27
1	11.79	3.83	62.02	2.28	19.40	11.48	1.46	75446.04
2	9.26	3.64	54.26	2.31	18.48	11.61	1.46	75704.05
3	10.72	3.79	64.57	2.33	18.21	11.66	1.46	75474.73
4	9.58	3.35	60.61	2.17	18.46	11.68	1.46	75019.01
5	1.31	2.14	65.40	1.94	20.38	11.12	1.48	78596.93
6	6.89	2.20	61.51	1.36	20.99	10.63	1.47	80466.84
7	10.34	4.87	47.63	1.86	19.82	11.09	1.46	78779.81
8	8.29	4.47	60.78	1.54	20.58	10.78	1.46	80289.80
9	9.76	0.44	61.11	1.97	19.68	11.39	1.45	75550.44
10	10.11	2.02	55.30	1.59	20.17	10.74	1.44	80785.99
11	9.58	4.13	56.93	2.04	18.86	11.55	1.42	75129.09
12	10.46	8.32	56.38	1.68	20.26	10.84	1.42	80102.54
13	9.97	2.88	57.10	1.95	19.32	11.31	1.41	76592.54
14	9.34	3.05	61.96	1.82	20.04	11.11	1.41	77310.99
15	9.58	8.78	51.55	2.20	17.64	11.49	1.40	76871.30
16	11.00	5.55	62.70	2.20	17.77	11.57	1.41	76490.92
17	10.51	0.86	54.33	2.06	18.73	11.26	1.40	77451.94
18	9.93	0.99	67.55	2.26	18.11	12.23	1.40	70600.50
19	12.32	1.82	41.17	2.18	18.37	11.25	1.40	78399.60
20	11.93	4.48	39.55	2.28	17.71	11.42	1.39	77496.77
21	8.21	2.23	49.84	2.07	18.21	11.65	1.40	75297.57
22	10.82	1.04	41.02	1.97	18.85	11.04	1.40	79033.41
23	12.06	0.79	48.47	2.30	19.55	11.29	1.40	76947.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.87	3.37	55.68	2.03	19.08	11.32	1.43	77077.51
最大值	13.17	8.78	67.55	2.33	20.99	12.23	1.53	80785.99
發生時間	0	15	18	0	6	18		10
最小值	1.31	0.44	39.55	1.36	17.64	10.63	1.38	70600.50
發生時間	5	9	20	6	15	6		18
零點偏移(率)	0.00 %	0.00 %	-0.02 %	0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	0.05 %	0.03 %	-0.26 %	0.51 %		0.33	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.06	6.68	62.03	2.13	16.11	11.04	1.33	60918.38
1	10.91	9.87	56.67	2.88	14.62	10.79	1.33	59624.60
2	8.42	1.36	52.61	2.28	15.95	10.45	1.33	60798.50
3	10.14	2.43	61.83	2.23	16.69	10.30	1.33	62751.17
4	10.94	6.83	63.81	2.26	17.30	10.12	1.33	64447.49
5	10.53	4.07	60.52	2.57	16.48	10.45	1.32	62078.37
6	9.30	5.01	51.42	2.38	16.23	10.13	1.31	63000.69
7	9.32	3.41	55.88	2.05	16.82	10.11	1.31	64041.65
8	10.02	5.34	55.29	2.28	16.97	10.11	1.29	65444.17
9	校正	校正	校正	校正	替代	校正	1.32	67056.55
10	9.22	3.24	66.24	1.90	17.60	10.57	1.31	65982.16
11	10.66	7.50	53.53	2.26	16.38	10.74	1.30	65167.31
12	8.46	4.39	69.07	2.04	16.38	10.75	1.30	63622.77
13	10.15	5.31	59.79	2.17	16.51	10.88	1.32	64448.62
14	10.45	12.89	59.93	2.50	14.84	11.13	1.31	63272.51
15	11.86	2.00	65.84	2.70	14.47	11.11	1.30	62537.87
16	8.25	3.34	57.99	2.30	15.62	10.87	1.31	63730.19
17	7.99	1.64	67.87	2.27	15.16	11.21	1.31	62574.69
18	8.84	2.97	64.08	2.22	15.69	11.23	1.32	63178.46
19	8.15	2.38	62.72	2.00	16.28	10.91	1.33	65159.14
20	12.09	11.87	62.80	3.63	13.68	11.27	1.33	63375.31
21	9.91	0.48	53.12	2.58	15.49	11.13	1.33	62550.52
22	10.12	0.71	57.03	2.14	16.40	10.60	1.33	65546.55
23	7.84	0.70	69.07	2.10	16.59	11.01	1.33	63770.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	24
平均值	9.68	4.54	60.40	2.34	16.01	10.74	1.32	63544.92
最大值	12.09	12.89	69.07	3.63	17.60	11.27	1.35	67056.55
發生時間	20	14	12	20	10	20		9
最小值	7.84	0.48	51.42	1.90	13.68	10.11	1.28	59624.60
發生時間	23	21	6	10	20	7		1
零點偏移(率)	0.00 %	-0.05 %	-0.01 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	-1.94 %	-1.82 %	0.13 %	0.41 %		0.24	-0.03	0.20 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.17	4.46	64.83	2.72	14.73	10.99	1.80	82064.05
1	9.35	4.85	60.74	2.66	14.30	11.08	1.79	80803.79
2	7.41	7.10	62.15	2.64	14.45	10.78	1.79	78586.11
3	8.50	2.55	61.57	2.49	15.14	10.87	1.80	84551.75
4	10.55	4.26	62.46	2.64	15.16	10.80	1.80	83543.25
5	9.85	7.72	58.67	2.87	14.26	10.75	1.80	80272.67
6	7.57	4.85	60.08	2.24	15.46	10.37	1.80	82394.05
7	10.79	5.40	59.12	2.01	17.29	10.04	1.82	86607.76
8	10.12	6.42	57.82	2.45	15.38	10.51	1.81	85267.75
9	6.99	1.48	63.44	1.92	17.64	10.20	1.83	86829.76
10	9.07	2.37	59.76	2.11	15.58	10.79	1.82	84895.52
11	9.08	1.66	59.46	2.14	16.72	10.36	1.80	85278.34
12	9.46	7.96	61.62	2.34	16.01	10.47	1.80	84466.17
13	9.18	0.55	58.07	2.41	14.75	10.93	1.82	83438.86
14	11.29	1.28	66.62	2.43	15.14	10.76	1.82	83616.32
15	10.01	3.58	63.67	3.21	14.22	10.95	1.81	83293.46
16	10.08	2.43	61.54	2.52	14.96	10.75	1.82	83812.21
17	6.99	2.57	71.19	2.53	14.95	11.73	1.82	77686.17
18	8.11	2.51	55.44	2.07	15.79	10.19	1.81	85185.40
19	10.27	2.03	66.86	2.58	14.47	11.00	1.82	82931.77
20	10.57	8.57	50.66	2.39	15.14	10.92	1.83	86066.45
21	10.50	1.56	55.98	2.32	15.38	11.01	1.85	85345.07
22	9.98	1.00	51.26	2.14	16.10	10.61	1.85	88268.76
23	11.03	1.51	51.04	2.15	15.51	10.95	1.85	86787.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.46	3.69	60.17	2.42	15.36	10.74	1.81	83833.05
最大值	11.29	8.57	71.19	3.21	17.64	11.73	1.86	88268.76
發生時間	14	20	17	15	9	17		22
最小值	6.99	0.55	50.66	1.92	14.22	10.04	1.77	77686.17
發生時間	9	13	20	9	15	7		17
零點偏移(率)	-0.02 %	0.00 %	-0.17 %	-0.03 %		0.00	0.00	0.00 %
全幅偏移(率)	2.08 %	0.26 %	-0.11 %	0.20 %		0.40	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								