

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.11	3.55	50.71	3.10	17.40	11.76	1.31	73587.12
1	8.08	3.39	54.13	2.66	19.19	11.38	1.33	75604.05
2	9.65	3.37	55.69	3.17	17.42	11.62	1.33	74356.93
3	9.85	3.49	48.54	3.33	17.30	11.63	1.33	75258.41
4	9.03	5.87	55.04	3.29	16.67	11.88	1.33	73672.69
5	9.98	3.91	57.90	3.28	17.05	11.83	1.33	70784.91
6	9.04	3.40	59.04	3.15	17.07	12.01	1.33	71619.47
7	9.88	3.50	50.18	3.33	17.23	11.76	1.33	73642.22
8	9.92	3.29	58.39	3.21	16.89	11.92	1.33	72652.61
9	8.80	3.52	59.77	2.97	17.60	11.93	1.31	72089.88
10	6.76	4.40	51.25	3.28	16.23	12.04	1.31	71731.24
11	4.97	3.50	56.85	3.10	16.54	12.07	1.30	71716.02
12	5.46	3.54	61.85	3.20	16.16	12.20	1.32	70361.16
13	3.52	6.44	53.76	3.17	17.98	12.12	1.33	67484.68
14	9.14	2.30	50.37	3.62	15.88	12.09	1.33	71830.88
15	7.67	2.97	48.34	3.87	14.95	12.39	1.35	69928.57
16	4.65	2.81	58.25	3.35	16.34	12.61	1.37	67547.83
17	0.11	2.35	60.68	2.80	16.78	12.50	1.37	68433.44
18	2.48	1.77	46.42	2.82	17.10	11.80	1.33	73162.10
19	3.54	1.56	61.50	2.53	17.76	11.66	1.33	73574.04
20	5.31	1.86	41.05	3.08	16.59	12.22	1.32	70328.72
21	5.61	1.77	58.50	2.74	17.75	11.86	1.31	72104.22
22	5.38	1.87	69.70	3.03	16.48	12.62	1.33	67414.13
23	6.59	1.64	55.92	2.60	18.53	11.49	1.32	74212.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.86	3.17	55.16	3.11	17.04	11.97	1.33	71795.74
最大值	9.98	6.44	69.70	3.87	19.19	12.62	1.44	75604.05
發生時間	5	13	22	15	1	22		1
最小值	0.11	1.56	41.05	2.53	14.95	11.38	1.29	67414.13
發生時間	17	19	20	19	15	1		22
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.77 %	-0.07 %	-0.20 %	0.17 %		0.00	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.20	3.73	59.38	1.87	19.15	10.33	1.37	82732.00
1	8.80	6.51	48.12	2.27	19.85	9.93	1.36	86951.81
2	9.24	4.86	48.48	2.85	18.69	9.88	1.36	87502.73
3	8.53	4.93	58.64	2.71	18.32	10.20	1.36	84139.97
4	11.15	3.99	56.93	3.39	19.73	9.91	1.36	86304.30
5	10.59	5.59	52.58	2.96	19.17	10.09	1.36	86656.67
6	10.16	4.95	55.64	2.37	18.69	10.16	1.38	81749.74
7	8.85	3.54	56.96	2.13	19.30	10.00	1.38	86496.65
8	10.33	3.56	56.20	2.42	18.42	10.36	1.38	85359.97
9	9.66	3.68	49.14	3.30	17.36	10.39	1.38	81849.97
10	8.24	3.20	52.21	2.59	16.95	10.33	1.38	81166.43
11	11.29	3.13	68.89	2.53	17.83	10.33	1.39	85615.37
12	9.15	4.88	48.21	2.69	16.24	10.46	1.40	80903.68
13	11.82	5.42	46.73	2.99	16.46	10.20	1.41	78245.67
14	10.23	7.93	55.77	2.71	18.97	9.48	1.43	87937.60
15	7.37	8.80	58.19	2.93	15.67	10.80	1.44	76831.31
16	9.63	5.91	38.90	2.86	16.87	10.34	1.43	79870.82
17	10.58	4.66	56.22	2.85	17.48	10.44	1.43	79301.92
18	8.57	3.90	63.79	2.05	18.22	10.90	1.41	76807.79
19	6.85	6.43	40.84	1.67	18.78	10.34	1.41	83940.06
20	5.32	6.30	52.63	1.69	18.68	10.07	1.41	85322.42
21	9.95	3.57	50.00	2.28	17.89	9.99	1.42	82239.24
22	10.36	3.45	55.46	2.27	18.28	9.96	1.41	82255.96
23	6.25	3.91	48.23	1.61	19.12	9.78	1.41	83372.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.21	4.87	53.26	2.50	18.17	10.19	1.39	83064.79
最大值	11.82	8.80	68.89	3.39	19.85	10.90	1.45	87937.60
發生時間	13	15	11	4	1	18		14
最小值	5.32	3.13	38.90	1.61	15.67	9.48	1.35	76807.79
發生時間	20	11	16	23	15	14		18
零點偏移(率)	-0.19 %	-0.01 %	-0.02 %	-0.04 %		-0.08	0.00	0.00 %
全幅偏移(率)	3.31 %	0.06 %	-0.50 %	0.06 %		-0.10	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.65	2.05	67.32	2.59	17.55	10.71	1.47	84666.01
1	5.24	4.65	54.66	2.39	17.99	10.40	1.46	86561.94
2	8.18	2.81	56.10	2.83	16.47	10.48	1.46	83561.70
3	9.04	3.05	54.32	2.83	17.44	10.24	1.46	84550.81
4	9.15	5.03	51.61	2.54	17.27	10.28	1.46	85548.31
5	11.37	9.22	45.79	3.85	18.26	9.67	1.45	84568.46
6	8.92	2.07	56.04	2.83	18.80	9.80	1.44	87620.09
7	3.50	4.57	58.61	2.49	18.07	10.11	1.46	91003.56
8	9.89	4.79	51.28	3.10	16.85	10.48	1.47	79713.66
9	9.94	6.09	52.44	3.06	17.94	10.08	1.47	82483.37
10	10.30	5.60	55.36	3.12	18.54	9.78	1.49	85259.66
11	10.27	10.73	42.75	3.20	16.82	9.94	1.49	82899.65
12	9.71	2.57	52.04	3.40	14.47	10.68	1.47	77299.32
13	8.32	3.81	59.13	3.90	14.35	11.03	1.48	76266.53
14	12.91	8.78	52.52	4.05	14.01	10.77	1.46	78216.60
15	7.54	4.46	55.65	3.46	13.98	11.16	1.45	74421.68
16	6.83	2.67	55.82	3.14	14.94	10.90	1.46	80298.42
17	6.75	1.71	56.79	2.74	16.08	10.67	1.48	81916.12
18	4.47	1.93	67.02	2.72	16.22	11.58	1.49	75024.33
19	0.55	1.67	47.57	2.16	16.73	10.91	1.49	82897.30
20	2.68	1.93	59.64	2.38	16.66	10.70	1.49	86428.62
21	4.24	2.59	56.82	2.59	15.87	10.87	1.49	83641.85
22	9.72	1.81	58.42	2.73	16.80	10.70	1.49	84374.26
23	5.89	1.43	57.68	2.44	17.39	10.68	1.49	83978.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.71	4.00	55.22	2.94	16.65	10.53	1.47	82633.38
最大值	12.91	10.73	67.32	4.05	18.80	11.58	1.50	91003.56
發生時間	14	11	0	14	6	18		7
最小值	0.55	1.43	42.75	2.16	13.98	9.67	1.43	74421.68
發生時間	19	23	11	19	15	5		15
零點偏移(率)	-0.01 %	-0.02 %	-0.01 %	-0.01 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.14 %	0.31 %	-0.83 %	0.20 %		-0.01	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								