

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.73	11.91	47.24	2.80	17.05	11.51	1.27	79401.37
1	9.24	12.53	53.41	5.12	19.10	10.79	1.26	74091.58
2	8.95	6.54	41.60	1.29	18.32	9.73	1.25	86232.03
3	9.25	12.53	59.02	0.28	15.95	11.40	1.25	82167.74
4	9.66	13.43	42.25	0.23	15.85	12.04	1.25	76840.72
5	5.10	12.84	35.67	4.37	16.31	11.50	1.23	81718.79
6	3.56	12.42	34.18	4.19	17.47	10.93	1.24	85265.74
7	10.22	12.53	48.90	4.61	17.20	11.24	1.22	82772.49
8	9.44	12.45	51.01	3.44	17.26	11.16	1.25	83197.41
9	11.80	13.07	51.94	4.58	15.92	11.74	1.25	80828.17
10	5.23	13.53	49.43	4.09	16.91	11.73	1.23	82169.43
11	6.22	13.29	46.89	5.50	15.19	11.94	1.22	80917.22
12	9.78	14.12	56.31	1.95	15.22	12.54	1.18	75000.43
13	10.07	12.90	55.03	1.60	15.85	11.66	1.22	81639.57
14	9.10	13.07	49.15	1.62	15.43	11.81	1.25	80130.90
15	8.94	13.19	58.06	1.29	15.99	11.87	1.24	80280.41
16	10.90	12.66	54.99	1.19	17.07	11.28	1.22	82982.48
17	7.10	12.68	47.73	1.15	16.59	11.36	1.25	82041.72
18	9.16	12.44	47.32	1.21	17.01	11.15	1.25	83359.88
19	8.98	13.05	58.48	0.93	18.14	11.40	1.25	80269.50
20	9.43	12.62	36.01	1.31	17.24	11.06	1.25	83874.57
21	9.52	12.54	42.04	1.26	17.66	11.00	1.25	83682.21
22	9.68	12.68	55.75	1.18	17.52	11.22	1.25	82314.88
23	8.71	13.15	59.88	1.35	16.60	11.70	1.25	78651.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.70	12.59	49.26	2.36	16.79	11.41	1.24	81242.97
最大值	11.80	14.12	59.88	5.50	19.10	12.54	1.28	86232.03
發生時間	9	12	23	11	1	12		2
最小值	3.56	6.54	34.18	0.23	15.19	9.73	1.18	74091.58
發生時間	6	2	6	4	11	2		1
零點偏移(率)	-0.03 %	-0.01 %	-0.01 %	-0.00 %		-0.05	-0.01	0.30 %
全幅偏移(率)	-0.90 %	-0.83 %	-0.15 %	-0.21 %		0.41	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.27	14.25	59.21	0.93	17.90	11.20	0.81	69135.37
1	8.66	26.90	66.80	1.97	16.61	12.85	0.81	57189.92
2	10.29	12.60	69.18	0.76	17.53	11.79	0.79	66695.87
3	9.50	9.52	61.59	0.96	17.42	11.36	0.79	71349.12
4	8.08	8.56	50.81	0.98	17.05	11.80	0.80	68284.86
5	9.68	10.10	53.34	0.73	17.82	11.55	0.80	66933.70
6	13.26	14.68	42.36	1.36	17.41	11.46	0.81	68247.64
7	7.89	13.03	57.30	1.28	16.50	12.05	0.81	64672.76
8	10.29	9.14	49.69	0.68	18.19	11.21	0.83	69461.81
9	8.52	8.39	48.70	1.05	16.73	11.58	0.82	71118.61
10	8.39	9.47	58.46	0.75	16.82	12.28	0.83	64219.64
11	校正	校正	校正	校正	替代	校正	0.95	78351.78
12	8.91	11.90	46.19	1.12	17.30	10.70	1.02	79013.70
13	11.54	11.63	44.50	0.70	19.72	9.88	0.99	80039.86
14	12.53	11.65	48.07	1.29	17.74	10.38	0.99	80841.91
15	9.30	11.78	41.40	1.02	17.31	10.47	0.99	76581.91
16	13.10	11.34	46.36	1.05	18.58	9.89	1.02	81931.87
17	11.34	12.08	42.35	1.44	17.05	10.42	1.01	78703.19
18	11.13	12.26	38.77	1.48	17.85	9.84	0.99	80480.18
19	9.27	11.28	34.60	1.01	18.02	9.57	0.97	78076.18
20	14.80	11.67	56.87	1.74	18.10	9.87	1.03	79981.96
21	11.62	11.51	58.59	0.93	19.60	9.43	0.99	83117.28
22	10.17	13.13	37.56	1.58	18.22	10.39	0.99	74107.92
23	11.60	12.18	57.59	0.96	18.21	10.36	0.96	81211.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	24
平均值	10.44	12.13	50.88	1.12	17.73	10.88	0.91	73739.53
最大值	14.80	26.90	69.18	1.97	19.72	12.85	1.15	83117.28
發生時間	20	1	2	1	13	1		21
最小值	7.89	8.39	34.60	0.68	16.50	9.43	0.79	57189.92
發生時間	7	9	19	8	7	21		1
零點偏移(率)	-0.11 %	-0.00 %	-0.10 %	-0.01 %		-0.10	-0.06	-0.10 %
全幅偏移(率)	-1.54 %	1.01 %	0.07 %	0.16 %		-0.24	0.31	-0.10 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.37	10.93	42.28	2.80	16.99	9.32	1.36	76056.99
1	7.56	11.40	49.54	2.79	19.29	9.29	1.36	76083.25
2	9.40	11.04	43.82	2.76	18.12	9.19	1.36	74731.51
3	7.45	11.25	40.94	2.70	17.43	9.45	1.37	72614.37
4	6.56	11.66	52.91	2.78	17.30	10.22	1.36	67671.15
5	7.85	11.25	54.94	2.94	17.26	10.01	1.36	72772.94
6	8.03	11.28	53.81	2.99	17.11	10.02	1.36	77485.15
7	7.58	11.43	55.94	2.83	16.52	10.45	1.38	76309.59
8	9.93	11.32	56.32	3.02	17.33	10.13	1.38	77264.54
9	5.67	12.17	60.88	3.14	16.01	11.01	1.36	71156.45
10	6.23	12.35	62.59	3.01	16.07	11.23	1.36	69976.82
11	8.23	11.57	58.26	2.98	16.11	10.56	1.37	74788.00
12	7.41	11.49	66.22	2.83	18.42	10.17	1.36	75680.69
13	6.00	11.17	44.68	2.69	17.19	10.06	1.36	77339.53
14	4.81	11.54	63.61	2.59	17.74	10.33	1.37	71867.34
15	6.63	11.24	52.08	2.95	17.26	9.66	1.36	76092.21
16	7.56	11.38	63.60	2.97	17.28	10.17	1.33	75777.89
17	7.65	11.32	56.10	2.80	16.40	10.25	1.36	75948.34
18	7.23	11.14	59.26	2.74	17.34	9.97	1.36	77772.32
19	8.12	11.45	63.26	2.86	19.31	9.73	1.35	77034.09
20	5.51	11.99	42.38	4.54	19.09	8.73	1.34	78459.75
21	8.66	10.82	42.26	2.66	18.37	9.07	1.34	75151.88
22	7.66	11.21	45.04	2.82	18.57	9.21	1.34	73138.43
23	7.24	11.12	56.36	2.76	18.40	9.73	1.35	75454.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.43	11.40	53.63	2.91	17.54	9.91	1.36	74859.49
最大值	9.93	12.35	66.22	4.54	19.31	11.23	1.41	78459.75
發生時間	8	10	12	20	19	10		20
最小值	4.81	10.82	40.94	2.59	16.01	8.73	1.31	67671.15
發生時間	14	21	3	14	9	20		4
零點偏移(率)	-0.12 %	0.00 %	-0.24 %	-0.00 %		-0.09	-0.01	0.00 %
全幅偏移(率)	-0.74 %	-0.37 %	-0.01 %	0.30 %		0.20	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								