

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.09	8.58	53.79	1.28	15.73	11.71	1.10	81777.62
1	9.80	13.83	47.77	1.70	16.42	11.83	1.09	79913.96
2	8.75	7.87	55.65	2.01	15.55	11.93	1.07	80031.23
3	9.87	13.20	51.18	1.96	14.87	11.69	1.10	82546.49
4	4.96	14.23	68.65	0.99	16.36	12.00	1.11	78882.55
5	9.30	13.22	61.83	0.82	18.31	10.53	1.12	87595.72
6	9.64	15.04	49.14	1.57	16.25	11.25	1.13	85336.09
7	10.11	10.18	47.63	2.75	14.58	11.95	1.12	80716.89
8	7.34	6.79	57.99	1.87	16.14	11.70	1.12	81201.13
9	9.43	0.99	47.79	2.08	14.94	11.75	1.13	81644.24
10	9.68	1.02	36.65	1.88	16.35	11.55	1.13	82291.79
11	9.88	8.50	36.52	2.77	14.43	11.91	1.09	79853.87
12	11.19	6.87	46.23	1.91	15.12	12.08	1.08	78266.47
13	9.23	5.91	59.51	1.25	15.85	11.72	1.09	81342.38
14	7.85	6.17	51.42	1.25	15.67	11.71	1.09	79801.75
15	9.27	6.03	49.97	1.37	16.27	11.47	1.11	82883.08
16	8.53	6.01	51.54	1.54	15.52	11.83	1.11	80663.11
17	5.64	6.83	50.19	1.76	15.85	11.84	1.11	80147.70
18	9.62	8.91	52.92	1.80	16.24	11.51	1.10	82673.08
19	8.21	5.88	52.32	1.37	16.16	11.56	1.08	82349.38
20	7.95	11.50	62.47	0.85	17.00	11.53	1.06	81953.91
21	10.08	13.59	50.10	1.85	15.81	11.53	1.06	82850.29
22	9.46	13.47	53.38	1.62	15.55	11.86	1.06	80397.46
23	9.25	12.67	60.63	1.26	16.27	11.51	1.06	83129.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.92	9.05	52.30	1.65	15.89	11.66	1.10	81593.74
最大值	11.19	15.04	68.65	2.77	18.31	12.08	1.13	87595.72
發生時間	12	6	4	11	5	12		5
最小值	4.96	0.99	36.52	0.82	14.43	10.53	1.06	78266.47
發生時間	4	9	11	5	11	5		12
零點偏移(率)	-0.06 %	0.01 %	-0.02 %	0.00 %		-0.02		0.00 %
全幅偏移(率)	2.05 %	-0.74 %	-0.29 %	0.03 %		0.04		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.97	4.56	53.71	1.85	16.03	10.67	1.05	83932.65
1	9.26	5.79	45.34	2.66	15.44	10.98	1.03	81341.30
2	9.46	3.77	40.95	3.27	14.27	10.85	1.02	81257.13
3	8.11	3.87	44.63	2.32	16.10	10.71	1.04	82981.26
4	8.79	7.25	48.11	1.63	17.39	10.62	1.06	84928.32
5	9.20	7.49	50.80	1.75	16.93	10.40	1.06	86572.59
6	5.01	14.13	42.90	2.77	14.43	11.54	1.08	77940.91
7	7.33	5.33	46.73	2.18	16.20	10.85	1.06	83582.34
8	6.96	4.50	48.64	1.78	15.89	10.73	1.08	81935.48
9	3.46	5.80	54.68	2.60	14.11	12.11	1.08	72761.89
10	3.73	3.11	39.58	1.38	16.54	11.01	1.06	81423.78
11	5.04	7.04	43.12	2.10	14.45	12.43	1.04	71620.28
12	3.98	1.27	40.25	1.92	15.12	11.74	1.06	76398.30
13	4.66	2.33	35.96	2.33	15.87	10.66	1.08	83845.52
14	2.83	8.05	50.38	2.53	13.86	11.17	1.06	78309.22
15	4.26	1.41	49.46	1.85	15.83	10.74	1.06	82856.83
16	8.13	3.25	46.83	2.30	15.99	10.70	1.08	83737.29
17	6.50	1.46	44.97	2.01	15.68	10.80	1.09	83568.75
18	5.29	3.04	42.93	1.82	16.18	10.61	1.09	83794.20
19	4.53	3.55	41.66	1.66	16.61	10.75	1.06	81848.86
20	9.08	5.91	47.49	2.88	15.11	10.94	1.06	82655.66
21	6.36	4.68	48.56	2.40	15.40	10.89	1.05	82518.09
22	8.55	7.92	48.76	2.06	16.32	10.61	1.04	83725.02
23	7.63	7.72	46.28	1.55	17.91	10.39	1.06	84219.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.59	5.13	45.95	2.15	15.74	10.95	1.06	81573.15
最大值	9.97	14.13	54.68	3.27	17.91	12.43	1.10	86572.59
發生時間	0	6	9	2	23	11		5
最小值	2.83	1.27	35.96	1.38	13.86	10.39	1.02	71620.28
發生時間	14	12	13	10	14	23		11
零點偏移(率)	-0.09 %	-0.01 %	-0.03 %	0.00 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	0.39 %	0.18 %	0.02 %		-0.17		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.69	6.84	39.87	1.19	17.59	9.39	0.93	78864.32
1	8.16	6.96	36.86	1.40	17.18	9.79	0.93	77069.91
2	9.91	5.08	36.57	3.96	16.16	9.60	0.92	77545.41
3	9.80	5.01	36.60	1.96	15.85	9.65	0.92	76440.14
4	8.01	5.41	39.24	1.48	16.99	9.79	0.93	76033.88
5	9.70	7.25	36.19	1.88	16.88	9.43	0.93	79457.33
6	8.56	6.07	38.88	1.83	15.33	10.15	0.92	73119.62
7	8.14	3.18	37.38	1.92	16.69	9.35	0.96	72075.86
8	9.74	4.66	50.31	2.34	16.33	9.65	0.96	74294.31
9	10.98	3.81	50.71	3.43	18.09	9.08	0.95	76816.55
10	5.02	3.28	39.29	3.30	16.23	9.53	0.93	72478.41
11	2.38	4.04	36.51	0.73	17.61	9.08	0.94	75446.67
12	7.90	5.25	34.36	2.55	16.98	8.82	0.94	77289.63
13	9.11	5.72	34.54	1.98	15.97	9.46	0.93	73014.91
14	9.17	4.88	42.88	1.99	14.84	10.02	0.93	73592.71
15	14.92	3.03	41.58	1.82	15.70	10.69	0.96	73003.83
16	14.16	4.24	42.21	2.44	15.41	10.26	0.96	74087.63
17	12.60	5.03	42.83	5.41	14.61	10.15	0.97	77089.90
18	3.20	6.19	47.93	1.15	15.47	10.32	0.96	74997.76
19	2.47	10.42	49.08	1.04	15.38	10.30	0.95	74476.79
20	1.90	7.35	46.83	1.12	16.03	9.93	0.98	78333.50
21	3.22	5.03	52.41	1.97	13.61	11.01	0.98	73372.81
22	3.34	6.17	45.36	1.21	15.43	10.02	0.96	76386.73
23	5.05	3.17	48.65	1.52	14.99	10.25	0.98	77167.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.76	5.34	41.96	2.07	16.06	9.82	0.95	75519.01
最大值	14.92	10.42	52.41	5.41	18.09	11.01	1.00	79457.33
發生時間	15	19	21	17	9	21		5
最小值	1.90	3.03	34.36	0.73	13.61	8.82	0.90	72075.86
發生時間	20	15	12	11	21	12		7
零點偏移(率)	-0.11 %	-0.05 %	-0.01 %	0.00 %		0.02		0.10 %
全幅偏移(率)	-0.23 %	0.55 %	-0.50 %	0.17 %		-0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								