

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.09	5.54	41.30	1.78	18.41	10.98	1.02	75987.90
1	8.71	6.16	58.30	0.98	20.45	10.73	1.02	76588.17
2	10.16	6.11	47.26	1.95	17.14	11.21	1.01	76139.94
3	8.97	7.65	52.25	1.71	16.44	11.61	1.02	73590.44
4	8.86	9.39	57.31	1.78	15.48	11.90	1.05	71835.53
5	9.41	9.09	58.23	1.68	15.51	11.91	1.05	71790.27
6	8.14	9.09	61.56	1.22	16.46	12.05	1.06	70627.61
7	9.11	8.59	62.35	1.02	17.34	11.62	1.06	73199.55
8	7.80	8.80	54.59	1.06	16.97	11.58	1.05	74194.03
9	5.55	8.66	60.20	0.87	16.91	11.74	1.05	73122.14
10	10.50	9.31	49.54	2.20	15.72	11.65	1.00	75134.70
11	6.61	8.99	61.25	1.59	15.41	12.23	1.01	70687.11
12	8.19	10.55	50.92	1.61	15.70	11.32	1.01	77943.33
13	7.87	9.73	57.78	1.62	16.12	11.88	1.01	72866.99
14	9.22	10.47	54.98	1.78	15.88	11.83	1.02	73149.71
15	9.17	11.69	63.18	1.34	16.05	11.88	1.01	72424.26
16	6.46	3.61	64.68	1.08	15.97	11.95	1.04	72016.70
17	9.18	3.63	50.40	0.77	18.82	10.93	1.06	78150.07
18	9.39	3.35	56.20	0.64	19.09	11.07	1.07	76646.00
19	9.05	3.35	41.35	0.91	18.13	11.18	1.05	76392.26
20	7.87	2.62	53.42	0.79	18.29	11.28	1.07	75962.54
21	9.46	2.70	50.75	1.28	17.67	11.33	1.05	75519.72
22	8.36	3.16	68.24	0.88	17.55	11.90	1.06	71390.95
23	9.40	3.26	63.45	1.00	17.81	11.66	1.06	73073.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.81	6.90	55.81	1.31	17.06	11.56	1.04	74101.38
最大值	14.09	11.69	68.24	2.20	20.45	12.23	1.09	78150.07
發生時間	0	15	22	10	1	11		17
最小值	5.55	2.62	41.30	0.64	15.41	10.73	0.99	70627.61
發生時間	9	20	0	18	11	1		6
零點偏移(率)	-0.04 %	-0.08 %	-0.03 %	-0.01 %		-0.46		0.00 %
全幅偏移(率)	0.01 %	0.53 %	-0.60 %	0.48 %		0.15		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.08	4.14	49.33	2.55	14.83	10.34	1.00	85972.33
1	9.32	4.80	53.71	2.54	17.12	10.26	1.00	84165.86
2	9.09	3.13	53.62	1.77	16.82	10.31	0.99	84606.14
3	9.59	5.04	57.74	1.13	16.98	10.23	0.99	85343.56
4	9.05	3.98	62.39	1.37	16.24	10.37	0.99	84859.48
5	9.25	5.35	53.79	1.65	15.90	10.44	0.99	84511.00
6	10.52	2.72	58.25	1.19	16.54	10.39	1.05	84156.62
7	9.30	3.52	58.43	1.41	16.45	10.33	1.08	85140.11
8	9.07	4.89	34.23	1.51	16.38	10.12	1.08	86743.67
9	10.45	8.36	43.47	1.04	18.21	9.72	1.06	88447.17
10	7.83	7.29	63.05	1.35	17.11	9.83	1.05	88065.65
11	12.24	4.65	61.70	2.11	15.06	10.81	1.05	82520.41
12	8.50	4.91	57.15	1.36	16.71	10.05	1.05	86522.61
13	7.62	9.74	61.01	2.52	14.47	10.70	1.05	83176.91
14	7.43	1.95	60.85	2.46	14.88	10.47	1.05	85755.59
15	7.58	2.24	60.75	2.36	15.22	10.44	1.05	85603.55
16	8.93	2.84	51.06	1.81	18.04	9.48	1.03	90246.34
17	9.07	2.91	48.99	2.09	17.94	9.50	1.03	89715.52
18	8.15	2.53	56.92	1.75	17.98	9.50	1.05	90094.13
19	9.05	3.14	57.80	2.13	16.75	9.98	1.05	87071.01
20	6.33	7.70	55.40	2.57	16.57	9.98	1.06	87565.28
21	7.53	3.24	56.07	2.02	17.69	9.67	1.05	88879.65
22	1.42	2.28	61.70	0.73	19.52	9.73	1.05	86497.48
23	3.08	3.09	48.15	1.05	20.43	9.03	1.07	90516.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.31	4.35	55.23	1.77	16.83	10.07	1.04	86507.34
最大值	12.24	9.74	63.05	2.57	20.43	10.81	1.10	90516.14
發生時間	11	13	10	20	23	11		23
最小值	1.42	1.95	34.23	0.73	14.47	9.03	0.99	82520.41
發生時間	22	14	8	22	13	23		11
零點偏移(率)	-0.08 %	-0.01 %	-0.10 %	-0.01 %		0.01		-0.10 %
全幅偏移(率)	0.00 %	0.13 %	-0.59 %	0.02 %		-0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.28	4.17	52.05	1.21	16.32	10.99	0.99	76694.73
1	11.39	7.84	45.44	1.71	16.21	10.26	0.99	81577.54
2	9.71	3.99	42.36	1.71	15.35	10.38	0.98	78681.53
3	9.85	4.14	43.56	2.33	13.87	10.80	0.99	74669.26
4	10.41	3.42	61.40	2.36	14.44	11.18	0.99	73765.46
5	8.55	4.02	57.59	1.90	14.96	10.25	0.97	76217.91
6	9.55	5.89	39.54	2.24	13.75	10.64	0.98	73036.58
7	4.16	2.65	59.81	1.71	14.60	11.26	0.98	74122.53
8	10.25	2.44	56.97	1.82	15.25	10.52	0.99	79411.81
9	9.19	2.86	50.42	2.04	14.17	10.92	0.99	79314.28
10	14.84	10.26	57.73	2.89	14.00	11.29	0.98	78920.86
11	13.50	5.49	55.37	3.62	11.82	11.81	0.98	75292.43
12	8.81	4.50	62.71	1.97	14.42	10.98	0.98	78881.53
13	6.74	7.41	67.41	1.99	14.00	11.76	0.99	72384.66
14	6.49	5.87	54.39	1.42	16.15	10.62	0.99	82393.26
15	9.50	6.74	52.26	1.86	14.59	11.29	0.99	77682.84
16	1.19	1.90	51.51	1.26	15.67	11.39	0.98	73468.14
17	1.33	2.60	28.27	1.28	15.64	10.83	0.97	78763.83
18	1.37	0.21	38.27	0.98	16.72	10.68	0.97	75780.77
19	6.00	1.84	41.24	1.73	14.75	11.08	0.98	75311.80
20	5.64	13.46	32.00	1.58	15.39	11.34	0.98	76637.69
21	11.55	9.12	39.84	2.34	14.41	11.24	0.97	77502.40
22	6.78	5.42	61.96	1.78	14.88	11.50	0.97	74427.78
23	4.70	1.37	52.54	1.11	16.57	11.08	0.97	75552.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.95	4.90	50.19	1.87	14.91	11.00	0.98	76687.18
最大值	14.84	13.46	67.41	3.62	16.72	11.81	1.02	82393.26
發生時間	10	20	13	11	18	11		14
最小值	1.19	0.21	28.27	0.98	11.82	10.25	0.96	72384.66
發生時間	16	18	17	18	11	5		13
零點偏移(率)	-0.08 %	-0.04 %	-0.08 %	-0.04 %		0.02		0.00 %
全幅偏移(率)	0.02 %	0.03 %	-0.13 %	0.03 %		0.10		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								