

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年06月08日

報表日期: 113年06月08日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.94	6.53	46.60	1.25	18.04	11.11	1.02	82744.15
1	8.89	3.51	42.28	1.74	17.96	11.17	1.02	83339.09
2	15.29	3.87	50.90	2.33	18.48	11.08	1.02	85277.51
3	8.25	4.96	64.56	2.25	17.46	11.30	1.02	84605.48
4	7.95	5.26	60.37	1.31	18.51	11.32	1.02	83179.68
5	11.44	2.50	55.52	1.12	19.69	10.24	1.02	87269.53
6	8.29	4.22	60.72	0.73	19.76	11.07	1.03	83633.12
7	7.53	4.01	48.89	0.85	19.48	11.29	1.04	82005.63
8	9.63	3.93	42.44	1.24	19.58	10.48	1.06	88330.32
9	9.79	4.37	43.48	2.95	16.66	11.13	1.06	85601.28
10	6.50	4.00	61.76	1.51	19.08	10.96	1.06	84989.94
11	11.90	4.86	50.67	1.96	19.53	10.38	1.04	89314.27
12	7.28	6.67	55.70	2.41	16.83	11.44	1.02	83224.51
13	3.10	5.65	51.07	2.41	16.79	11.20	1.03	84209.04
14	2.58	4.60	52.53	2.20	16.61	11.25	1.04	85231.12
15	4.87	4.39	52.64	2.65	16.77	11.33	1.05	84212.60
16	4.92	4.40	52.58	1.81	18.20	11.02	1.05	85507.46
17	2.46	3.09	55.96	1.22	19.60	10.58	1.05	87916.41
18	2.96	2.77	55.78	1.10	18.95	11.18	1.04	83558.39
19	1.38	4.43	53.56	0.77	19.28	11.57	1.04	79390.54
20	3.25	5.41	37.57	1.38	18.35	10.59	1.02	88966.57
21	7.34	5.52	34.66	1.99	17.74	10.69	1.02	88847.23
22	5.34	4.56	46.64	0.91	21.07	9.89	1.04	91633.54
23	6.13	5.35	47.96	0.64	21.79	9.82	1.05	91527.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.92	4.54	51.04	1.61	18.59	10.92	1.04	85604.78
最 大 值	15.29	6.67	64.56	2.95	21.79	11.57	1.06	91633.54
發生時間	2	12	3	9	23	19		22
最 小 值	1.38	2.50	34.66	0.64	16.61	9.82	1.00	79390.54
發生時間	19	5	21	23	14	23		19
零點偏移(率)	-0.10 %	-0.04 %	-0.01 %	0.00 %		-0.14		0.10 %
全幅偏移(率)	0.00 %	-0.00 %	-0.55 %	0.49 %		-0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月08日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.20	3.30	52.86	1.27	18.27	10.83	1.02	81207.34
1	6.48	3.21	59.74	1.16	20.15	10.34	1.02	83510.36
2	10.12	4.10	46.88	2.78	17.37	10.15	1.02	88182.88
3	10.73	2.10	62.47	2.87	16.72	10.85	1.02	82898.53
4	9.68	2.12	66.76	1.48	17.81	10.94	1.02	80749.15
5	10.34	2.90	56.54	0.76	20.95	9.95	1.02	85745.58
6	7.62	4.28	47.11	1.07	19.19	10.89	0.99	81733.80
7	8.95	6.35	43.65	1.83	18.87	10.31	0.99	85052.14
8	7.41	2.49	57.22	2.15	16.57	11.47	1.01	77828.06
9	5.02	3.35	56.00	0.64	20.66	10.29	1.01	83436.62
10	7.66	4.71	39.12	1.60	19.00	10.21	1.00	85282.85
11	7.87	2.86	53.23	2.39	17.11	10.83	0.99	82768.78
12	5.06	3.61	59.19	2.80	15.92	11.27	1.02	80251.57
13	1.41	4.06	59.05	3.06	15.35	11.37	1.00	79871.80
14	1.53	2.72	57.78	3.04	15.25	11.48	0.98	78896.90
15	3.04	2.05	59.94	2.32	17.25	10.78	0.97	82853.09
16	1.87	1.38	66.75	1.83	17.32	11.09	0.98	79852.99
17	0.49	0.30	67.40	0.92	19.12	10.13	0.98	86252.93
18	1.35	1.86	56.95	1.93	17.01	11.32	0.99	78687.09
19	2.49	3.27	54.30	1.37	17.68	10.67	1.00	83219.64
20	2.62	0.83	50.32	2.10	17.26	10.72	1.00	83228.43
21	3.25	1.81	56.63	1.88	16.66	11.10	1.01	80763.18
22	5.58	1.98	55.92	1.75	16.54	11.14	0.98	80382.28
23	3.35	1.83	62.81	1.17	17.56	11.54	0.99	76218.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.50	2.81	56.19	1.84	17.73	10.82	1.00	82036.43
最 大 值	10.73	6.35	67.40	3.06	20.95	11.54	1.05	88182.88
發生時間	3	7	17	13	5	23		2
最 小 值	0.49	0.30	39.12	0.64	15.25	9.95	0.97	76218.44
發生時間	17	17	10	9	14	5		23
零點偏移(率)	-0.09 %	-0.00 %	-0.01 %	-0.05 %		-0.06		-0.10 %
全幅偏移(率)	0.13 %	0.31 %	-0.07 %	0.34 %		0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月08日

[illegible]