

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月23日

報表日期: 114年06月23日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.64	8.87	54.46	2.03	14.87	11.30	1.24	81311.74
1	8.30	4.17	56.39	1.75	16.61	11.38	1.23	79772.48
2	7.79	8.07	53.67	2.54	16.63	10.93	1.22	79287.06
3	10.76	7.18	50.34	2.54	16.50	11.21	1.23	82370.94
4	8.33	2.85	61.53	2.48	15.27	11.89	1.23	77392.18
5	4.78	8.34	56.06	1.44	17.52	11.42	1.25	78781.45
6	2.66	14.99	40.92	2.27	18.45	10.71	1.25	78817.60
7	1.56	4.30	48.99	1.89	16.43	10.99	1.24	82598.17
8	2.85	3.02	60.28	1.74	16.14	11.60	1.25	78993.60
9	4.21	1.54	61.02	1.80	16.80	11.67	1.25	79059.64
10	4.04	1.98	57.63	1.70	16.96	11.60	1.24	79379.18
11	10.80	7.59	61.31	2.70	15.58	11.95	1.25	77259.96
12	10.82	9.62	51.14	4.00	12.38	12.36	1.24	76618.10
13	6.88	2.77	52.55	2.58	13.67	12.30	1.25	76293.02
14	6.22	4.32	52.38	2.73	13.83	12.29	1.24	73942.85
15	2.17	3.52	55.99	1.78	15.39	12.13	1.24	75916.68
16	2.10	3.13	66.06	1.93	15.01	11.85	1.25	79507.17
17	2.68	5.51	48.68	2.57	13.81	12.03	1.23	78571.56
18	3.57	4.88	57.56	1.82	15.42	12.01	1.23	77649.33
19	2.18	3.18	53.61	1.86	15.13	11.80	1.23	79621.41
20	4.49	2.88	64.74	1.43	16.23	11.89	1.25	77639.69
21	8.05	3.01	47.63	2.14	15.25	11.61	1.25	80914.33
22	5.47	2.89	46.78	1.87	16.02	11.57	1.25	80350.64
23	3.04	2.64	53.81	1.18	17.08	11.57	1.25	79562.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.52	5.05	54.73	2.12	15.71	11.67	1.24	78817.12
最 大 值	10.82	14.99	66.06	4.00	18.45	12.36	1.27	82598.17
發生時間	12	6	16	12	6	12		7
最 小 值	1.56	1.54	40.92	1.18	12.38	10.71	1.21	73942.85
發生時間	7	9	6	23	12	6		14
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	-0.00 %		-0.02		0.00 %
全幅偏移(率)	0.00 %	0.33 %	-0.13 %	0.00 %		0.16		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月23日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.55	3.47	57.05	2.52	16.65	10.96	1.10	79018.20
1	11.27	9.34	57.99	3.40	16.79	10.76	1.10	79406.91
2	7.20	2.95	54.32	2.39	16.84	10.68	1.09	80010.14
3	6.17	2.57	63.28	1.81	17.76	10.79	1.09	80254.18
4	6.48	3.77	55.36	2.85	16.06	11.00	1.08	77301.18
5	8.87	3.18	57.74	2.48	16.53	10.75	1.08	78706.95
6	13.80	3.99	49.46	3.82	14.51	11.07	1.07	72753.12
7	5.49	1.95	54.71	2.27	16.17	10.65	1.09	78476.97
8	6.83	2.43	49.92	2.34	16.33	10.81	1.10	75926.11
9	6.23	1.88	60.71	1.64	18.30	10.43	1.10	80214.80
10	5.80	1.80	51.79	1.77	17.26	10.37	1.10	76811.52
11	6.55	3.40	53.20	1.77	17.13	10.36	1.10	76762.08
12	7.90	3.30	62.10	2.20	16.21	11.22	1.09	78895.13
13	9.58	2.98	51.38	3.29	16.76	10.89	1.10	79562.62
14	2.58	1.63	65.54	2.65	16.14	11.35	1.10	78142.64
15	3.89	4.34	62.35	3.37	15.10	11.61	1.10	77900.18
16	3.30	2.42	58.42	3.05	14.88	11.26	1.09	81296.82
17	6.62	2.12	58.59	2.49	15.81	10.95	1.09	83060.58
18	9.79	5.00	56.88	2.38	16.66	10.42	1.09	84048.22
19	7.81	3.51	59.88	1.67	17.57	10.30	1.09	83606.84
20	9.34	8.21	52.08	2.51	16.42	10.53	1.09	83149.78
21	9.01	2.15	64.70	2.53	16.12	10.83	1.09	83360.16
22	8.74	2.24	57.40	2.21	16.90	10.60	1.10	84529.46
23	4.47	2.21	65.10	1.89	17.12	11.15	1.10	79188.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.30	3.37	57.50	2.47	16.50	10.82	1.09	79682.63
最 大 值	13.80	9.34	65.54	3.82	18.30	11.61	1.11	84529.46
發生時間	6	1	14	6	9	15		22
最 小 值	2.58	1.63	49.46	1.64	14.51	10.30	1.06	72753.12
發生時間	14	14	6	9	6	19		6
零點偏移(率)	-0.15 %	-0.09 %	-0.08 %	-0.01 %		-0.13		-0.10 %
全幅偏移(率)	0.14 %	0.23 %	0.19 %	0.21 %		-0.03		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月23日

報表日期: 114年06月23日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	2.23	2.72	59.76	3.05	16.19	10.02	1.42	74600.89
1	2.18	2.79	62.16	2.94	17.32	9.85	1.46	75332.48
2	2.65	2.57	55.32	2.99	16.92	9.70	1.48	76666.69
3	5.69	4.13	56.01	4.14	14.61	10.27	1.48	74014.94
4	1.49	3.94	58.45	3.38	15.29	9.96	1.45	72701.32
5	1.65	5.13	57.83	3.15	16.38	9.62	1.43	75030.98
6	2.94	4.97	53.72	3.83	14.86	9.34	1.45	70452.32
7	0.98	5.16	47.52	1.56	16.06	8.66	1.42	68055.97
8	1.04	5.09	51.00	1.51	16.15	8.70	1.40	72244.39
9	2.16	2.92	49.22	1.82	14.53	9.35	1.40	72953.62
10	1.02	2.09	58.87	1.43	17.02	9.21	1.38	73610.59
11	1.04	3.83	59.96	2.86	15.34	9.59	1.41	69957.63
12	1.07	2.14	61.05	3.20	14.93	9.95	1.42	75161.71
13	1.11	5.99	61.87	4.15	13.05	10.54	1.43	71823.16
14	1.11	10.91	68.57	3.85	14.12	10.40	1.43	69980.98
15	0.03	7.59	62.52	4.64	14.17	10.01	1.43	72757.66
16	0.33	10.41	65.24	3.21	15.40	9.69	1.41	76723.35
17	2.54	3.19	65.22	3.24	15.55	9.68	1.40	78032.09
18	2.23	1.97	64.00	3.11	16.83	9.27	1.38	77863.20
19	0.62	8.78	62.05	3.03	16.11	8.97	1.39	78419.95
20	2.74	11.25	63.08	3.38	14.11	9.82	1.43	76298.44
21	0.23	2.77	68.83	3.15	15.99	9.86	1.43	78338.96
22	0.18	7.70	60.08	3.00	16.45	9.19	1.40	80487.55
23	0.61	3.44	66.18	3.16	16.00	9.81	1.38	79554.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	1.58	5.06	59.94	3.07	15.56	9.64	1.42	74627.64
最 大 值	5.69	11.25	68.83	4.64	17.32	10.54	1.48	80487.55
發生時間	3	20	21	15	1	13		22
最 小 值	0.03	1.97	47.52	1.43	13.05	8.66	1.36	68055.97
發生時間	15	18	7	10	13	7		7
零點偏移(率)	-0.15 %	-0.08 %	-0.05 %	0.00 %		-0.09		-0.10 %
全幅偏移(率)	0.02 %	-0.26 %	-1.14 %	0.02 %		0.02		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								