

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月24日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 9.60 | 12.18 | 54.05 | 1.30 | 19.13 | 11.33 | 1.32 | 78771.31 |
| 1 | 11.32 | 12.00 | 46.40 | 1.92 | 20.07 | 10.35 | 1.31 | 84615.70 |
| 2 | 8.89 | 12.18 | 51.67 | 2.69 | 15.69 | 11.77 | 1.32 | 75215.87 |
| 3 | 8.83 | 12.49 | 50.36 | 1.68 | 17.92 | 11.21 | 1.33 | 77677.60 |
| 4 | 9.64 | 11.66 | 48.75 | 1.79 | 17.92 | 10.99 | 1.33 | 82737.41 |
| 5 | 3.80 | 11.88 | 49.55 | 3.20 | 17.85 | 11.33 | 1.32 | 83925.68 |
| 6 | 10.24 | 11.73 | 56.97 | 3.00 | 18.97 | 10.83 | 1.31 | 82696.40 |
| 7 | 8.71 | 11.84 | 43.63 | 3.23 | 18.11 | 10.65 | 1.31 | 85270.41 |
| 8 | 8.87 | 12.28 | 61.94 | 3.11 | 17.01 | 11.35 | 1.31 | 80039.08 |
| 9 | 12.18 | 12.26 | 60.32 | 2.83 | 18.37 | 10.95 | 1.30 | 81197.12 |
| 10 | 7.41 | 11.92 | 53.38 | 3.01 | 16.62 | 11.27 | 1.31 | 78222.61 |
| 11 | 13.09 | 11.77 | 57.80 | 2.69 | 17.07 | 11.16 | 1.30 | 79183.25 |
| 12 | 6.72 | 11.96 | 62.63 | 2.14 | 16.72 | 11.36 | 1.29 | 76881.01 |
| 13 | 10.02 | 12.03 | 62.66 | 2.34 | 16.88 | 11.33 | 1.29 | 76246.77 |
| 14 | 11.13 | 11.89 | 49.03 | 2.22 | 17.41 | 11.03 | 1.28 | 79092.89 |
| 15 | 7.83 | 12.17 | 61.00 | 2.05 | 17.05 | 11.36 | 1.29 | 76429.82 |
| 16 | 9.69 | 11.57 | 57.77 | 1.69 | 18.04 | 10.83 | 1.29 | 82612.78 |
| 17 | 8.32 | 11.75 | 43.40 | 1.84 | 17.19 | 11.11 | 1.29 | 79810.93 |
| 18 | 12.05 | 11.89 | 50.67 | 1.63 | 18.44 | 10.98 | 1.30 | 82186.89 |
| 19 | 12.92 | 12.37 | 39.77 | 2.15 | 17.72 | 10.97 | 1.30 | 82224.16 |
| 20 | 6.94 | 12.16 | 56.57 | 2.07 | 16.80 | 11.08 | 1.31 | 81740.18 |
| 21 | 13.17 | 11.76 | 52.43 | 2.56 | 16.34 | 11.25 | 1.31 | 79581.72 |
| 22 | 7.66 | 12.18 | 63.69 | 2.37 | 16.21 | 11.58 | 1.31 | 77130.41 |
| 23 | 8.86 | 12.92 | 42.96 | 1.86 | 16.90 | 11.40 | 1.31 | 80030.20 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.50 | 12.04 | 53.22 | 2.31 | 17.52 | 11.14 | 1.30 | 80146.67 |
| 最大值 | 13.17 | 12.92 | 63.69 | 3.23 | 20.07 | 11.77 | 1.34 | 85270.41 |
| 發生時間 | 21 | 23 | 22 | 7 | 1 | 2 | | 7 |
| 最小值 | 3.80 | 11.57 | 39.77 | 1.30 | 15.69 | 10.35 | 1.28 | 75215.87 |
| 發生時間 | 5 | 16 | 19 | 0 | 2 | 1 | | 2 |
| 零點偏移(率) | -0.09 % | 0.01 % | -0.02 % | -0.01 % | | -0.06 | -0.01 | 0.30 % |
| 全幅偏移(率) | -1.84 % | -1.71 % | -0.97 % | -1.71 % | | -0.02 | 0.00 | 0.30 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月24日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.52 | 12.46 | 55.21 | 0.72 | 19.11 | 10.15 | 1.02 | 80913.04 |
| 1 | 10.93 | 11.97 | 48.15 | 1.77 | 17.58 | 10.56 | 1.02 | 79092.28 |
| 2 | 10.67 | 11.74 | 53.90 | 1.15 | 17.54 | 10.42 | 1.02 | 79203.49 |
| 3 | 9.74 | 11.69 | 48.57 | 0.85 | 19.42 | 10.06 | 1.02 | 79731.28 |
| 4 | 8.57 | 11.65 | 46.88 | 1.78 | 19.45 | 9.91 | 1.02 | 81437.95 |
| 5 | 8.81 | 11.61 | 45.02 | 2.10 | 18.18 | 10.26 | 1.02 | 79306.62 |
| 6 | 10.16 | 11.57 | 49.36 | 0.82 | 18.32 | 10.33 | 1.02 | 79380.01 |
| 7 | 9.85 | 11.69 | 47.59 | 1.54 | 17.44 | 10.38 | 1.01 | 79265.66 |
| 8 | 9.14 | 11.80 | 46.83 | 1.20 | 17.79 | 10.41 | 1.02 | 79519.46 |
| 9 | 11.06 | 11.78 | 49.45 | 1.53 | 17.71 | 10.41 | 1.01 | 78519.45 |
| 10 | 10.14 | 11.70 | 49.14 | 1.51 | 17.26 | 10.43 | 1.02 | 77341.85 |
| 11 | 8.67 | 11.92 | 49.87 | 1.56 | 17.32 | 10.41 | 1.02 | 77765.63 |
| 12 | 10.24 | 12.30 | 55.73 | 1.34 | 17.21 | 10.41 | 1.02 | 77497.81 |
| 13 | 8.91 | 11.79 | 60.69 | 1.17 | 17.81 | 10.42 | 1.04 | 78387.43 |
| 14 | 8.21 | 11.69 | 56.74 | 1.61 | 17.86 | 10.27 | 1.04 | 78263.45 |
| 15 | 13.69 | 11.82 | 64.02 | 1.41 | 17.99 | 10.35 | 1.05 | 77838.31 |
| 16 | 4.73 | 7.34 | 64.50 | 1.34 | 17.22 | 10.27 | 1.04 | 80591.13 |
| 17 | 12.68 | 12.21 | 44.76 | 1.53 | 16.54 | 10.63 | 1.04 | 78648.89 |
| 18 | 7.07 | 12.29 | 45.90 | 1.54 | 17.83 | 10.21 | 1.02 | 78873.92 |
| 19 | 12.09 | 11.96 | 54.73 | 2.52 | 17.60 | 10.71 | 1.02 | 75941.79 |
| 20 | 16.04 | 13.13 | 52.09 | 2.11 | 16.79 | 10.05 | 1.02 | 79864.71 |
| 21 | 6.30 | 12.29 | 51.25 | 2.34 | 15.56 | 10.49 | 1.02 | 78040.29 |
| 22 | 9.17 | 6.99 | 48.61 | 1.14 | 18.21 | 9.97 | 1.02 | 79023.76 |
| 23 | 12.40 | 12.18 | 58.22 | 1.24 | 18.14 | 10.25 | 1.02 | 75678.54 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.91 | 11.57 | 51.97 | 1.49 | 17.75 | 10.32 | 1.02 | 78755.28 |
| 最大值 | 16.04 | 13.13 | 64.50 | 2.52 | 19.45 | 10.71 | 1.06 | 81437.95 |
| 發生時間 | 20 | 20 | 16 | 19 | 4 | 19 | | 4 |
| 最小值 | 4.73 | 6.99 | 44.76 | 0.72 | 15.56 | 9.91 | 1.00 | 75678.54 |
| 發生時間 | 16 | 22 | 17 | 0 | 21 | 4 | | 23 |
| 零點偏移(率) | -0.09 % | -0.01 % | -0.02 % | -0.01 % | | -0.10 | -0.01 | 0.00 % |
| 全幅偏移(率) | -1.81 % | -0.91 % | 0.58 % | -0.39 % | | -0.13 | 0.00 | 0.00 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月24日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 9.27 | 11.58 | 50.32 | 1.21 | 21.14 | 9.07 | 1.37 | 79263.60 |
| 1 | 9.50 | 12.20 | 55.27 | 1.79 | 20.43 | 9.10 | 1.38 | 76148.28 |
| 2 | 9.06 | 12.01 | 57.41 | 2.25 | 16.95 | 9.77 | 1.38 | 69628.88 |
| 3 | 9.28 | 11.83 | 53.71 | 1.83 | 18.55 | 10.13 | 1.40 | 69152.85 |
| 4 | 9.22 | 12.01 | 48.28 | 2.19 | 18.88 | 9.87 | 1.40 | 73941.58 |
| 5 | 10.56 | 11.44 | 47.70 | 2.11 | 17.12 | 10.22 | 1.40 | 71464.31 |
| 6 | 8.57 | 11.64 | 48.01 | 2.14 | 17.86 | 10.11 | 1.41 | 72342.11 |
| 7 | 8.47 | 11.26 | 46.26 | 2.36 | 18.86 | 9.76 | 1.43 | 69714.24 |
| 8 | 9.23 | 11.33 | 53.24 | 2.32 | 18.67 | 9.86 | 1.43 | 75415.43 |
| 9 | 9.98 | 11.58 | 54.30 | 2.15 | 17.68 | 10.21 | 1.42 | 73260.09 |
| 10 | 8.41 | 11.73 | 53.62 | 2.15 | 17.34 | 10.27 | 1.43 | 72745.27 |
| 11 | 10.58 | 12.11 | 54.85 | 2.26 | 16.68 | 10.63 | 1.42 | 72390.05 |
| 12 | 9.29 | 12.06 | 61.74 | 2.04 | 17.74 | 10.66 | 1.41 | 74760.46 |
| 13 | 8.36 | 12.12 | 57.02 | 2.19 | 17.06 | 10.75 | 1.40 | 74429.19 |
| 14 | 10.23 | 12.45 | 57.79 | 2.31 | 16.34 | 10.95 | 1.40 | 72358.61 |
| 15 | 10.31 | 12.14 | 59.77 | 2.42 | 16.39 | 10.82 | 1.39 | 72663.30 |
| 16 | 9.80 | 11.74 | 52.02 | 2.26 | 16.49 | 10.33 | 1.38 | 72069.77 |
| 17 | 5.96 | 11.69 | 45.94 | 1.89 | 17.49 | 9.92 | 1.39 | 74120.51 |
| 18 | 9.41 | 12.44 | 45.81 | 2.15 | 16.33 | 10.09 | 1.40 | 73594.49 |
| 19 | 12.50 | 11.78 | 42.84 | 2.79 | 18.51 | 9.32 | 1.41 | 75508.91 |
| 20 | 8.02 | 13.76 | 44.43 | 2.73 | 16.69 | 9.72 | 1.42 | 72143.14 |
| 21 | 10.66 | 11.85 | 49.10 | 2.36 | 16.75 | 10.08 | 1.41 | 72575.49 |
| 22 | 8.63 | 13.16 | 49.13 | 2.44 | 17.18 | 10.18 | 1.39 | 69044.53 |
| 23 | 10.45 | 11.34 | 48.34 | 2.18 | 18.99 | 9.62 | 1.39 | 74518.39 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.41 | 11.97 | 51.54 | 2.19 | 17.76 | 10.06 | 1.40 | 73052.23 |
| 最大值 | 12.50 | 13.76 | 61.74 | 2.79 | 21.14 | 10.95 | 1.45 | 79263.60 |
| 發生時間 | 19 | 20 | 12 | 19 | 0 | 14 | | 0 |
| 最小值 | 5.96 | 11.26 | 42.84 | 1.21 | 16.33 | 9.07 | 1.36 | 69044.53 |
| 發生時間 | 17 | 7 | 19 | 0 | 18 | 0 | | 22 |
| 零點偏移(率) | -0.02 % | -0.01 % | -0.01 % | -0.01 % | | -0.20 | -0.01 | 0.20 % |
| 全幅偏移(率) | -0.89 % | -0.22 % | 0.85 % | 0.46 % | | 0.10 | 0.04 | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |