

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.31	12.16	55.02	1.87	18.88	11.44	1.25	71191.53
1	15.18	12.09	44.88	3.35	18.90	11.12	1.25	73873.61
2	7.17	11.95	52.56	3.97	18.04	11.08	1.25	75279.10
3	13.06	11.72	54.94	3.89	17.81	11.20	1.25	74390.38
4	3.37	11.89	52.98	3.30	17.86	11.36	1.25	73218.49
5	10.89	13.31	51.34	2.47	18.00	11.06	1.25	72704.60
6	9.56	13.02	53.75	1.94	17.95	11.05	1.26	75280.93
7	9.77	12.86	52.66	2.30	17.12	11.23	1.26	74557.27
8	8.78	13.10	56.41	2.04	17.34	11.05	1.25	75848.21
9	8.38	13.17	59.54	1.71	19.91	10.57	1.27	77901.08
10	3.87	12.98	47.17	2.12	16.98	11.36	1.25	75695.36
11	2.33	12.98	52.06	1.22	18.07	11.40	1.25	73662.55
12	3.70	12.96	48.88	0.78	19.34	10.91	1.25	75809.09
13	5.07	12.48	56.59	0.32	21.62	10.45	1.25	76785.85
14	5.55	12.87	51.49	1.07	18.29	11.15	1.25	73745.85
15	6.88	13.44	47.11	1.48	16.00	11.77	1.25	69927.47
16	12.77	13.68	54.27	3.32	16.61	11.38	1.25	73709.08
17	13.92	13.01	57.75	3.36	16.41	11.40	1.25	73438.50
18	9.12	13.40	50.07	2.10	16.55	11.38	1.25	73152.90
19	13.60	12.36	54.71	2.22	19.06	10.79	1.25	76216.78
20	15.62	14.35	48.87	3.83	15.26	11.59	1.25	72383.54
21	13.32	13.12	48.39	2.42	15.88	11.36	1.26	71209.98
22	10.33	12.79	42.39	1.85	17.21	11.11	1.25	74242.91
23	12.08	13.39	52.70	2.55	19.44	10.71	1.26	75644.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.36	12.88	51.94	2.31	17.86	11.16	1.25	74161.24
最大值	15.62	14.35	59.54	3.97	21.62	11.77	1.28	77901.08
發生時間	20	20	9	2	13	15		9
最小值	2.33	11.72	42.39	0.32	15.26	10.45	1.24	69927.47
發生時間	11	3	22	13	20	13		15
零點偏移(率)	-0.04 %	-0.13 %	-0.02 %	0.00 %		-0.08	-0.01	0.20 %
全幅偏移(率)	2.35 %	-0.52 %	0.08 %	0.02 %		-0.05	0.10	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.16	13.82	47.06	0.95	19.09	10.10	1.00	81876.79
1	9.42	12.38	42.49	0.99	18.58	10.71	1.00	79033.52
2	7.93	12.41	52.02	1.51	19.18	10.44	1.00	80638.82
3	9.60	11.61	49.33	1.36	18.80	10.00	1.01	83452.73
4	7.56	12.30	48.49	1.70	18.21	10.71	1.01	77709.86
5	8.70	12.35	49.30	2.01	17.36	10.66	1.00	82075.86
6	4.70	14.25	48.23	1.58	16.60	10.96	1.02	80816.84
7	4.46	15.04	53.22	1.03	17.53	11.05	1.03	76258.64
8	9.11	14.73	56.40	0.97	19.78	9.93	1.03	83805.27
9	7.91	12.33	50.81	1.55	17.96	10.55	1.02	80777.68
10	4.58	10.17	47.33	2.34	17.81	11.07	1.02	75031.80
11	2.00	11.02	56.79	3.43	16.51	11.03	1.02	72273.66
12	5.41	12.40	53.37	3.47	16.46	10.87	1.02	73756.98
13	4.98	16.07	46.82	3.68	15.77	11.01	1.02	72643.69
14	5.23	10.15	51.04	3.96	15.74	11.06	1.02	71425.88
15	6.04	15.06	51.78	2.53	17.10	10.67	1.02	76514.58
16	9.30	12.07	58.64	2.03	16.50	10.81	1.02	81070.93
17	11.00	11.68	59.89	0.72	18.53	10.42	1.02	82881.14
18	8.66	11.74	56.57	0.66	18.39	10.26	1.02	84875.06
19	9.22	12.02	57.31	1.14	17.18	10.67	1.02	81073.18
20	9.90	11.88	56.52	1.77	16.42	10.76	1.02	80278.35
21	9.79	11.98	58.31	1.20	17.18	10.71	1.02	80883.36
22	9.76	12.18	58.48	0.64	18.14	10.77	1.02	78923.88
23	6.38	11.55	52.22	0.54	19.54	9.82	1.02	80704.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.45	12.55	52.60	1.74	17.68	10.63	1.02	79115.94
最大值	11.00	16.07	59.89	3.96	19.78	11.07	1.05	84875.06
發生時間	17	13	17	14	8	10		18
最小值	2.00	10.15	42.49	0.54	15.74	9.82	0.98	71425.88
發生時間	11	14	1	23	14	23		14
零點偏移(率)	-0.09 %	-0.01 %	-0.03 %	-0.00 %		-0.09	-0.01	0.00 %
全幅偏移(率)	0.90 %	-0.25 %	0.23 %	0.02 %		0.04	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.71	11.70	56.20	3.20	17.02	10.39	1.36	73896.89
1	6.87	11.84	53.79	3.01	19.11	9.90	1.33	75828.29
2	4.88	11.87	61.08	3.13	17.09	10.57	1.31	73807.45
3	5.64	11.56	57.97	3.18	17.67	10.24	1.31	74458.81
4	5.93	11.50	51.46	3.02	17.26	10.21	1.33	73086.64
5	5.29	11.38	53.67	3.09	17.55	10.05	1.34	73885.90
6	5.78	11.41	59.56	3.06	17.43	10.14	1.34	73063.90
7	3.36	13.49	49.07	3.03	16.73	10.32	1.32	75035.39
8	4.36	13.75	52.14	3.16	16.66	10.03	1.33	73373.88
9	3.86	11.35	53.24	2.85	16.93	10.10	1.33	72143.34
10	3.13	11.58	59.18	3.05	16.04	10.21	1.34	71066.46
11	3.80	11.56	47.03	2.92	16.96	10.13	1.34	71695.77
12	3.00	11.30	50.63	2.70	16.70	10.21	1.34	71019.31
13	3.00	11.69	55.95	2.96	17.04	10.01	1.32	72858.81
14	3.02	11.46	54.67	2.83	17.99	9.99	1.32	72270.29
15	5.21	10.90	54.50	3.02	20.75	9.11	1.35	75929.11
16	9.73	11.27	49.46	2.50	19.76	9.08	1.35	75332.77
17	8.09	11.74	46.31	1.76	18.00	8.62	1.33	71514.14
18	7.92	11.01	55.91	2.54	17.55	8.91	1.30	71243.22
19	9.14	10.92	52.12	2.91	18.28	8.91	1.29	71881.24
20	10.30	10.97	53.11	3.05	17.59	8.99	1.31	71450.21
21	8.23	11.38	53.18	2.77	17.52	8.97	1.32	70779.47
22	8.88	11.60	50.86	3.19	18.21	8.87	1.33	70171.87
23	5.66	11.46	37.32	3.07	18.84	8.59	1.31	69878.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.99	11.61	52.85	2.92	17.69	9.69	1.33	72736.33
最大值	10.30	13.75	61.08	3.20	20.75	10.57	1.37	75929.11
發生時間	20	8	2	0	15	2		15
最小值	3.00	10.90	37.32	1.76	16.04	8.59	1.29	69878.76
發生時間	12	15	23	17	10	23		23
零點偏移(率)	-0.07 %	0.01 %	-0.03 %	0.00 %		-0.11	-0.01	-0.10 %
全幅偏移(率)	2.85 %	-0.15 %	-0.08 %	-0.01 %		0.25	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								