

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.45	10.54	50.79	0.68	19.36	11.32	1.07	73042.00
1	2.63	12.69	60.46	0.69	20.43	11.46	1.09	71072.64
2	5.62	8.21	50.57	0.88	18.77	11.09	1.10	75258.71
3	6.67	7.56	56.09	0.61	18.53	11.23	1.08	75009.38
4	1.48	8.90	59.16	0.42	19.09	11.38	1.06	72940.30
5	6.74	12.27	53.48	0.82	19.19	11.02	1.06	76388.28
6	6.79	12.16	52.32	0.91	18.31	11.37	1.07	73917.68
7	4.10	13.33	59.41	0.67	18.49	11.69	1.06	71071.58
8	3.00	11.42	46.27	0.52	19.49	10.35	1.09	79795.37
9	10.06	8.86	43.11	1.26	18.19	10.96	1.09	75956.70
10	9.77	10.54	42.93	1.84	16.79	11.15	1.08	75663.50
11	7.67	7.39	60.45	0.66	19.36	10.97	1.06	75202.84
12	5.40	6.14	59.11	0.25	20.93	10.23	1.08	78702.13
13	9.21	6.66	52.68	0.94	18.67	10.72	1.09	76913.04
14	7.82	6.78	45.49	0.71	20.20	10.48	1.07	78094.77
15	8.89	6.04	47.66	0.81	19.61	10.69	1.09	76776.05
16	7.15	7.28	40.46	2.05	16.51	11.31	1.09	73683.90
17	9.07	2.16	43.72	1.86	17.38	11.44	1.07	70991.21
18	6.14	6.84	57.81	0.73	19.04	11.56	1.06	70691.42
19	9.12	6.47	51.87	1.10	19.18	11.07	1.05	74844.98
20	8.83	5.86	47.65	0.80	19.47	10.80	1.09	76614.11
21	7.25	6.77	46.38	0.87	20.01	10.46	1.08	77841.95
22	9.69	6.82	41.69	1.56	17.72	11.46	1.06	72837.60
23	8.79	6.00	34.97	1.00	17.98	11.28	1.07	74477.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.97	8.24	50.19	0.94	18.86	11.06	1.08	74907.83
最大值	10.06	13.33	60.46	2.05	20.93	11.69	1.10	79795.37
發生時間	9	7	1	16	12	7		8
最小值	1.48	2.16	34.97	0.25	16.51	10.23	1.05	70691.42
發生時間	4	17	23	12	16	12		18
零點偏移(率)	-0.02 %	-0.02 %	-0.01 %	0.00 %		-0.13		0.00 %
全幅偏移(率)	-0.11 %	-0.26 %	-0.29 %	0.22 %		-0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.26	3.52	47.28	1.67	19.00	10.16	1.05	85096.37
1	1.21	9.42	48.46	2.27	18.52	10.11	1.05	85977.68
2	1.99	8.50	49.92	2.06	18.51	10.03	1.05	86693.91
3	2.53	3.80	53.93	2.07	17.97	10.25	1.06	84452.21
4	5.32	4.19	52.86	2.37	17.86	10.09	1.07	86682.98
5	6.12	4.04	53.32	2.75	17.84	10.18	1.07	85783.26
6	4.53	6.82	57.13	2.27	17.33	10.71	1.06	83161.20
7	4.16	7.61	50.44	2.40	17.84	10.12	1.06	86281.23
8	7.43	7.41	48.96	2.32	17.70	10.10	1.06	86556.53
9	9.10	6.70	52.76	2.77	16.65	10.36	1.05	85389.67
10	9.36	4.10	60.47	3.17	15.25	10.83	1.07	82783.07
11	5.93	5.52	56.97	1.77	18.25	10.44	1.06	83020.26
12	7.86	5.93	51.02	1.89	18.77	10.14	1.05	84574.80
13	8.41	3.40	55.77	3.12	17.34	10.32	1.05	84803.53
14	5.98	6.09	46.88	1.70	19.39	9.82	1.05	86627.93
15	8.60	3.37	59.26	2.68	17.57	9.95	1.05	87433.17
16	8.38	8.33	56.36	3.33	15.84	10.84	1.05	82010.81
17	8.99	4.60	49.66	3.82	15.89	10.73	1.05	82696.43
18	8.96	3.98	38.29	2.20	18.91	9.71	1.06	87812.89
19	8.08	5.51	34.17	1.68	19.42	9.72	1.07	87263.64
20	5.32	3.65	42.75	2.31	17.37	10.34	1.05	84727.16
21	3.11	4.11	46.73	2.95	16.49	10.98	1.05	81749.44
22	5.82	4.40	51.62	2.74	16.49	10.92	1.05	81933.67
23	8.51	4.11	42.61	2.84	16.93	10.45	1.04	84708.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.21	5.38	50.32	2.46	17.63	10.30	1.06	84925.85
最大值	9.36	9.42	60.47	3.82	19.42	10.98	1.07	87812.89
發生時間	10	1	10	17	19	21		18
最小值	1.21	3.37	34.17	1.67	15.25	9.71	1.02	81749.44
發生時間	1	15	19	0	10	18		21
零點偏移(率)	-0.06 %	-0.02 %	-0.01 %	-0.03 %		0.02		-0.20 %
全幅偏移(率)	0.02 %	0.53 %	0.24 %	0.19 %		-0.31		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.34	5.06	53.45	0.88	17.37	10.90	0.92	79549.44
1	4.25	12.96	48.00	1.03	17.65	10.64	0.94	81564.53
2	7.06	7.79	49.86	1.43	16.52	10.74	0.91	81172.99
3	7.03	6.94	51.00	1.37	16.74	10.74	0.91	80652.74
4	8.33	7.55	51.50	1.59	16.46	10.92	0.92	80366.00
5	7.56	7.91	52.69	1.44	16.07	11.07	0.91	77061.19
6	8.46	11.16	49.39	1.18	16.66	10.58	0.91	80347.90
7	7.17	15.48	47.56	0.96	18.29	9.96	0.97	85435.46
8	7.72	3.73	52.63	1.59	15.70	10.95	0.97	80284.84
9	9.63	6.90	57.20	1.50	16.22	10.83	0.97	82722.66
10	9.60	6.80	55.71	2.43	13.62	11.41	0.98	74442.50
11	6.48	5.75	51.74	0.92	17.81	10.64	0.96	77990.40
12	7.30	5.99	41.79	0.85	18.58	9.84	1.00	84454.54
13	7.44	7.12	47.20	1.51	16.22	10.66	0.98	81027.33
14	9.10	8.42	47.97	1.22	16.95	10.48	0.95	83197.74
15	8.23	7.84	44.92	1.78	14.81	10.83	0.94	79587.34
16	4.85	3.78	49.67	2.43	13.58	11.20	0.98	72152.69
17	6.58	2.76	50.85	2.72	13.58	11.31	0.97	70889.27
18	4.91	7.28	56.04	1.43	15.55	11.31	0.94	70641.85
19	5.63	6.16	58.17	0.89	18.30	10.41	0.95	82343.40
20	8.90	9.64	40.22	1.27	16.84	10.70	0.97	79855.41
21	6.03	1.23	48.71	1.22	16.89	10.81	0.94	77428.00
22	7.05	3.84	38.50	1.41	16.49	10.36	0.94	80248.91
23	6.68	1.75	58.87	1.00	17.70	10.26	0.94	78462.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.14	6.83	50.15	1.42	16.44	10.73	0.95	79244.98
最大值	9.63	15.48	58.87	2.72	18.58	11.41	1.01	85435.46
發生時間	9	7	23	17	12	10		7
最小值	4.25	1.23	38.50	0.85	13.58	9.84	0.90	70641.85
發生時間	1	21	22	12	16	12		18
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	-0.05 %		0.01		0.00 %
全幅偏移(率)	-0.56 %	0.03 %	-0.50 %	0.03 %		0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								