

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月01日

| 項目      | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 10.66    | 3.85     | 58.05    | 2.39     | 16.81    | 12.34    | 1.46     | 68534.20  |
| 1       | 9.39     | 4.93     | 39.40    | 2.47     | 16.54    | 12.00    | 1.47     | 71342.57  |
| 2       | 9.57     | 4.04     | 54.58    | 2.52     | 17.08    | 12.26    | 1.46     | 68453.15  |
| 3       | 11.17    | 3.38     | 63.73    | 2.61     | 16.41    | 12.13    | 1.46     | 70622.03  |
| 4       | 9.87     | 3.84     | 59.57    | 2.74     | 16.04    | 12.32    | 1.46     | 68913.55  |
| 5       | 9.01     | 8.58     | 69.70    | 2.44     | 16.82    | 12.25    | 1.43     | 65578.18  |
| 6       | 9.52     | 5.35     | 47.58    | 2.26     | 17.03    | 11.70    | 1.43     | 72203.44  |
| 7       | 10.07    | 6.88     | 51.72    | 3.14     | 15.03    | 12.24    | 1.44     | 69880.38  |
| 8       | 7.22     | 7.54     | 62.10    | 2.99     | 15.88    | 12.75    | 1.45     | 63147.45  |
| 9       | 8.68     | 4.12     | 64.50    | 2.67     | 15.57    | 12.66    | 1.46     | 66123.42  |
| 10      | 1.06     | 5.32     | 55.13    | 2.36     | 16.05    | 13.11    | 1.49     | 62670.22  |
| 11      | 0.18     | 5.36     | 65.38    | 2.11     | 16.69    | 12.92    | 1.57     | 63671.57  |
| 12      | 7.20     | 6.46     | 44.90    | 2.22     | 16.63    | 11.64    | 1.49     | 73825.03  |
| 13      | 11.74    | 11.25    | 47.08    | 3.92     | 13.63    | 12.51    | 1.49     | 69473.67  |
| 14      | 9.32     | 2.37     | 57.96    | 3.29     | 15.01    | 12.25    | 1.49     | 70760.89  |
| 15      | 10.43    | 1.47     | 54.72    | 2.70     | 15.65    | 12.17    | 1.49     | 70600.29  |
| 16      | 8.11     | 4.42     | 53.02    | 2.63     | 15.63    | 12.16    | 1.49     | 71150.35  |
| 17      | 9.56     | 4.96     | 53.10    | 2.76     | 15.49    | 12.21    | 1.49     | 70260.51  |
| 18      | 7.33     | 3.46     | 65.19    | 1.91     | 17.26    | 11.93    | 1.49     | 71588.15  |
| 19      | 5.19     | 3.45     | 63.16    | 1.76     | 17.47    | 12.04    | 1.47     | 70783.26  |
| 20      | 8.23     | 3.59     | 63.18    | 1.68     | 18.05    | 11.50    | 1.47     | 74022.76  |
| 21      | 6.41     | 3.58     | 57.39    | 1.83     | 17.18    | 11.91    | 1.47     | 71768.77  |
| 22      | 7.55     | 3.50     | 56.74    | 1.99     | 17.11    | 11.89    | 1.46     | 72166.35  |
| 23      | 5.68     | 3.60     | 57.78    | 1.83     | 17.32    | 12.00    | 1.47     | 71162.26  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 8.05     | 4.80     | 56.90    | 2.47     | 16.35    | 12.20    | 1.47     | 69529.27  |
| 最大值     | 11.74    | 11.25    | 69.70    | 3.92     | 18.05    | 13.11    | 1.68     | 74022.76  |
| 發生時間    | 13       | 13       | 5        | 13       | 20       | 10       |          | 20        |
| 最小值     | 0.18     | 1.47     | 39.40    | 1.68     | 13.63    | 11.50    | 1.40     | 62670.22  |
| 發生時間    | 11       | 15       | 1        | 20       | 13       | 20       |          | 10        |
| 零點偏移(率) | -0.25 %  | 0.00 %   | -0.00 %  | 0.00 %   |          | -0.02    | 0.00     | 0.00 %    |
| 全幅偏移(率) | -0.32 %  | 0.21 %   | -0.30 %  | 0.03 %   |          | 0.07     | 0.00     | 0.40 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月01日

| 項目      | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 7.61     | 4.54     | 61.30    | 1.96     | 16.88    | 11.37    | 1.47     | 75903.46  |
| 1       | 9.48     | 4.99     | 49.20    | 1.26     | 19.89    | 10.34    | 1.48     | 84565.23  |
| 2       | 8.35     | 4.32     | 50.08    | 1.65     | 19.47    | 10.05    | 1.49     | 86404.31  |
| 3       | 10.19    | 3.88     | 47.31    | 2.07     | 18.33    | 10.37    | 1.49     | 85023.73  |
| 4       | 9.94     | 4.00     | 54.42    | 1.99     | 18.39    | 10.31    | 1.49     | 85137.65  |
| 5       | 9.26     | 3.87     | 55.28    | 1.87     | 17.84    | 10.62    | 1.48     | 83203.13  |
| 6       | 11.10    | 3.77     | 51.09    | 1.85     | 18.66    | 10.40    | 1.49     | 79143.47  |
| 7       | 9.20     | 4.62     | 57.14    | 1.64     | 18.45    | 10.36    | 1.50     | 85063.12  |
| 8       | 10.62    | 3.72     | 51.96    | 1.87     | 18.00    | 10.48    | 1.51     | 84851.17  |
| 9       | 9.15     | 5.45     | 54.01    | 1.82     | 18.17    | 10.38    | 1.51     | 84643.78  |
| 10      | 9.37     | 4.65     | 46.71    | 1.76     | 18.30    | 10.26    | 1.51     | 84363.37  |
| 11      | 7.49     | 6.49     | 51.12    | 2.08     | 16.08    | 10.74    | 1.50     | 82163.42  |
| 12      | 9.14     | 10.35    | 57.13    | 3.10     | 13.97    | 11.30    | 1.48     | 79120.33  |
| 13      | 9.60     | 10.35    | 54.25    | 3.37     | 13.50    | 11.46    | 1.47     | 75555.07  |
| 14      | 12.60    | 4.80     | 52.95    | 3.11     | 14.99    | 10.61    | 1.50     | 80309.59  |
| 15      | 7.83     | 5.93     | 49.67    | 2.25     | 15.72    | 10.33    | 1.50     | 81073.00  |
| 16      | 6.96     | 2.92     | 51.67    | 1.74     | 16.90    | 10.51    | 1.51     | 83890.69  |
| 17      | 0.20     | 3.59     | 55.90    | 1.13     | 17.39    | 10.76    | 1.51     | 83088.56  |
| 18      | 0.08     | 3.93     | 52.84    | 0.80     | 19.15    | 10.30    | 1.51     | 84590.23  |
| 19      | 0.12     | 4.39     | 51.47    | 1.20     | 17.95    | 10.76    | 1.51     | 82086.59  |
| 20      | 0.58     | 4.52     | 52.59    | 1.24     | 18.03    | 10.72    | 1.51     | 82437.27  |
| 21      | 1.38     | 3.86     | 51.64    | 0.93     | 19.40    | 10.13    | 1.52     | 86250.25  |
| 22      | 2.47     | 3.81     | 60.58    | 0.88     | 19.42    | 10.50    | 1.51     | 84479.06  |
| 23      | 2.89     | 3.86     | 45.54    | 0.81     | 19.88    | 10.13    | 1.51     | 86135.24  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 6.90     | 4.86     | 52.74    | 1.77     | 17.70    | 10.55    | 1.50     | 82895.07  |
| 最大值     | 12.60    | 10.35    | 61.30    | 3.37     | 19.89    | 11.46    | 1.54     | 86404.31  |
| 發生時間    | 14       | 12       | 0        | 13       | 1        | 13       |          | 2         |
| 最小值     | 0.08     | 2.92     | 45.54    | 0.80     | 13.50    | 10.05    | 1.45     | 75555.07  |
| 發生時間    | 18       | 16       | 23       | 18       | 13       | 2        |          | 13        |
| 零點偏移(率) | -0.23 %  | -0.06 %  | -0.07 %  | -0.01 %  |          | -0.09    | 0.00     | 0.00 %    |
| 全幅偏移(率) | 2.12 %   | 0.63 %   | -0.13 %  | 0.35 %   |          | -0.24    | 0.00     | 0.20 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月01日

| 項目      | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 10.88    | 4.66     | 59.67    | 1.57     | 17.56    | 10.54    | 1.43     | 87038.61  |
| 1       | 11.65    | 3.60     | 60.62    | 1.61     | 17.29    | 10.73    | 1.43     | 86959.82  |
| 2       | 10.56    | 5.16     | 57.94    | 1.42     | 17.81    | 10.98    | 1.43     | 85844.36  |
| 3       | 9.71     | 6.40     | 59.17    | 1.74     | 17.38    | 10.55    | 1.43     | 90108.76  |
| 4       | 9.29     | 4.98     | 56.25    | 1.51     | 16.60    | 10.94    | 1.43     | 86030.64  |
| 5       | 9.68     | 9.80     | 53.06    | 2.12     | 18.18    | 10.15    | 1.43     | 89165.85  |
| 6       | 9.34     | 3.16     | 51.93    | 1.57     | 16.22    | 10.87    | 1.43     | 84305.29  |
| 7       | 4.58     | 8.22     | 62.48    | 1.66     | 16.07    | 10.84    | 1.42     | 84478.84  |
| 8       | 10.75    | 5.27     | 55.26    | 1.73     | 17.13    | 10.57    | 1.43     | 87255.88  |
| 9       | 8.77     | 5.53     | 55.60    | 1.62     | 17.50    | 10.59    | 1.43     | 86553.33  |
| 10      | 9.95     | 10.50    | 49.13    | 1.79     | 17.24    | 10.31    | 1.43     | 86534.86  |
| 11      | 7.03     | 2.21     | 56.70    | 1.71     | 15.64    | 10.82    | 1.43     | 85410.58  |
| 12      | 6.98     | 5.72     | 58.02    | 2.54     | 13.89    | 11.41    | 1.43     | 81918.02  |
| 13      | 9.88     | 9.25     | 57.57    | 3.55     | 13.19    | 11.38    | 1.43     | 79445.48  |
| 14      | 9.37     | 7.63     | 53.05    | 4.19     | 13.64    | 11.35    | 1.42     | 77697.42  |
| 15      | 11.48    | 5.11     | 53.53    | 3.26     | 14.53    | 10.75    | 1.41     | 78390.49  |
| 16      | 6.61     | 2.67     | 55.08    | 2.08     | 16.31    | 10.61    | 1.41     | 81505.31  |
| 17      | 8.84     | 3.28     | 52.83    | 1.70     | 16.59    | 10.65    | 1.42     | 82358.80  |
| 18      | 6.81     | 2.59     | 60.83    | 1.43     | 18.34    | 10.25    | 1.43     | 84585.42  |
| 19      | 7.64     | 2.29     | 53.04    | 1.34     | 17.90    | 10.63    | 1.43     | 85386.89  |
| 20      | 6.92     | 3.27     | 54.83    | 1.40     | 17.97    | 10.40    | 1.43     | 87989.54  |
| 21      | 8.51     | 2.67     | 59.96    | 1.47     | 18.10    | 10.61    | 1.43     | 86753.05  |
| 22      | 8.44     | 3.25     | 58.10    | 1.54     | 18.42    | 10.53    | 1.43     | 87502.44  |
| 23      | 9.11     | 4.72     | 54.84    | 1.51     | 18.34    | 10.46    | 1.44     | 88355.12  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 8.87     | 5.08     | 56.23    | 1.92     | 16.74    | 10.71    | 1.43     | 85065.62  |
| 最大值     | 11.65    | 10.50    | 62.48    | 4.19     | 18.42    | 11.41    | 1.45     | 90108.76  |
| 發生時間    | 1        | 10       | 7        | 14       | 22       | 12       |          | 3         |
| 最小值     | 4.58     | 2.21     | 49.13    | 1.34     | 13.19    | 10.15    | 1.39     | 77697.42  |
| 發生時間    | 7        | 11       | 10       | 19       | 13       | 5        |          | 14        |
| 零點偏移(率) | -0.01 %  | -0.00 %  | -0.04 %  | -0.01 %  |          | -0.01    | 0.00     | 0.00 %    |
| 全幅偏移(率) | 0.47 %   | 0.67 %   | -0.17 %  | 0.05 %   |          | 0.13     | 0.00     | 0.20 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |