

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月08日

報表日期: 115年08月08日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.06	11.62	57.21	1.76	19.49	11.05	1.18	73330.95
1	10.89	11.67	49.47	1.83	18.73	11.17	1.16	73320.75
2	8.63	11.74	57.26	1.85	18.30	11.32	1.18	73025.50
3	10.38	11.91	47.71	1.87	17.00	11.61	1.18	72027.82
4	8.58	11.94	50.31	1.87	16.77	11.69	1.18	71228.76
5	6.83	11.51	53.92	1.43	19.06	11.07	1.18	75271.99
6	9.62	12.61	53.62	1.61	17.82	11.16	1.18	74188.26
7	9.25	12.89	54.93	1.96	17.17	11.39	1.18	72517.68
8	11.08	13.27	50.22	2.23	16.78	11.50	1.18	71980.83
9	7.40	13.47	54.23	1.84	15.91	11.94	1.18	68966.22
10	9.65	13.58	51.00	2.19	15.81	11.94	1.18	69307.56
11	13.36	13.71	57.69	2.83	15.06	12.00	1.17	69406.09
12	13.67	12.31	58.92	2.46	15.45	11.98	1.17	69564.44
13	7.17	12.36	60.45	2.37	15.98	12.05	1.18	69137.59
14	9.09	12.06	54.44	3.12	15.28	11.92	1.18	70249.78
15	10.75	11.93	59.48	2.73	16.90	11.67	1.17	70841.43
16	7.81	11.99	52.90	3.54	15.76	11.48	1.15	73226.08
17	5.45	13.68	58.34	3.40	14.58	12.32	1.15	68099.30
18	9.11	12.20	61.35	2.72	15.85	11.97	1.17	69594.41
19	9.94	11.83	62.18	2.66	17.01	11.46	1.18	72095.81
20	10.38	11.84	60.21	2.74	16.90	11.55	1.18	71352.33
21	8.44	11.85	60.27	2.53	17.01	11.57	1.17	70952.82
22	8.93	12.31	60.59	2.10	18.07	11.31	1.16	72536.56
23	10.18	12.09	51.17	2.52	17.80	11.09	1.15	73918.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.36	12.35	55.74	2.34	16.85	11.59	1.17	71505.89
最 大 值	13.67	13.71	62.18	3.54	19.49	12.32	1.18	75271.99
發生時間	12	11	19	16	0	17		5
最 小 值	5.45	11.51	47.71	1.43	14.58	11.05	1.13	68099.30
發生時間	17	5	3	5	17	0		17
零點偏移(率)	-0.07 %	-0.02 %	-0.01 %	0.00 %		-0.04	-0.01	0.20 %
全幅偏移(率)	-0.23 %	0.14 %	0.09 %	-0.32 %		-0.24	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月08日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.50	11.64	54.02	1.90	18.91	9.92	1.36	75396.05
1	3.95	11.70	51.76	1.24	19.27	9.93	1.32	74303.01
2	7.39	12.02	52.07	1.40	17.64	10.18	1.33	74400.30
3	3.73	11.83	55.63	1.19	17.60	10.43	1.36	71505.64
4	4.55	11.91	49.70	1.45	16.80	10.38	1.35	72500.37
5	4.16	12.69	58.18	1.40	16.46	10.82	1.37	74537.33
6	8.89	13.56	56.10	1.58	16.79	10.46	1.36	74867.16
7	3.69	13.23	56.58	1.56	15.92	10.82	1.32	75936.11
8	7.96	13.56	58.57	1.61	16.22	10.56	1.33	75564.54
9	5.87	13.77	54.50	1.67	16.17	10.45	1.33	74598.25
10	4.20	14.21	52.86	2.36	16.64	10.11	1.30	74778.70
11	6.07	12.09	60.59	1.94	17.87	10.02	1.31	74438.82
12	3.48	12.26	54.34	2.23	16.38	10.44	1.30	72013.66
13	8.02	11.96	61.47	2.48	17.05	10.34	1.31	72669.66
14	4.89	13.61	50.44	4.34	18.31	9.54	1.30	73514.66
15	2.42	10.79	27.86	1.63	19.12	8.44	1.29	69238.37
16	3.81	12.04	51.10	1.84	18.25	10.23	1.32	72629.96
17	3.35	11.44	47.59	2.04	17.44	9.69	1.30	73378.41
18	9.69	12.13	52.99	2.53	17.51	10.02	1.31	74192.74
19	5.67	11.49	61.52	2.24	19.99	9.70	1.32	76253.44
20	2.70	11.75	54.74	2.01	19.46	9.79	1.35	73607.72
21	5.42	15.18	40.71	4.50	21.01	8.70	1.34	74623.16
22	4.28	3.69	28.68	0.17	19.78	8.47	1.31	75006.12
23	6.69	9.14	37.12	1.55	19.30	9.14	1.30	73675.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.39	11.99	51.21	1.95	17.91	9.94	1.32	73901.25
最 大 值	9.69	15.18	61.52	4.50	21.01	10.82	1.38	76253.44
發生時間	18	21	19	21	21	5		19
最 小 值	2.42	3.69	27.86	0.17	15.92	8.44	1.27	69238.37
發生時間	15	22	15	22	7	15		15
零點偏移(率)	-0.06 %	-0.03 %	-0.10 %	-0.01 %		-0.06	-0.01	0.10 %
全幅偏移(率)	0.32 %	0.56 %	0.17 %	-0.26 %		-0.05	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								