

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.91	5.01	67.42	2.83	16.30	11.69	1.06	74477.80
1	9.72	5.18	50.55	3.06	17.25	11.33	1.07	79756.25
2	9.22	6.03	52.00	3.15	18.23	11.29	1.07	78932.80
3	6.61	6.29	64.93	2.28	18.46	10.36	1.10	82836.27
4	6.00	5.41	67.96	2.69	15.83	11.74	1.09	77371.60
5	5.55	9.15	58.01	3.05	16.10	11.86	1.06	78514.19
6	7.65	5.08	57.24	1.94	18.05	11.17	1.05	80618.85
7	10.25	5.11	61.37	3.01	16.40	11.55	1.06	77443.02
8	10.60	4.65	53.91	2.30	17.34	11.18	1.05	78445.33
9	9.29	5.15	67.65	1.67	18.09	11.39	1.05	75450.37
10	9.67	5.10	46.00	2.28	17.13	11.39	1.08	74856.59
11	9.94	5.67	60.02	2.34	16.70	11.89	1.05	73545.27
12	8.68	5.84	58.39	2.19	16.66	11.78	1.05	74547.41
13	8.40	8.06	48.62	2.74	15.28	11.92	1.05	70595.26
14	12.07	8.90	69.65	2.88	15.82	12.35	1.05	68982.69
15	14.00	8.23	54.71	4.41	15.67	11.70	1.05	76083.64
16	13.59	9.58	49.64	7.19	14.96	12.18	1.03	69908.95
17	6.21	3.68	58.15	5.94	15.66	12.21	1.04	71107.97
18	7.75	3.89	64.96	2.02	16.47	12.57	1.07	71637.80
19	9.74	5.57	52.08	2.04	16.78	12.02	1.05	75761.50
20	4.42	11.31	57.59	2.36	15.81	12.63	1.07	71590.03
21	9.85	7.78	57.61	1.47	17.72	11.49	1.05	78986.72
22	7.61	10.27	55.21	2.25	15.94	11.93	1.05	76728.85
23	7.75	9.48	55.87	2.87	15.21	12.19	1.05	74087.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.73	6.68	57.90	2.87	16.58	11.74	1.06	75511.12
最大值	14.00	11.31	69.65	7.19	18.46	12.63	1.15	82836.27
發生時間	15	20	14	16	3	20		3
最小值	4.42	3.68	46.00	1.47	14.96	10.36	1.01	68982.69
發生時間	20	17	10	21	16	3		14
零點偏移(率)	-0.82 %	-0.01 %	-0.19 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.98 %	0.08 %	0.03 %		-0.18		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.52	2.59	64.47	2.25	16.77	10.30	1.10	82981.05
1	7.48	6.37	45.25	2.49	17.34	9.98	1.10	80630.53
2	7.05	8.37	46.40	3.05	17.38	10.37	1.10	83281.49
3	6.71	11.32	59.15	2.36	18.52	9.78	1.10	86247.08
4	3.58	3.28	54.54	2.73	15.07	10.97	1.10	76100.92
5	0.41	7.35	50.00	1.74	20.09	9.82	1.10	85127.32
6	2.42	6.02	49.71	1.61	18.66	9.85	1.09	92200.10
7	7.23	14.58	52.88	1.91	19.00	9.68	1.24	84957.02
8	11.84	8.78	61.62	1.91	18.43	9.81	1.22	86216.12
9	8.07	10.27	44.03	1.87	18.72	9.87	1.13	84301.71
10	3.74	13.70	48.11	1.68	19.26	9.39	1.11	84924.84
11	5.23	8.63	55.05	1.69	18.43	9.94	1.11	81656.17
12	7.68	7.98	66.58	1.81	18.26	10.03	1.11	83978.64
13	9.77	9.42	68.71	2.35	17.49	10.19	1.12	83230.69
14	9.92	9.36	52.70	3.05	15.53	10.77	1.09	79729.06
15	9.09	6.88	66.26	3.19	14.99	11.17	1.08	78476.57
16	8.66	2.89	55.76	2.62	15.59	11.52	1.09	75862.84
17	16.29	3.84	55.53	7.59	16.26	10.88	1.10	81911.77
18	8.72	3.12	58.33	10.02	14.99	11.68	1.08	78249.84
19	6.35	4.13	57.72	3.16	17.13	10.85	1.08	82527.60
20	5.27	7.12	57.37	1.76	17.13	11.31	1.08	78240.00
21	8.63	8.65	59.07	1.86	18.10	10.35	1.07	84800.33
22	8.02	9.28	48.88	2.96	15.88	10.77	1.07	82506.80
23	5.65	5.55	62.52	1.79	17.73	10.41	1.09	83146.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.39	7.48	55.86	2.81	17.36	10.40	1.11	82553.56
最大值	16.29	14.58	68.71	10.02	20.09	11.68	1.42	92200.10
發生時間	17	7	13	18	5	18		6
最小值	0.41	2.59	44.03	1.61	14.99	9.39	1.07	75862.84
發生時間	5	0	9	6	15	10		16
零點偏移(率)	-0.39 %	0.00 %	-0.13 %	-0.09 %		0.01		0.00 %
全幅偏移(率)	0.00 %	1.20 %	0.86 %	0.26 %		-0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.19	6.15	57.19	2.69	15.33	10.93	1.03	76841.68
1	8.32	5.39	57.37	2.56	16.14	10.91	1.04	79724.57
2	8.75	7.27	53.75	2.88	15.91	11.26	1.03	74677.51
3	10.54	4.01	65.32	3.40	15.75	10.90	1.01	76860.64
4	5.92	9.61	57.31	3.03	15.21	11.03	1.00	74275.28
5	8.02	6.73	52.98	2.82	17.10	9.67	1.01	82276.50
6	8.27	4.37	49.25	3.06	15.51	10.54	1.01	75092.29
7	12.30	7.21	60.73	3.07	14.21	11.39	1.01	74678.98
8	6.72	13.02	65.87	2.04	17.66	10.37	1.01	73321.22
9	9.80	5.78	58.04	2.34	18.20	9.72	1.02	78085.25
10	10.49	8.39	42.58	2.91	18.14	9.21	1.02	77867.71
11	10.81	4.61	60.62	2.87	17.05	9.52	1.06	81088.79
12	10.95	7.38	49.63	2.41	14.96	10.76	1.03	76568.23
13	10.20	9.30	61.92	1.99	16.07	10.97	1.02	76974.34
14	15.02	4.48	58.27	4.27	13.94	11.38	1.01	70739.91
15	14.26	9.06	55.95	8.52	12.08	12.56	1.01	70664.35
16	10.31	5.54	56.94	4.30	14.71	12.32	0.99	70007.61
17	10.14	2.81	49.34	3.19	15.13	11.21	0.99	76855.79
18	8.79	2.09	61.80	2.50	14.61	11.48	1.00	74976.18
19	9.12	3.96	58.45	2.46	14.25	11.58	1.02	73605.13
20	3.30	5.53	58.17	2.59	13.92	12.13	1.00	70324.54
21	1.82	4.79	66.49	1.76	15.82	11.74	0.99	72732.52
22	3.57	5.46	44.31	1.34	16.91	10.46	1.00	80515.50
23	10.09	5.74	51.13	2.44	15.61	10.67	0.99	79417.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.95	6.20	56.39	2.98	15.59	10.95	1.01	75757.17
最大值	15.02	13.02	66.49	8.52	18.20	12.56	1.12	82276.50
發生時間	14	8	21	15	9	15		5
最小值	1.82	2.09	42.58	1.34	12.08	9.21	0.97	70007.61
發生時間	21	18	10	22	15	10		16
零點偏移(率)	0.00 %	0.00 %	-0.10 %	-0.07 %		-0.02		0.00 %
全幅偏移(率)	-0.08 %	0.75 %	-0.79 %	0.24 %		0.06		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								