

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.53	13.65	43.14	2.45	18.42	10.70	1.26	76758.35
1	16.93	13.84	52.60	2.89	17.91	11.09	1.27	74601.77
2	10.07	12.82	54.01	1.50	19.23	10.94	1.25	75115.08
3	7.10	12.63	55.42	1.52	17.19	11.17	1.25	75436.64
4	2.36	12.80	59.51	0.90	18.57	10.93	1.25	76352.90
5	3.74	13.70	48.56	2.76	17.71	10.82	1.19	79644.28
6	14.51	13.42	59.26	2.17	18.33	11.04	1.19	75532.07
7	15.91	12.23	48.93	3.07	16.53	11.45	1.19	74099.24
8	2.62	12.16	51.90	1.31	16.87	11.56	1.21	72729.37
9	6.90	12.33	49.30	0.90	18.19	10.97	1.21	76038.39
10	7.35	12.23	44.97	1.19	17.58	11.07	1.19	74031.43
11	6.26	12.00	41.66	0.99	17.79	11.08	1.20	74268.81
12	7.53	12.65	42.90	1.34	16.84	11.27	1.18	74474.94
13	6.90	12.45	50.38	1.54	15.89	11.53	1.18	72785.62
14	6.68	12.31	53.31	0.91	17.08	11.46	1.18	73044.61
15	6.73	12.61	45.88	1.77	17.84	10.85	1.18	76548.30
16	6.76	12.94	47.96	2.27	17.31	11.14	1.19	75029.25
17	12.80	12.85	48.35	3.19	16.24	11.14	1.18	75533.17
18	14.11	13.27	39.79	4.05	18.57	10.69	1.18	77050.74
19	9.79	12.12	48.13	2.40	17.20	11.12	1.19	74550.77
20	9.82	13.52	43.58	2.46	17.27	11.19	1.19	74155.65
21	8.75	12.50	50.73	2.75	17.03	11.29	1.21	74027.61
22	6.38	12.59	54.32	3.42	16.70	11.42	1.21	72332.45
23	6.22	12.35	53.71	1.98	17.26	11.59	1.19	70830.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.82	12.75	49.51	2.07	17.48	11.15	1.20	74790.50
最大值	16.93	13.84	59.51	4.05	19.23	11.59	1.27	79644.28
發生時間	1	1	4	18	2	23		5
最小值	2.36	12.00	39.79	0.90	15.89	10.69	1.18	70830.47
發生時間	4	11	18	4	13	18		23
零點偏移(率)	-0.01 %	-0.00 %	-0.03 %	-0.03 %		-0.12	-0.01	0.20 %
全幅偏移(率)	2.00 %	0.18 %	0.12 %	0.23 %		-0.13	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.90	11.70	53.28	1.13	18.59	9.96	1.02	80553.90
1	9.03	11.82	54.27	1.23	17.82	10.34	1.02	79853.83
2	2.68	12.22	60.92	1.50	18.84	10.34	1.02	81080.19
3	5.46	12.35	62.89	1.93	15.83	11.17	1.02	79104.50
4	6.81	12.49	53.32	1.90	16.38	11.12	1.02	77333.53
5	10.78	12.46	54.55	2.40	16.63	10.82	1.02	80159.94
6	10.42	13.26	55.90	1.84	16.37	11.23	1.01	81234.97
7	14.35	11.40	55.16	2.52	16.19	11.06	1.01	78060.46
8	8.54	12.44	47.36	2.26	16.36	10.76	0.98	79286.56
9	9.02	11.92	55.94	2.02	16.92	10.65	0.99	79777.89
10	8.61	12.51	42.40	2.62	15.82	10.88	0.99	76802.83
11	10.64	12.08	53.99	1.98	16.73	10.76	1.01	77428.17
12	8.81	11.94	45.82	2.15	15.95	10.78	1.00	76921.73
13	11.35	12.45	49.33	2.70	15.36	11.11	0.99	74819.91
14	11.56	13.38	46.66	3.08	15.77	10.69	0.99	74911.88
15	10.18	12.26	51.01	3.29	16.06	10.90	1.00	78634.03
16	10.88	11.70	58.06	2.76	17.79	10.39	1.00	81196.80
17	10.90	11.93	48.85	2.19	18.28	10.41	1.00	82533.01
18	7.79	12.02	47.69	2.40	16.34	10.65	0.99	80449.64
19	11.32	13.10	54.92	2.48	15.30	11.04	1.00	77723.39
20	10.63	12.60	49.72	3.02	16.06	10.80	0.99	80108.99
21	11.31	12.03	58.88	2.50	16.17	10.85	1.01	79761.41
22	8.84	12.28	62.17	2.30	16.01	11.09	1.02	79157.40
23	10.64	12.09	61.33	2.26	17.76	10.52	1.01	82235.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.60	12.27	53.52	2.27	16.64	10.76	1.00	79130.45
最大值	14.35	13.38	62.89	3.29	18.84	11.23	1.06	82533.01
發生時間	7	14	3	15	2	6		17
最小值	2.68	11.40	42.40	1.13	15.30	9.96	0.97	74819.91
發生時間	2	7	10	0	19	0		13
零點偏移(率)	-0.11 %	-0.01 %	-0.03 %	-0.00 %		-0.10	-0.01	0.00 %
全幅偏移(率)	2.33 %	-0.13 %	0.75 %	0.02 %		-0.06	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.56	11.27	50.07	3.08	19.18	9.40	1.34	72146.68
1	4.20	11.62	41.74	2.89	19.60	9.76	1.35	72303.27
2	4.20	11.52	41.37	2.53	21.05	9.52	1.36	72661.69
3	3.25	11.56	47.60	2.89	18.30	9.80	1.33	73663.41
4	5.53	11.78	55.48	3.76	16.01	10.50	1.31	72213.92
5	5.95	13.22	51.39	4.17	16.52	10.16	1.31	72218.14
6	3.60	11.79	56.65	3.07	17.28	10.17	1.31	73039.06
7	1.98	10.39	49.80	2.74	18.18	9.32	1.33	78453.92
8	5.65	11.21	52.16	2.24	17.73	9.97	1.33	73730.46
9	8.71	12.30	54.95	2.24	19.16	9.59	1.35	78052.00
10	7.84	11.67	61.37	0.66	18.03	10.41	1.33	75840.74
11	6.87	11.77	53.30	0.63	17.23	10.51	1.31	75116.17
12	6.15	12.09	58.93	1.83	14.79	10.89	1.34	71070.13
13	8.97	11.94	56.72	2.09	14.43	10.62	1.31	71974.39
14	8.66	11.81	57.34	1.87	15.76	10.52	1.31	72722.86
15	8.91	11.69	56.75	2.33	16.52	10.39	1.34	73108.65
16	10.17	11.64	50.66	3.38	16.92	10.03	1.34	75795.52
17	6.29	11.37	52.79	3.08	17.11	9.86	1.31	75087.28
18	9.23	12.19	45.60	2.53	16.75	9.57	1.31	73457.32
19	10.45	11.51	42.96	3.77	16.83	9.25	1.32	72085.29
20	8.77	12.06	42.51	1.88	16.51	8.96	1.31	69616.82
21	9.47	11.69	38.21	1.81	17.65	8.85	1.27	69482.86
22	8.67	11.01	38.74	1.92	17.93	8.92	1.30	69542.35
23	9.02	12.52	47.58	2.22	19.30	8.48	1.31	71903.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.96	11.73	50.19	2.48	17.45	9.81	1.32	73136.95
最大值	10.45	13.22	61.37	4.17	21.05	10.89	1.36	78453.92
發生時間	19	5	10	5	2	12		7
最小值	1.98	10.39	38.21	0.63	14.43	8.48	1.27	69482.86
發生時間	7	7	21	11	13	23		21
零點偏移(率)	-0.06 %	0.00 %	-0.08 %	0.00 %		-0.12	-0.01	0.00 %
全幅偏移(率)	0.88 %	0.02 %	-0.22 %	0.16 %		0.20	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								