

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.87	7.64	51.13	4.24	13.13	12.60	1.46	70457.50
1	9.39	1.54	64.09	2.96	15.55	12.05	1.46	73026.88
2	9.96	2.18	46.10	4.56	12.58	12.62	1.46	70419.03
3	11.02	3.45	60.11	4.70	12.74	12.56	1.46	71134.10
4	8.79	3.92	69.51	3.75	14.15	12.57	1.47	70444.59
5	7.92	4.88	65.23	3.85	13.24	12.64	1.46	77257.00
6	7.34	5.07	69.23	3.43	14.59	12.99	1.48	66748.29
7	7.41	4.08	52.61	3.22	14.56	12.12	1.46	74047.57
8	9.60	5.55	51.71	3.85	13.90	12.40	1.46	72088.85
9	8.58	5.27	63.59	3.35	14.60	12.20	1.46	73039.91
10	10.23	6.49	52.06	4.07	12.94	12.52	1.45	71372.93
11	9.03	6.95	56.11	3.83	13.49	12.48	1.46	71370.23
12	9.48	2.97	70.90	3.37	14.37	12.38	1.46	71338.65
13	10.22	5.80	45.74	4.28	12.69	12.60	1.43	70206.79
14	10.68	7.26	49.35	4.93	11.87	12.89	1.40	68050.91
15	9.78	5.08	57.74	4.58	12.70	12.73	1.40	69410.25
16	9.53	9.34	48.16	6.54	12.39	12.68	1.41	70579.86
17	8.91	10.57	52.70	5.38	12.29	12.78	1.43	69448.45
18	5.20	5.90	63.53	3.34	14.22	12.35	1.46	71605.29
19	6.94	7.05	53.94	3.92	13.25	12.43	1.46	71452.42
20	10.43	13.78	54.07	4.72	12.22	12.61	1.46	70819.71
21	8.61	3.30	61.95	3.56	13.77	12.32	1.46	72110.62
22	8.65	5.24	53.89	3.93	13.37	12.60	1.43	70092.41
23	1.61	4.70	66.21	2.71	15.07	12.41	1.46	70554.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.67	5.75	57.49	4.04	13.49	12.52	1.45	71128.19
最大值	11.02	13.78	70.90	6.54	15.55	12.99	1.51	77257.00
發生時間	3	20	12	16	1	6		5
最小值	1.61	1.54	45.74	2.71	11.87	12.05	1.39	66748.29
發生時間	23	1	13	23	14	1		6
零點偏移(率)	-0.01 %	0.00 %	0.00 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	2.46 %	0.25 %	-0.04 %	-0.08 %		0.39	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.57	3.98	53.90	2.28	16.79	10.61	1.43	82128.17
1	9.24	4.92	54.69	2.24	16.39	10.84	1.43	80369.89
2	11.90	5.53	57.68	2.84	14.13	10.45	1.43	78342.14
3	11.70	6.47	54.32	2.44	15.94	10.16	1.40	79924.89
4	8.81	5.11	60.40	1.88	17.29	10.23	1.39	79319.48
5	7.63	6.12	45.95	1.85	17.18	10.05	1.40	80809.66
6	2.67	5.16	65.39	1.48	17.14	11.21	1.42	75207.63
7	6.83	4.39	54.02	1.60	17.35	10.41	1.44	83206.52
8	10.38	5.79	66.78	2.09	16.45	10.74	1.43	85072.20
9	11.59	5.59	59.41	2.37	15.82	10.80	1.41	85921.66
10	10.20	4.94	53.92	2.38	14.44	11.01	1.39	83285.04
11	9.29	3.71	64.67	2.20	14.61	11.16	1.38	82314.57
12	10.34	3.49	57.13	2.38	14.66	11.06	1.38	81234.79
13	10.23	3.13	58.84	2.34	15.02	11.12	1.40	83009.08
14	10.47	3.27	57.32	2.34	15.29	10.97	1.40	80161.70
15	10.48	4.65	58.39	2.33	15.37	10.97	1.40	82217.61
16	10.64	5.56	51.28	2.50	14.96	10.89	1.39	85089.07
17	12.52	9.65	51.39	7.73	15.08	10.76	1.38	82602.27
18	8.07	5.86	66.18	2.88	16.13	10.84	1.38	82331.11
19	10.06	5.56	54.15	2.28	15.07	10.89	1.39	85350.68
20	10.63	6.29	56.99	2.29	15.19	10.82	1.39	84074.62
21	9.21	5.44	59.81	2.08	15.48	11.01	1.38	82014.69
22	7.12	5.88	63.78	1.55	17.13	11.11	1.40	80699.40
23	3.38	6.31	54.62	1.45	17.02	11.40	1.39	79406.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.25	5.28	57.54	2.41	15.83	10.81	1.40	81837.24
最大值	12.52	9.65	66.78	7.73	17.35	11.40	1.44	85921.66
發生時間	17	17	8	17	7	23		9
最小值	2.67	3.13	45.95	1.45	14.13	10.05	1.38	75207.63
發生時間	6	13	5	23	2	5		6
零點偏移(率)	-0.01 %	0.00 %	-0.09 %	-0.02 %		-0.03	0.00	0.00 %
全幅偏移(率)	0.24 %	-0.41 %	-0.01 %	0.13 %		0.18	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.58	5.26	61.10	2.24	14.71	11.11	1.68	82609.67
1	5.91	7.75	57.36	2.06	15.42	10.94	1.68	82371.89
2	11.22	9.70	58.92	3.23	12.79	11.16	1.69	82079.76
3	8.75	2.63	64.81	3.13	13.26	11.69	1.68	76830.52
4	7.65	1.57	64.19	2.01	15.37	11.02	1.68	81500.27
5	2.68	2.07	68.72	1.84	15.37	11.79	1.72	76181.72
6	2.28	2.65	55.99	1.56	16.13	10.74	1.72	83190.51
7	3.56	5.36	57.85	1.34	16.06	10.25	1.74	79274.61
8	4.06	8.14	57.07	1.88	14.80	10.71	1.75	82880.12
9	9.26	9.57	54.47	2.40	14.27	10.77	1.72	84163.90
10	10.08	5.87	57.74	2.00	14.60	10.99	1.72	82094.09
11	9.14	3.06	57.11	1.94	14.94	10.75	1.72	80230.63
12	7.36	3.19	61.43	2.29	13.76	11.18	1.73	79091.14
13	4.58	3.17	60.45	1.61	14.96	11.07	1.72	80624.48
14	3.27	3.31	62.45	1.99	14.13	11.34	1.70	79073.76
15	2.62	6.83	60.92	2.12	13.93	11.22	1.70	78897.64
16	4.23	5.22	56.89	2.64	13.61	11.02	1.70	79604.08
17	6.62	5.95	61.57	3.86	13.78	11.18	1.71	80472.26
18	5.63	5.30	61.59	1.75	15.50	10.92	1.73	82459.51
19	9.40	6.26	60.23	1.96	15.02	10.99	1.75	82608.54
20	11.77	5.91	65.62	2.56	13.51	11.24	1.75	81476.65
21	8.11	10.10	57.44	2.28	14.14	11.11	1.72	82882.78
22	5.67	4.88	56.36	2.26	14.39	11.66	1.70	73894.76
23	3.77	3.25	64.72	1.23	16.65	10.68	1.74	84426.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.38	5.29	60.21	2.17	14.63	11.06	1.71	80788.33
最大值	11.77	10.10	68.72	3.86	16.65	11.79	1.76	84426.58
發生時間	20	21	5	17	23	5		23
最小值	2.28	1.57	54.47	1.23	12.79	10.25	1.65	73894.76
發生時間	6	4	9	23	2	7		22
零點偏移(率)	-0.04 %	0.00 %	-0.15 %	-0.05 %		0.01	0.00	0.00 %
全幅偏移(率)	1.79 %	-0.34 %	-0.51 %	0.09 %		0.22	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								