

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.14	5.61	49.26	0.95	19.27	11.02	1.07	75601.46
1	5.25	5.12	51.20	1.09	20.08	10.53	1.07	78323.95
2	3.02	7.41	60.91	1.05	18.59	11.13	1.08	75222.22
3	3.27	7.24	48.57	1.21	17.97	10.82	1.08	77608.02
4	4.03	7.57	55.69	1.44	17.32	11.30	1.08	73751.07
5	6.39	8.95	48.73	1.44	18.12	10.95	1.07	78883.06
6	9.02	7.75	55.14	1.46	17.52	11.24	1.07	74125.18
7	7.39	7.58	49.01	1.34	17.05	11.08	1.09	75402.62
8	9.27	6.60	55.58	1.51	16.78	11.59	1.10	74242.40
9	5.22	6.71	53.48	0.92	18.06	11.43	1.11	76746.11
10	9.79	7.55	41.92	2.30	16.15	11.34	1.08	78912.66
11	3.43	6.56	55.54	1.40	16.63	11.92	1.09	74091.48
12	3.91	6.78	56.22	1.04	17.00	11.63	1.10	76534.15
13	7.16	6.94	55.13	1.10	17.44	11.38	1.10	77553.86
14	7.63	6.98	46.68	1.76	16.18	11.65	1.11	76263.53
15	3.62	7.70	53.38	1.94	15.44	12.17	1.08	72516.54
16	2.16	7.70	56.28	1.09	16.80	11.77	1.07	74916.23
17	1.73	7.19	46.84	0.49	18.73	10.97	1.10	78592.27
18	0.23	8.72	44.29	0.71	18.39	11.46	1.11	73916.68
19	4.47	7.20	43.54	0.93	19.46	10.61	1.12	79478.74
20	9.51	7.89	61.22	1.54	18.08	10.90	1.11	78207.60
21	9.14	7.66	55.08	1.86	17.57	10.97	1.10	78735.24
22	8.92	7.02	58.15	1.47	17.49	11.16	1.10	76508.45
23	9.10	6.89	60.29	1.40	17.77	11.27	1.10	75611.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.66	7.22	52.59	1.31	17.66	11.26	1.09	76322.70
最大值	9.79	8.95	61.22	2.30	20.08	12.17	1.14	79478.74
發生時間	10	5	20	10	1	15		19
最小值	0.23	5.12	41.92	0.49	15.44	10.53	1.06	72516.54
發生時間	18	1	10	17	15	1		15
零點偏移(率)	0.00 %	0.00 %	-0.08 %	0.00 %		0.03		0.00 %
全幅偏移(率)	0.02 %	-0.17 %	0.13 %	0.24 %		0.30		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.91	13.02	49.14	1.77	22.68	8.63	1.09	92924.87
1	4.40	6.79	48.89	2.80	18.24	9.87	1.09	88372.10
2	8.38	6.10	51.59	2.93	16.44	10.40	1.10	85695.61
3	8.44	2.04	51.73	2.29	17.33	10.29	1.10	85655.58
4	9.05	3.15	56.26	2.43	16.45	10.42	1.09	86091.77
5	8.92	3.29	55.52	2.45	16.28	10.34	1.10	86796.45
6	9.76	5.02	51.60	2.21	17.10	10.05	1.07	84804.09
7	10.03	2.99	53.71	2.32	17.33	10.15	1.08	86507.70
8	9.08	2.83	64.59	1.75	17.88	10.04	1.07	86789.58
9	9.14	3.16	51.00	1.88	17.33	10.19	1.05	86533.73
10	8.02	4.37	60.00	1.72	16.39	10.45	1.07	85188.58
11	7.72	7.10	55.43	1.82	16.02	10.69	1.09	84318.16
12	8.98	7.35	57.13	1.96	16.49	10.20	1.07	87483.91
13	9.21	8.22	53.25	2.04	16.14	10.61	1.06	84452.59
14	8.79	6.17	54.63	1.79	16.75	10.39	1.05	85326.32
15	9.56	8.50	54.54	2.51	15.29	10.66	1.05	84438.88
16	7.01	10.28	59.15	2.16	15.36	10.68	1.06	84567.39
17	0.69	3.83	52.78	0.75	17.79	10.91	1.06	80785.97
18	1.89	3.74	35.29	1.65	18.08	9.94	1.05	87557.40
19	1.64	4.21	28.23	2.24	17.19	10.27	1.05	85806.01
20	1.22	3.70	53.30	2.06	17.04	10.39	1.05	84889.31
21	0.87	3.87	45.86	1.60	17.60	10.58	1.05	83068.06
22	0.73	3.65	41.89	1.95	16.81	10.63	1.05	83104.26
23	4.66	3.68	54.12	2.06	16.88	10.39	1.05	85279.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.42	5.29	51.65	2.05	17.12	10.30	1.07	85684.92
最大值	10.03	13.02	64.59	2.93	22.68	10.91	1.11	92924.87
發生時間	7	0	8	2	0	17		0
最小值	0.69	2.04	28.23	0.75	15.29	8.63	1.05	80785.97
發生時間	17	3	19	17	15	0		17
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.00 %		0.04		-0.20 %
全幅偏移(率)	0.04 %	0.52 %	-0.70 %	0.15 %		0.10		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.04	5.91	46.31	1.04	16.33	10.71	0.97	81928.82
1	5.51	7.75	52.18	1.22	17.30	10.75	0.98	83011.33
2	4.48	7.65	46.66	1.54	14.98	10.87	0.97	79646.82
3	4.60	4.64	52.02	1.37	16.55	10.46	0.97	82295.03
4	7.67	9.49	47.76	1.34	17.27	9.86	0.97	82334.67
5	9.81	12.34	49.37	1.71	14.35	11.01	0.97	76283.90
6	10.78	4.95	58.92	1.43	18.15	9.64	0.97	83978.63
7	8.46	2.53	59.93	1.09	16.45	9.90	0.97	78069.93
8	9.76	2.67	51.99	1.44	14.99	10.21	0.97	79620.92
9	7.87	3.14	46.74	1.23	15.46	10.30	0.98	79588.67
10	9.90	3.72	65.68	1.34	16.53	10.17	0.98	87613.83
11	2.37	5.71	52.43	1.72	13.74	11.25	0.97	80535.75
12	0.18	7.46	54.11	1.23	15.02	11.15	0.99	79757.26
13	0.63	11.93	52.83	1.18	14.86	11.09	0.99	77911.55
14	7.94	10.79	42.46	1.33	15.18	10.40	0.95	77376.11
15	3.58	5.67	50.82	1.21	14.98	10.87	0.96	75775.20
16	3.13	6.32	55.19	0.68	16.44	10.76	0.98	78189.79
17	2.37	6.00	51.98	1.30	15.10	11.04	0.97	76119.38
18	2.53	2.16	52.41	1.23	15.18	10.92	0.97	77830.20
19	1.31	0.35	53.72	1.25	14.86	11.14	0.97	77196.14
20	0.46	10.89	52.81	1.82	13.50	11.24	0.97	77111.33
21	0.24	5.38	52.65	1.09	15.82	10.84	0.96	77659.08
22	2.42	5.33	52.48	1.21	15.04	11.05	0.96	76315.69
23	3.61	4.45	56.58	0.81	16.68	10.77	0.97	78866.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.78	6.13	52.42	1.28	15.62	10.68	0.97	79375.69
最大值	10.78	12.34	65.68	1.82	18.15	11.25	0.99	87613.83
發生時間	6	5	10	20	6	11		10
最小值	0.18	0.35	42.46	0.68	13.50	9.64	0.94	75775.20
發生時間	12	19	14	16	20	6		15
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.02 %		0.02		0.00 %
全幅偏移(率)	2.07 %	0.32 %	-0.30 %	0.33 %		0.38		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								