

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.58	5.67	56.24	1.23	16.89	11.67	1.10	73515.37
1	2.57	7.08	60.27	0.64	18.62	12.21	1.11	67907.96
2	1.37	7.49	51.95	1.09	18.18	12.08	1.12	69736.25
3	10.88	5.45	40.50	1.61	17.51	11.13	1.10	78142.31
4	8.71	6.04	45.91	1.18	17.97	11.24	1.10	76045.86
5	7.53	6.96	51.29	1.19	17.27	11.74	1.09	80335.59
6	8.80	6.29	54.66	1.03	18.09	11.27	1.09	75776.02
7	8.52	6.00	52.81	0.97	17.90	11.64	1.09	73244.85
8	10.16	5.66	50.17	1.42	17.52	11.42	1.05	75189.27
9	9.70	7.48	46.83	1.47	16.37	11.87	1.03	73054.58
10	9.27	7.45	51.58	1.40	16.48	12.04	1.06	71177.58
11	8.46	7.21	50.32	1.05	16.89	11.63	1.04	73851.07
12	7.28	7.66	56.28	0.87	17.06	11.87	1.02	72159.32
13	4.34	7.72	56.51	0.82	17.21	11.86	1.02	71820.56
14	4.37	7.23	57.81	0.45	18.17	11.55	1.04	73552.14
15	9.52	7.91	45.04	1.52	16.62	11.51	1.03	75066.30
16	9.87	9.81	43.46	1.84	16.02	11.86	1.06	72221.64
17	9.26	6.13	48.60	0.84	16.88	11.72	1.07	73289.72
18	4.26	7.45	56.53	0.56	17.81	11.49	1.07	74184.33
19	8.09	11.08	49.75	1.05	18.29	11.06	1.05	77270.18
20	9.02	11.91	56.04	0.60	18.78	11.19	1.05	75913.44
21	6.58	11.45	55.45	0.64	19.33	11.27	1.05	74414.31
22	8.18	10.73	48.02	0.69	20.05	10.65	1.05	78656.95
23	7.52	10.49	54.52	0.72	19.88	10.82	1.05	77071.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.62	7.85	51.69	1.04	17.74	11.53	1.06	74316.54
最大值	10.88	11.91	60.27	1.84	20.05	12.21	1.19	80335.59
發生時間	3	20	1	16	22	1		5
最小值	1.37	5.45	40.50	0.45	16.02	10.65	1.02	67907.96
發生時間	2	3	3	14	16	22		1
零點偏移(率)	-0.06 %	-0.01 %	-0.04 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	-1.80 %	0.37 %	-0.02 %	0.03 %		-0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.00	4.00	59.04	1.52	15.99	11.36	1.05	77673.46
1	7.49	4.00	48.30	1.58	18.82	9.98	1.05	86209.74
2	8.32	5.27	52.11	2.49	16.61	10.40	1.05	85604.46
3	7.79	2.62	51.78	2.22	15.86	10.72	1.05	83322.72
4	9.49	4.16	47.58	2.01	16.15	10.54	1.05	84279.11
5	9.32	7.75	53.72	2.26	15.56	10.87	1.06	82474.35
6	10.62	5.93	49.32	3.08	15.44	10.62	1.03	83634.49
7	10.12	5.42	47.22	2.85	15.80	10.41	1.01	85511.51
8	8.50	4.46	62.28	1.94	15.93	10.46	0.98	85236.36
9	9.30	4.25	53.59	2.38	15.04	10.53	0.99	85452.77
10	8.89	3.79	57.96	2.45	14.58	10.86	1.01	82927.19
11	7.40	3.66	62.01	1.91	15.34	10.74	0.99	83151.21
12	3.00	4.97	54.32	2.09	14.37	11.10	0.97	81625.98
13	0.10	3.13	55.52	1.28	17.20	10.29	0.97	84627.60
14	0.37	5.11	52.95	2.13	15.54	10.53	0.97	84460.66
15	5.35	4.10	57.13	2.79	15.44	10.41	0.97	85298.67
16	5.38	4.30	60.50	2.37	14.82	10.70	0.99	83684.08
17	7.90	3.99	57.90	2.27	15.60	10.28	1.00	86347.65
18	7.61	3.51	56.05	2.42	16.08	10.57	0.99	83732.88
19	5.88	3.71	56.78	2.42	16.19	10.49	0.99	84412.80
20	9.00	4.02	46.98	2.51	16.56	10.20	0.98	86270.36
21	9.63	3.54	57.61	1.86	17.72	10.14	0.99	84687.49
22	8.21	5.78	54.20	2.18	16.94	10.23	0.99	85220.33
23	8.22	7.03	58.10	1.70	17.37	10.06	0.99	86863.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.33	4.52	54.71	2.20	16.04	10.52	1.01	84279.56
最大值	10.62	7.75	62.28	3.08	18.82	11.36	1.07	86863.57
發生時間	6	5	8	6	1	0		23
最小值	0.10	2.62	46.98	1.28	14.37	9.98	0.97	77673.46
發生時間	13	3	20	13	12	1		0
零點偏移(率)	-0.05 %	-0.05 %	-0.03 %	0.00 %		0.05		-0.10 %
全幅偏移(率)	0.00 %	0.85 %	-0.16 %	0.15 %		-0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.20	4.01	51.36	1.86	15.30	10.17	0.99	73086.13
1	6.03	6.43	41.94	2.24	13.14	11.38	0.99	67311.26
2	0.26	10.65	43.27	1.23	14.92	11.14	0.99	72953.32
3	0.12	2.78	63.51	0.88	14.98	10.84	0.99	73455.93
4	4.79	9.62	55.99	1.64	13.94	10.97	0.99	75336.49
5	4.58	2.12	50.94	1.42	14.48	10.84	0.99	74918.78
6	0.85	6.41	52.97	1.41	13.77	11.11	1.02	72852.32
7	0.63	6.10	51.18	1.00	14.35	11.42	1.03	71493.74
8	4.34	4.97	62.23	1.06	15.19	11.46	1.02	73372.83
9	1.64	5.99	52.25	1.35	14.43	11.15	1.02	76843.72
10	0.50	4.90	62.10	0.99	15.63	11.18	1.01	75171.07
11	2.07	5.55	52.98	1.60	14.34	11.12	1.00	77474.52
12	1.49	6.60	51.34	1.69	13.90	11.54	0.99	75103.00
13	7.08	7.36	61.00	1.75	14.58	11.32	1.01	76798.79
14	3.03	4.62	55.35	1.66	14.04	11.50	1.01	76380.11
15	5.82	4.93	60.70	1.80	14.35	11.48	1.00	76559.62
16	4.13	5.35	57.33	2.10	13.56	11.53	1.02	76700.09
17	6.71	4.52	56.00	1.89	14.13	11.58	1.00	79191.88
18	8.58	4.81	52.69	2.22	14.07	11.37	1.00	78766.78
19	6.58	4.93	59.80	2.44	13.84	11.40	1.01	78526.50
20	8.56	5.24	57.41	1.69	14.93	11.19	1.02	81229.59
21	7.68	4.65	56.09	1.39	15.89	10.88	1.02	83852.90
22	7.03	6.97	59.23	1.13	16.47	10.95	1.02	83458.45
23	6.83	8.53	61.11	1.23	16.68	10.85	1.02	83636.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.61	5.75	55.37	1.57	14.62	11.18	1.01	76436.43
最大值	11.20	10.65	63.51	2.44	16.68	11.58	1.07	83852.90
發生時間	0	2	3	19	23	17		21
最小值	0.12	2.12	41.94	0.88	13.14	10.17	0.99	67311.26
發生時間	3	5	1	3	1	0		1
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	-0.01 %		0.03		0.00 %
全幅偏移(率)	-0.57 %	-0.16 %	-0.47 %	-0.03 %		0.00		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								