

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.48	13.95	54.02	2.06	18.13	11.93	1.29	75289.93
1	9.34	12.61	45.59	2.60	18.96	10.93	1.28	83047.27
2	12.17	12.97	45.90	3.17	16.20	11.43	1.28	80896.87
3	8.11	12.96	52.48	3.21	15.30	11.71	1.27	78164.65
4	11.67	12.80	52.85	3.09	16.22	11.48	1.27	81157.54
5	8.72	12.87	51.05	2.04	17.34	11.35	1.24	81013.63
6	9.36	12.78	48.64	2.35	17.44	11.27	1.24	81918.96
7	9.94	12.96	48.78	1.93	17.42	11.41	1.24	79537.84
8	11.07	12.85	56.39	1.44	17.99	11.24	1.25	81748.30
9	8.49	12.88	46.14	2.61	15.58	11.45	1.27	81785.90
10	17.24	13.37	40.64	3.11	15.49	11.89	1.29	78236.27
11	10.17	13.40	39.40	2.58	16.46	11.73	1.27	78676.67
12	13.81	12.91	54.64	4.07	15.89	11.61	1.26	79925.08
13	6.54	13.16	54.51	4.59	14.64	11.91	1.29	78498.09
14	5.45	13.30	58.79	3.57	15.07	11.99	1.29	77806.09
15	8.40	13.28	53.76	3.08	16.43	11.81	1.27	78358.53
16	8.50	13.12	50.81	3.55	16.77	11.57	1.28	79370.16
17	14.47	12.98	45.59	5.30	15.69	11.49	1.27	80256.06
18	8.53	12.84	53.92	3.14	17.63	11.25	1.26	81706.90
19	12.58	12.95	48.66	6.35	15.66	11.46	1.27	80564.09
20	6.66	13.20	49.42	0.70	17.21	11.43	1.28	80144.07
21	9.60	12.62	45.76	0.86	17.21	11.18	1.29	81340.67
22	7.83	12.60	45.79	0.84	17.25	11.05	1.29	82890.85
23	8.85	13.05	39.14	0.80	16.75	11.41	1.28	79344.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.04	13.02	49.28	2.79	16.61	11.50	1.27	80069.94
最大值	17.24	13.95	58.79	6.35	18.96	11.99	1.29	83047.27
發生時間	10	0	14	19	1	14		1
最小值	5.45	12.60	39.14	0.70	14.64	10.93	1.23	75289.93
發生時間	14	22	23	20	13	1		0
零點偏移(率)	-0.06 %	0.00 %	-0.01 %	-0.00 %		-0.19	-0.01	0.30 %
全幅偏移(率)	0.22 %	0.25 %	1.04 %	0.92 %		-0.05	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.31	10.69	58.72	0.91	17.68	11.50	0.79	77856.27
1	8.40	10.81	61.09	0.66	18.43	11.83	0.79	72113.93
2	9.17	17.26	57.52	0.70	18.18	12.07	0.79	71428.22
3	11.12	17.55	56.93	0.52	19.37	11.37	0.79	78301.30
4	7.43	17.96	56.49	0.90	17.88	11.99	0.79	73937.19
5	9.36	18.38	55.60	1.22	17.38	12.26	0.79	69707.87
6	3.85	15.67	61.25	0.89	17.13	12.51	0.80	67428.83
7	11.69	11.52	56.15	0.65	18.85	11.57	0.79	72260.99
8	9.10	15.34	48.44	1.00	17.15	12.11	0.80	71412.18
9	12.19	12.76	56.25	1.06	17.68	11.54	0.82	77862.52
10	7.19	12.54	62.74	1.10	17.34	11.71	0.83	76829.36
11	11.02	11.69	63.06	1.23	16.97	11.46	0.81	78901.37
12	10.83	23.71	58.63	2.00	15.23	11.66	0.80	78077.19
13	8.23	10.67	63.04	1.00	17.00	11.41	0.81	78614.11
14	7.63	10.60	62.23	1.25	16.58	11.68	0.82	76725.38
15	9.52	12.62	56.33	1.29	15.64	12.09	0.81	72521.64
16	8.83	15.53	47.45	1.91	15.95	11.52	0.81	76178.59
17	14.37	13.25	42.03	1.93	16.25	11.15	0.81	80846.18
18	6.14	12.47	36.14	1.40	16.60	11.31	0.79	80288.52
19	10.66	12.58	43.27	1.59	17.33	11.08	0.81	81944.92
20	10.51	10.33	44.31	1.12	17.34	11.06	0.83	81766.37
21	7.49	42.30	39.28	1.81	15.77	11.24	0.82	79517.44
22	10.57	13.73	38.84	1.81	16.16	11.49	0.81	79331.20
23	9.69	12.22	43.96	1.71	16.55	11.51	0.81	78816.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.30	15.09	52.91	1.24	17.10	11.63	0.80	76361.15
最大值	14.37	42.30	63.06	2.00	19.37	12.51	0.83	81944.92
發生時間	17	21	11	12	3	6		19
最小值	3.85	10.33	36.14	0.52	15.23	11.06	0.79	67428.83
發生時間	6	20	18	3	12	20		6
零點偏移(率)	-0.02 %	0.01 %	-0.07 %	-0.01 %		-0.07	-0.06	0.00 %
全幅偏移(率)	0.87 %	-0.81 %	-0.11 %	-0.02 %		-0.04	0.31	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.26	11.37	55.27	2.72	19.60	9.48	1.36	78082.68
1	6.98	11.93	52.22	2.20	20.10	9.36	1.36	77123.10
2	8.32	11.25	56.97	2.68	17.14	9.97	1.35	74210.00
3	10.61	11.31	62.92	3.90	17.27	9.98	1.35	72289.23
4	8.29	11.61	52.54	4.09	17.45	9.51	1.34	74052.93
5	10.42	11.39	53.90	2.79	18.02	9.52	1.34	74088.43
6	11.95	11.42	56.73	1.05	17.35	9.69	1.34	73232.60
7	8.77	10.92	43.50	2.23	17.48	9.57	1.36	78075.49
8	10.99	13.40	58.51	3.30	15.42	10.74	1.38	76657.78
9	10.42	11.22	53.22	2.66	16.56	10.57	1.37	77358.12
10	9.64	12.51	48.89	2.87	15.91	10.78	1.38	77250.95
11	6.76	11.72	53.98	2.37	16.30	11.06	1.36	76449.53
12	9.30	11.54	62.49	2.52	17.38	10.90	1.36	77785.15
13	10.14	15.42	59.70	3.18	15.35	11.49	1.36	73009.23
14	9.43	17.11	57.16	3.28	15.39	11.40	1.38	72481.04
15	7.21	14.56	58.89	3.12	15.05	11.39	1.37	72942.16
16	7.01	18.55	47.42	2.70	15.53	10.45	1.36	74488.82
17	7.16	10.59	49.97	2.45	16.03	10.02	1.35	73091.83
18	7.45	11.92	45.14	2.47	16.16	10.04	1.35	71905.70
19	8.54	11.47	52.99	2.41	16.68	9.99	1.35	73074.72
20	7.46	11.98	49.75	2.63	15.39	10.29	1.36	71342.27
21	9.30	11.46	47.50	2.42	16.46	10.13	1.36	72347.95
22	10.83	11.66	49.16	2.66	16.74	10.08	1.36	72727.35
23	10.76	11.60	50.81	2.56	16.97	9.99	1.37	73161.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.96	12.41	53.32	2.72	16.74	10.27	1.36	74467.86
最大值	11.95	18.55	62.92	4.09	20.10	11.49	1.40	78082.68
發生時間	6	16	3	4	1	13		0
最小值	6.76	10.59	43.50	1.05	15.05	9.36	1.33	71342.27
發生時間	11	17	7	6	15	1		20
零點偏移(率)	-0.09 %	0.01 %	-0.01 %	0.00 %		-0.10	-0.01	0.10 %
全幅偏移(率)	-0.96 %	1.94 %	1.62 %	1.00 %		-0.16	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								