

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年06月15日

報表日期: 113年06月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.71	5.49	66.65	1.41	17.82	11.55	1.02	81410.09
1	11.57	5.96	58.97	2.74	19.33	11.07	1.02	84263.86
2	10.45	6.07	57.19	1.87	18.56	11.82	1.02	78699.19
3	9.82	5.01	50.79	1.20	19.44	10.86	1.02	85845.57
4	7.96	5.32	49.94	1.01	18.73	11.39	1.01	81904.83
5	2.85	5.26	44.02	1.15	18.42	10.83	0.99	86478.59
6	6.11	3.80	45.99	1.15	19.10	10.88	0.99	85626.43
7	7.56	3.65	50.58	1.06	19.63	11.11	1.02	83633.15
8	4.24	5.18	51.65	0.76	19.96	11.28	1.02	81413.05
9	8.68	4.26	33.12	1.61	18.04	11.08	1.01	84921.89
10	11.52	9.78	43.62	3.16	15.24	11.80	1.01	81442.30
11	10.78	2.67	43.60	2.04	17.03	11.65	1.02	80892.16
12	10.96	2.33	52.44	0.90	20.61	10.85	1.02	84381.96
13	11.46	3.36	55.94	2.68	18.63	11.56	1.00	80114.09
14	4.97	2.24	46.39	2.89	18.84	11.20	1.02	83050.96
15	12.48	4.94	47.64	3.12	18.32	11.26	1.02	83134.71
16	10.46	9.86	45.79	2.41	17.16	11.80	1.02	78774.42
17	8.44	1.46	48.46	1.28	18.00	11.44	1.02	82116.20
18	13.26	2.36	45.41	1.49	17.70	11.40	0.99	81556.88
19	9.29	3.97	64.24	0.63	19.70	11.89	0.98	76441.96
20	7.57	3.86	44.70	0.96	19.81	11.81	0.98	77040.18
21	9.65	6.72	50.26	2.50	18.83	11.17	0.97	82310.32
22	12.58	7.84	42.38	3.67	16.65	11.24	0.97	82812.70
23	11.63	2.32	53.92	1.12	18.33	11.27	0.97	80604.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.42	4.74	49.74	1.78	18.49	11.34	1.00	82036.23
最 大 值	13.26	9.86	66.65	3.67	20.61	11.89	1.03	86478.59
發生時間	18	16	0	22	12	19		5
最 小 值	2.85	1.46	33.12	0.63	15.24	10.83	0.97	76441.96
發生時間	5	17	9	19	10	5		19
零點偏移(率)	-0.13 %	0.00 %	-0.02 %	-0.01 %		-0.21		0.00 %
全幅偏移(率)	0.00 %	-0.24 %	0.37 %	-0.21 %		-0.01		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月15日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.77	3.38	60.61	1.31	19.74	10.35	1.02	83753.89
1	6.78	4.29	63.56	1.88	19.26	11.48	1.02	75373.54
2	8.27	3.80	49.53	0.85	18.92	11.22	1.02	77984.05
3	8.57	5.40	49.97	2.42	17.75	10.59	1.02	83729.58
4	9.43	4.67	55.08	1.67	18.91	10.73	1.02	81632.87
5	9.28	2.10	49.15	2.59	17.72	10.86	1.02	81859.79
6	6.02	3.62	60.50	1.28	19.48	10.01	1.03	84075.78
7	11.30	2.49	58.65	2.96	16.52	11.25	1.02	79630.65
8	7.89	2.61	58.54	1.89	18.07	11.54	1.02	75546.66
9	9.84	6.46	49.21	3.14	14.76	11.88	1.03	76449.89
10	14.13	11.09	46.63	4.46	12.98	12.24	1.02	75033.24
11	10.83	9.39	45.22	1.66	13.18	12.12	1.02	75466.71
12	17.14	4.43	46.02	2.59	16.47	11.63	1.03	75839.04
13	7.97	1.44	49.18	2.43	19.41	11.60	1.03	73751.02
14	1.72	3.23	50.58	2.12	16.88	12.01	1.03	72713.90
15	9.53	3.27	49.33	2.26	16.84	11.58	1.04	76791.32
16	9.51	4.61	49.22	2.34	15.91	11.37	1.04	77857.88
17	9.81	3.60	50.55	1.48	17.50	10.79	1.04	82047.26
18	9.67	5.60	52.17	1.12	18.36	10.66	1.02	82488.16
19	11.14	2.08	63.13	0.44	20.87	10.57	1.02	81027.80
20	9.59	2.12	58.38	1.16	19.88	10.66	1.02	81095.12
21	8.29	10.65	45.12	2.55	16.36	11.30	1.02	78841.65
22	9.95	1.88	54.34	2.73	16.14	11.40	1.02	78743.80
23	11.29	6.07	57.83	2.71	16.51	11.30	1.02	79055.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.57	4.51	53.02	2.08	17.43	11.21	1.02	78782.86
最 大 值	17.14	11.09	63.56	4.46	20.87	12.24	1.05	84075.78
發生時間	12	10	1	10	19	10		6
最 小 值	1.72	1.44	45.12	0.44	12.98	10.01	1.01	72713.90
發生時間	14	13	21	19	10	6		14
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	0.00 %		-0.04		0.00 %
全幅偏移(率)	0.13 %	-0.06 %	-0.23 %	-0.12 %		-0.09		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月15日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.05	4.70	51.67	2.26	17.15	10.91	0.98	81522.05
1	11.03	4.55	55.69	2.15	19.87	10.06	0.97	83135.33
2	6.07	5.25	53.34	1.86	18.68	10.15	0.99	83683.97
3	9.42	4.05	49.29	2.23	16.52	10.99	1.01	80298.34
4	9.10	2.41	53.99	2.43	18.12	10.39	1.02	82608.79
5	6.53	3.87	53.02	1.89	16.86	10.73	1.01	80762.00
6	9.10	4.46	62.77	2.41	17.23	10.56	1.01	81179.91
7	12.82	3.93	54.95	3.02	15.98	10.62	0.98	76223.34
8	7.62	2.91	55.21	1.76	16.35	11.02	1.00	77497.58
9	14.46	5.02	50.02	4.19	13.92	11.28	0.95	76846.99
10	10.83	5.56	56.34	3.36	13.39	11.87	0.99	73956.40
11	3.12	3.51	56.62	1.50	14.43	11.79	0.97	73632.97
12	12.67	2.91	55.91	2.90	16.55	11.31	0.97	76290.54
13	6.99	6.67	55.32	2.14	15.25	12.03	0.94	69270.07
14	3.38	1.82	53.51	2.13	16.37	11.08	0.93	76989.68
15	2.34	2.19	58.46	2.74	15.57	11.40	0.95	75299.83
16	3.96	2.73	60.19	1.51	17.16	10.97	0.94	78637.23
17	1.87	3.15	50.72	0.84	16.95	10.88	0.94	79377.85
18	2.77	3.06	56.14	0.97	16.67	11.14	0.93	77268.69
19	3.23	10.75	69.79	1.39	16.79	12.43	1.05	67094.19
20	4.45	8.14	42.68	2.46	14.44	12.93	1.02	64904.08
21	1.39	6.83	52.04	1.01	18.32	10.69	0.97	79787.90
22	6.32	7.66	44.95	2.20	14.29	10.77	0.93	77207.17
23	1.35	1.73	54.49	1.55	15.78	10.76	0.92	72788.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.87	4.49	54.46	2.12	16.36	11.12	0.97	76927.66
最 大 值	14.46	10.75	69.79	4.19	19.87	12.93	1.42	83683.97
發生時間	9	19	19	9	1	20		2
最 小 值	1.35	1.73	42.68	0.84	13.39	10.06	0.92	64904.08
發生時間	23	23	20	17	10	1		20
零點偏移(率)	-0.15 %	-0.01 %	-0.08 %	0.00 %		-0.11		0.10 %
全幅偏移(率)	0.02 %	-0.52 %	-0.18 %	-0.67 %		0.19		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								