

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月21日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.84	12.48	56.96	1.57	16.86	11.21	0.95	81537.65
1	3.21	12.80	59.87	1.59	18.38	11.25	0.94	80165.99
2	9.85	12.27	50.77	0.99	18.56	10.82	0.94	83071.29
3	7.85	12.33	54.84	0.89	18.31	10.92	0.94	82793.26
4	7.10	12.24	55.62	1.00	18.47	10.77	0.92	83946.48
5	6.74	12.07	56.78	0.84	18.87	10.61	0.92	84422.81
6	7.15	12.19	48.45	0.48	18.79	10.73	0.91	87366.33
7	6.98	12.55	47.02	0.65	19.46	10.56	0.92	84357.55
8	6.94	12.31	53.10	0.87	19.19	10.74	0.93	82510.48
9	6.93	12.18	56.54	0.62	19.50	10.60	0.93	83306.75
10	6.41	12.56	52.26	0.59	19.56	10.51	0.92	84166.90
11	6.56	13.31	52.56	1.29	16.88	11.83	0.93	78785.20
12	6.55	12.58	54.33	0.95	16.99	11.27	0.93	81358.80
13	6.45	12.47	55.09	1.10	16.69	11.23	0.92	82083.71
14	6.44	12.38	48.99	0.95	16.84	11.16	0.91	81680.60
15	6.71	12.97	54.70	1.30	16.47	11.64	0.91	78262.33
16	7.71	12.86	54.39	1.71	14.98	11.64	0.91	80246.74
17	7.43	12.93	60.15	1.79	15.48	11.71	0.92	79102.98
18	6.70	12.54	60.03	1.44	16.36	11.30	0.91	81752.06
19	6.71	12.58	57.29	0.96	17.52	11.20	0.92	82008.71
20	6.48	12.32	54.13	0.59	17.71	10.94	0.91	83845.60
21	6.37	12.28	48.31	1.07	17.53	10.91	0.92	83768.35
22	6.46	12.51	58.18	1.41	17.25	11.09	0.90	82357.16
23	5.15	12.33	55.15	1.25	17.18	11.02	0.90	83203.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.57	12.50	54.40	1.08	17.66	11.07	0.92	82337.55
最 大 值	9.85	13.31	60.15	1.79	19.56	11.83	0.96	87366.33
發生時間	2	11	17	17	10	11		6
最 小 值	2.84	12.07	47.02	0.48	14.98	10.51	0.90	78262.33
發生時間	0	5	7	6	16	10		15
零點偏移(率)	-0.14 %	-0.08 %	-0.05 %	-0.01 %		-0.01	-0.01	-0.10 %
全幅偏移(率)	0.14 %	0.13 %	-0.24 %	0.14 %		-0.01	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月21日

報表日期: 115年09月21日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.39	11.74	51.33	3.42	17.38	10.46	1.26	75305.16
1	11.60	11.65	51.07	3.55	19.87	9.82	1.25	78674.49
2	7.05	11.75	55.55	3.55	17.80	10.24	1.23	75850.58
3	11.31	11.77	54.54	3.60	17.08	10.47	1.23	74161.28
4	6.61	11.68	57.92	3.49	18.12	10.29	1.20	75120.41
5	8.26	11.58	53.96	3.43	17.95	10.23	1.21	75916.49
6	9.51	11.54	51.94	3.70	18.52	10.11	1.23	76264.70
7	5.85	11.51	56.57	3.79	20.11	9.85	1.27	76838.68
8	9.57	11.54	60.80	2.23	19.18	9.99	1.25	76561.60
9	12.35	11.54	64.63	2.29	19.19	9.96	1.27	77120.17
10	10.91	11.67	58.25	2.35	19.22	9.67	1.27	78298.90
11	8.18	11.81	64.71	2.14	17.72	10.28	1.28	75910.18
12	7.43	11.48	66.12	2.04	18.07	10.10	1.25	74355.32
13	7.62	11.54	43.18	2.04	17.19	10.26	1.24	76518.20
14	3.13	12.71	55.20	2.03	17.07	11.28	1.24	66566.92
15	1.92	11.47	37.99	1.98	18.67	9.97	1.24	73807.69
16	3.10	11.88	59.99	1.93	18.53	10.18	1.24	76224.73
17	7.64	13.04	61.90	2.01	16.83	10.24	1.25	75724.78
18	6.56	12.36	65.89	2.12	16.40	10.74	1.25	76099.68
19	8.05	12.09	67.52	2.11	17.00	10.76	1.24	76267.82
20	4.76	12.06	67.01	2.11	18.90	10.53	1.28	79361.59
21	8.40	12.33	63.88	2.36	19.04	10.46	1.27	79586.30
22	8.80	11.77	54.18	2.39	18.50	10.31	1.27	77633.79
23	9.94	12.79	56.93	2.29	17.50	10.64	1.24	78187.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.71	11.89	57.54	2.62	18.16	10.29	1.25	76098.20
最 大 值	12.35	13.04	67.52	3.79	20.11	11.28	1.30	79586.30
發生時間	9	17	19	7	7	14		21
最 小 值	1.92	11.47	37.99	1.93	16.40	9.67	1.20	66566.92
發生時間	15	15	15	16	18	10		14
零點偏移(率)	0.00 %	-0.01 %	-0.09 %	-0.01 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	0.75 %	0.95 %	0.63 %	0.49 %		0.28	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								