

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.38	12.91	63.42	2.36	16.46	11.59	1.20	79364.31
1	6.27	13.09	56.00	1.82	16.96	11.67	1.20	78274.80
2	12.03	13.33	64.54	2.04	17.20	11.82	1.20	77039.59
3	9.59	13.34	49.96	2.79	15.17	12.01	1.21	77728.31
4	10.91	13.29	46.90	3.99	14.96	11.87	1.19	78884.46
5	4.39	12.19	54.20	5.36	14.68	12.07	1.18	82432.62
6	12.82	12.87	56.63	2.48	14.99	11.92	1.18	78472.07
7	8.63	12.46	55.46	2.04	14.80	12.07	1.19	77509.77
8	9.90	12.43	54.81	3.62	15.81	11.78	1.21	78931.07
9	8.36	11.93	60.80	2.19	17.04	11.46	1.20	80658.86
10	10.61	11.66	51.76	2.85	16.30	11.49	1.20	80673.86
11	1.32	11.96	51.21	1.59	16.38	11.56	1.19	80074.10
12	10.92	12.81	49.09	2.54	16.72	11.23	1.20	82759.86
13	9.55	12.24	55.00	2.59	15.62	11.92	1.20	77221.22
14	8.23	12.09	59.45	1.91	16.90	11.36	1.19	81080.61
15	9.84	11.91	52.73	2.23	16.34	11.66	1.20	78813.51
16	8.30	12.19	48.43	2.27	16.07	11.73	1.20	77688.55
17	10.59	11.61	66.38	2.24	17.18	11.33	1.20	81051.56
18	8.41	11.73	61.34	2.22	16.39	11.52	1.20	79753.24
19	9.67	14.23	50.10	2.11	15.97	11.50	1.21	80042.90
20	11.00	12.06	55.60	2.20	16.25	11.64	1.20	79037.02
21	3.90	11.82	59.57	3.13	16.23	11.44	1.19	80488.90
22	6.53	12.08	55.86	3.75	15.75	11.92	1.19	77007.72
23	7.92	12.09	57.14	3.12	16.51	11.84	1.19	76859.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.75	12.43	55.68	2.64	16.11	11.68	1.20	79243.66
最大值	12.82	14.23	66.38	5.36	17.20	12.07	1.22	82759.86
發生時間	6	19	17	5	2	5		12
最小值	1.32	11.61	46.90	1.59	14.68	11.23	1.18	76859.04
發生時間	11	17	4	11	5	12		23
零點偏移(率)	-0.01 %	-0.05 %	-0.01 %	-0.01 %		-0.20	-0.01	0.20 %
全幅偏移(率)	-0.82 %	0.80 %	0.22 %	1.32 %		-0.09	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.38	12.79	44.39	1.01	16.98	11.40	0.96	77220.84
1	1.53	12.50	54.59	1.75	16.76	11.16	0.95	77526.61
2	3.38	12.85	62.55	1.44	17.34	11.41	0.95	76859.48
3	1.23	12.94	48.54	1.62	16.63	11.53	0.96	76652.90
4	4.93	12.78	55.96	1.71	16.46	11.34	0.97	79617.66
5	4.66	13.06	57.61	2.35	16.58	11.18	0.97	81391.32
6	9.52	12.80	62.26	2.61	15.93	11.56	0.94	77052.11
7	7.90	12.52	55.41	1.78	17.31	11.18	0.94	80245.06
8	11.03	12.66	56.77	2.28	17.32	11.12	0.94	79798.27
9	9.46	12.50	53.33	1.17	18.23	10.94	0.94	80624.37
10	5.92	12.19	59.56	1.29	18.94	10.61	0.94	82119.77
11	10.53	12.44	48.71	1.32	17.44	11.12	0.94	79740.58
12	5.03	12.21	54.79	1.22	17.69	10.89	0.93	80932.39
13	12.00	12.22	48.75	1.42	17.49	10.94	0.94	80866.49
14	2.96	12.18	56.73	0.64	18.09	10.85	0.94	81418.50
15	7.77	12.03	44.80	0.71	17.99	10.72	0.94	82068.08
16	7.82	12.00	61.02	0.67	18.35	10.66	0.94	82601.54
17	7.67	12.16	49.53	1.49	16.57	10.99	0.94	81034.11
18	11.26	12.35	45.25	0.98	17.49	11.00	0.94	80691.86
19	3.04	12.29	57.08	0.79	18.21	10.93	0.94	80801.98
20	9.71	11.60	43.72	0.33	19.22	10.19	0.94	85145.20
21	2.98	12.57	49.70	0.61	16.81	11.30	0.94	78132.27
22	5.49	12.75	52.72	0.59	17.81	11.32	0.94	77096.88
23	2.62	11.39	62.03	0.50	18.61	10.02	0.94	85952.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.37	12.41	53.57	1.26	17.51	11.02	0.94	80232.97
最大值	12.00	13.06	62.55	2.61	19.22	11.56	0.97	85952.93
發生時間	13	5	2	6	20	6		23
最小值	1.23	11.39	43.72	0.33	15.93	10.02	0.93	76652.90
發生時間	3	23	20	20	6	23		3
零點偏移(率)	-0.13 %	0.01 %	-0.04 %	-0.01 %		-0.13	-0.01	-0.10 %
全幅偏移(率)	-0.47 %	0.68 %	0.97 %	0.51 %		-0.36	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.11	11.65	53.75	1.43	18.61	9.75	1.34	74324.38
1	1.49	11.86	55.34	1.66	18.18	10.06	1.31	74893.29
2	1.86	11.70	59.00	1.73	18.58	10.35	1.31	73111.85
3	3.21	11.67	58.02	1.88	16.90	10.56	1.31	73080.16
4	8.30	11.48	58.24	2.48	16.73	10.36	1.35	72959.82
5	6.70	11.22	49.18	2.44	16.35	10.12	1.36	72295.30
6	9.14	11.38	55.57	2.32	17.92	10.05	1.36	74354.21
7	7.00	11.39	51.45	2.11	17.29	10.15	1.32	72393.38
8	10.40	11.50	50.66	2.52	17.22	10.09	1.34	72900.85
9	5.51	11.31	52.73	2.03	17.61	9.91	1.29	72589.11
10	5.50	11.36	56.12	2.05	19.37	9.81	1.32	72354.89
11	4.59	11.78	45.29	1.58	18.44	9.49	1.35	74360.26
12	5.59	11.07	63.38	1.77	18.55	9.61	1.29	73813.00
13	2.80	11.19	59.85	1.56	17.53	9.69	1.27	72680.67
14	2.84	11.59	63.19	1.40	20.32	9.87	1.28	71803.90
15	3.12	11.41	53.79	1.72	20.43	9.45	1.29	77519.85
16	2.74	12.04	46.50	1.66	18.60	9.48	1.27	73279.74
17	3.85	13.21	46.74	1.31	21.77	8.92	1.29	78922.09
18	2.82	10.23	49.59	1.88	19.92	8.43	1.33	76865.91
19	4.55	10.52	31.69	1.81	18.55	8.58	1.31	72436.54
20	2.34	10.47	35.82	1.55	20.00	8.41	1.29	74005.69
21	6.87	10.14	64.46	2.74	19.04	8.56	1.27	76332.50
22	8.56	10.46	66.28	3.15	19.63	8.82	1.31	74382.33
23	1.69	10.75	56.95	1.95	19.42	9.29	1.32	73190.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.65	11.31	53.48	1.95	18.62	9.58	1.31	73952.07
最大值	10.40	13.21	66.28	3.15	21.77	10.56	1.36	78922.09
發生時間	8	17	22	22	17	3		17
最小值	0.11	10.14	31.69	1.31	16.35	8.41	1.27	71803.90
發生時間	0	21	19	17	5	20		14
零點偏移(率)	-0.14 %	0.00 %	-0.01 %	-0.00 %		-0.07	-0.01	-0.10 %
全幅偏移(率)	1.30 %	0.60 %	-0.05 %	0.98 %		0.08	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								