

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.71	1.34	55.24	4.03	13.66	12.68	1.42	67332.74
1	10.22	2.53	70.35	3.69	14.30	12.45	1.43	69485.14
2	8.75	4.29	57.35	3.70	14.50	12.58	1.37	68595.84
3	9.15	6.65	57.91	4.10	13.34	12.71	1.38	68662.20
4	6.44	2.28	68.67	3.77	13.64	12.66	1.41	69078.43
5	10.47	12.91	55.71	4.44	13.08	12.84	1.41	69985.75
6	7.12	3.30	66.89	3.84	13.96	12.69	1.41	68303.55
7	9.58	1.73	68.78	3.71	14.58	12.63	1.40	67725.20
8	9.12	2.49	60.85	3.62	14.29	12.47	1.39	69009.49
9	5.32	2.34	67.72	2.66	16.02	12.12	1.37	71267.24
10	8.47	2.91	58.81	3.20	14.82	12.30	1.37	69685.90
11	7.24	2.65	51.07	3.47	14.14	12.45	1.37	69638.90
12	8.20	8.46	60.21	4.44	12.50	12.70	1.37	68685.41
13	10.71	3.13	57.16	4.78	12.35	12.80	1.37	68467.48
14	8.01	1.90	65.11	3.73	14.12	12.55	1.41	68841.29
15	2.98	1.82	66.28	3.68	13.57	12.72	1.41	67762.29
16	2.18	2.80	57.27	3.64	13.54	12.56	1.42	68995.61
17	3.55	3.44	66.68	3.68	13.82	12.48	1.42	69535.36
18	3.10	1.61	68.46	3.00	14.80	12.36	1.41	69960.34
19	5.01	8.45	56.02	3.32	14.35	12.38	1.40	69776.21
20	3.57	6.18	70.32	2.86	15.07	12.47	1.39	68399.10
21	1.07	4.72	55.26	2.22	16.23	12.06	1.39	70377.84
22	2.48	5.43	46.34	2.40	15.84	12.05	1.37	71209.00
23	7.16	9.71	53.85	3.47	14.72	12.53	1.36	68076.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.65	4.29	60.93	3.56	14.22	12.51	1.39	69119.05
最大值	10.71	12.91	70.35	4.78	16.23	12.84	1.44	71267.24
發生時間	13	5	1	13	21	5		9
最小值	1.07	1.34	46.34	2.22	12.35	12.05	1.33	67332.74
發生時間	21	0	22	21	13	22		0
零點偏移(率)	-0.02 %	-0.01 %	-0.02 %	-0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	2.53 %	0.01 %	-0.47 %	0.11 %		-0.01	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.47	2.13	50.69	1.51	15.44	10.73	1.36	62606.48
1	10.65	3.10	44.03	1.77	17.95	10.05	1.38	65146.54
2	10.91	1.21	47.87	2.21	17.69	10.21	1.42	63687.57
3	9.86	6.36	53.49	2.11	16.97	10.07	1.38	63244.65
4	9.91	7.14	67.08	1.98	16.98	10.37	1.37	64287.35
5	9.79	2.70	55.67	2.05	16.64	10.50	1.36	60222.82
6	10.20	0.89	61.43	1.99	17.71	10.49	1.38	61345.23
7	7.19	3.24	48.20	2.09	16.88	10.39	1.38	59583.93
8	7.78	0.76	53.84	1.92	17.76	10.23	1.38	64304.03
9	9.65	1.15	64.39	1.97	16.59	11.25	1.39	61071.83
10	9.64	1.65	71.13	1.85	17.06	11.30	1.42	58767.51
11	7.61	1.28	64.43	1.66	17.43	10.55	1.43	63727.01
12	8.51	1.28	59.26	1.66	17.67	10.48	1.43	65008.88
13	5.84	1.48	59.75	1.50	17.43	10.69	1.40	63997.17
14	3.72	2.73	64.92	1.28	18.09	10.78	1.38	62941.10
15	7.85	5.22	57.92	1.89	17.18	10.81	1.38	64105.05
16	2.83	1.25	67.85	1.63	17.14	11.63	1.38	58377.46
17	6.73	5.14	51.69	2.06	16.07	10.79	1.38	64401.05
18	10.27	1.67	64.34	1.90	17.39	10.63	1.38	65433.46
19	8.16	3.36	62.16	1.58	17.81	10.59	1.38	65260.87
20	8.55	3.39	62.69	1.19	19.32	10.18	1.39	66675.43
21	8.08	0.66	42.69	1.12	19.29	9.96	1.38	67643.21
22	8.05	0.85	49.79	1.08	19.17	10.26	1.39	66648.12
23	6.94	1.09	61.54	1.33	18.20	10.56	1.39	65393.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.09	2.49	57.79	1.72	17.49	10.56	1.39	63495.02
最大值	10.91	7.14	71.13	2.21	19.32	11.63	1.45	67643.21
發生時間	2	4	10	2	20	16		21
最小值	2.83	0.66	42.69	1.08	15.44	9.96	1.35	58377.46
發生時間	16	21	21	22	0	21		16
零點偏移(率)	0.00 %	-0.03 %	-0.01 %	-0.00 %		-0.13	0.00	0.00 %
全幅偏移(率)	0.34 %	0.30 %	-0.54 %	0.21 %		0.12	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.69	3.93	58.79	3.97	15.46	11.29	1.90	82614.77
1	8.72	3.43	62.28	2.28	16.20	11.06	1.87	84155.84
2	7.70	6.66	59.72	2.28	16.38	10.82	1.85	87059.43
3	6.80	5.36	61.45	2.47	15.58	11.03	1.85	85601.84
4	5.89	3.09	61.79	1.98	16.56	10.85	1.85	85772.38
5	8.05	10.92	61.60	2.21	17.14	10.76	1.85	87104.63
6	9.67	3.25	59.04	2.36	16.04	11.14	1.85	84470.52
7	6.01	2.89	67.44	1.91	15.66	11.51	1.85	83924.12
8	8.11	1.61	61.63	1.90	17.24	10.67	1.85	87674.06
9	9.41	4.96	51.72	1.97	16.66	10.77	1.85	87896.85
10	10.40	14.29	59.05	2.30	15.51	10.79	1.86	86653.44
11	9.84	15.39	63.63	2.65	16.49	10.76	1.85	84065.81
12	6.03	5.81	54.35	1.62	17.31	10.08	1.85	85966.70
13	1.59	4.64	59.91	1.30	18.56	10.01	1.85	84628.38
14	1.88	16.05	60.46	1.43	18.17	10.07	1.85	88873.00
15	3.44	3.12	60.85	1.61	16.82	10.71	1.86	83069.76
16	4.96	1.75	63.79	1.70	16.73	10.55	1.86	82809.28
17	5.74	3.84	52.13	1.72	16.99	10.30	1.85	83948.01
18	3.79	2.73	69.11	1.59	16.93	11.11	1.85	79872.93
19	0.46	8.19	69.42	1.66	15.99	12.00	1.85	77673.75
20	0.67	6.45	65.24	1.38	17.53	10.81	1.86	86918.50
21	2.79	8.64	64.53	1.89	15.35	11.11	1.85	84555.75
22	5.17	8.96	57.70	3.40	16.58	10.63	1.85	87300.56
23	3.22	6.95	57.56	1.51	16.79	10.85	1.85	85878.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.75	6.37	60.97	2.05	16.61	10.82	1.85	84937.01
最大值	10.40	16.05	69.42	3.97	18.56	12.00	1.93	88873.00
發生時間	10	14	19	0	13	19		14
最小值	0.46	1.61	51.72	1.30	15.35	10.01	1.83	77673.75
發生時間	19	8	9	13	21	13		19
零點偏移(率)	-0.02 %	-0.00 %	-0.00 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	0.14 %	0.33 %	-0.43 %	0.26 %		0.18	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								