

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.30	5.61	61.72	3.47	17.91	12.37	1.48	69741.75
1	5.45	2.37	59.50	2.78	20.71	10.90	1.47	79206.09
2	8.87	3.47	46.50	2.94	19.56	11.25	1.46	77149.69
3	8.46	2.84	54.26	3.25	18.60	11.59	1.46	75558.51
4	7.22	3.44	51.26	3.14	19.05	11.45	1.46	76407.77
5	2.17	3.63	62.69	3.14	18.94	11.78	1.47	74266.22
6	8.63	4.10	62.15	3.37	18.59	12.14	1.47	70723.60
7	3.56	3.62	52.05	3.12	18.65	11.77	1.47	73805.05
8	7.48	4.21	52.83	2.82	19.43	11.08	1.46	77984.29
9	9.00	4.21	49.93	3.09	18.84	11.34	1.41	76020.82
10	8.48	3.31	52.33	2.93	19.02	11.22	1.46	76748.45
11	3.33	3.65	52.11	2.98	18.98	11.67	1.43	73091.18
12	6.10	4.75	46.40	2.70	19.97	10.90	1.44	77856.23
13	7.88	4.24	57.02	2.91	19.73	11.32	1.44	74922.93
14	9.92	2.82	53.17	3.10	19.55	11.28	1.41	74833.37
15	8.38	6.16	53.08	3.20	18.26	11.59	1.43	73719.02
16	12.52	6.23	56.28	3.27	18.97	11.49	1.46	74354.89
17	8.88	5.02	64.04	3.15	19.48	11.76	1.44	71510.89
18	8.37	2.71	57.54	2.85	19.88	11.25	1.41	75168.78
19	4.81	2.66	55.16	2.88	20.14	11.43	1.45	73969.14
20	4.61	6.63	55.42	3.16	18.64	11.92	1.46	71332.24
21	5.55	3.32	60.00	3.08	19.17	11.53	1.46	73500.40
22	7.43	2.18	57.61	2.89	19.43	11.12	1.46	76714.70
23	8.53	2.84	56.73	3.08	18.78	11.44	1.46	74443.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.12	3.92	55.41	3.05	19.18	11.48	1.45	74709.58
最大值	12.52	6.63	64.04	3.47	20.71	12.37	1.51	79206.09
發生時間	16	20	17	0	1	0		1
最小值	2.17	2.18	46.40	2.70	17.91	10.90	1.39	69741.75
發生時間	5	22	12	12	0	1		0
零點偏移(率)	-0.04 %	-0.03 %	-0.01 %	-0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	4.09 %	0.39 %	-0.26 %	0.23 %		0.23	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.12	4.30	57.65	2.11	16.59	10.79	1.43	63813.55
1	8.43	4.44	56.66	1.74	18.23	10.43	1.43	66080.66
2	7.97	2.21	58.49	2.14	16.71	10.63	1.43	64657.40
3	9.64	2.64	56.92	2.06	17.76	10.38	1.43	66024.72
4	8.76	3.02	58.82	1.81	18.57	10.30	1.43	66188.39
5	10.42	4.76	56.51	2.03	17.67	10.62	1.42	64889.41
6	10.32	5.24	55.99	1.81	18.13	10.36	1.38	64123.05
7	9.32	5.05	59.97	1.83	17.61	10.63	1.38	65784.36
8	9.97	10.64	58.14	1.98	17.46	10.43	1.34	67619.41
9	10.07	7.51	58.56	2.51	16.30	10.85	1.36	64463.26
10	9.29	1.96	59.61	2.09	17.21	10.69	1.37	65024.70
11	8.53	10.75	54.71	2.16	17.02	10.53	1.33	65795.00
12	6.58	4.16	56.29	1.96	17.07	10.64	1.35	64032.85
13	8.38	3.14	56.25	1.98	18.34	10.00	1.36	65935.20
14	10.42	7.12	64.11	2.72	16.20	10.61	1.33	63716.89
15	8.46	1.12	50.12	2.13	17.54	10.25	1.32	64125.49
16	8.83	2.25	46.92	2.16	17.45	10.05	1.33	63716.66
17	10.78	1.48	51.47	2.33	17.48	10.24	1.34	63580.67
18	9.93	3.53	56.72	2.53	16.62	10.58	1.32	62169.62
19	8.94	1.47	58.23	2.46	15.58	10.78	1.29	60425.55
20	8.44	3.30	55.32	2.25	17.06	10.09	1.30	63325.49
21	9.37	7.84	49.96	2.18	17.19	10.11	1.31	62110.42
22	9.53	3.56	46.87	2.29	16.76	10.02	1.33	61370.42
23	12.78	6.90	51.48	2.70	15.73	10.40	1.35	60746.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.35	4.52	55.66	2.17	17.18	10.43	1.36	64154.97
最大值	12.78	10.75	64.11	2.72	18.57	10.85	1.43	67619.41
發生時間	23	11	14	14	4	9		8
最小值	6.58	1.12	46.87	1.74	15.58	10.00	1.28	60425.55
發生時間	12	15	22	1	19	13		19
零點偏移(率)	-0.20 %	0.00 %	-0.00 %	-0.01 %		-0.05	0.00	0.00 %
全幅偏移(率)	0.91 %	0.32 %	-0.09 %	0.16 %		0.11	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.99	7.12	55.33	2.16	15.55	10.79	1.72	84111.78
1	9.06	8.49	47.32	1.68	17.32	10.53	1.72	86523.53
2	10.34	6.62	52.13	1.89	16.28	10.77	1.72	85236.79
3	7.33	5.93	55.97	1.80	16.42	10.58	1.72	85935.36
4	7.18	4.71	56.28	1.76	17.14	10.47	1.72	85510.70
5	7.18	5.98	56.17	1.60	17.78	10.23	1.72	87154.06
6	7.56	12.80	56.00	1.74	17.91	10.41	1.72	88195.81
7	6.85	6.90	55.44	1.66	17.07	10.48	1.70	87369.14
8	7.69	7.39	56.30	1.78	17.21	10.62	1.72	86410.68
9	7.14	13.56	57.19	1.81	16.42	10.84	1.74	85527.21
10	6.06	4.72	56.98	1.75	16.79	10.71	1.74	83563.61
11	6.58	6.06	52.64	1.94	16.12	10.64	1.75	81922.28
12	6.81	6.36	48.18	1.95	16.72	10.29	1.74	82735.30
13	7.57	8.81	48.19	1.82	17.10	10.18	1.74	84089.30
14	9.09	2.03	58.25	2.03	16.27	10.60	1.74	82477.77
15	9.61	6.05	53.50	1.94	17.28	10.09	1.73	85303.23
16	5.42	1.84	54.42	1.77	16.88	10.38	1.72	82248.40
17	7.53	4.94	50.35	1.73	18.11	10.20	1.73	83134.92
18	7.90	4.44	58.61	2.10	18.14	9.98	1.73	84477.85
19	12.23	11.38	45.28	1.88	16.97	9.93	1.72	81242.47
20	11.86	4.76	46.46	1.98	16.91	10.21	1.74	84508.20
21	8.82	1.17	55.23	2.08	15.81	10.59	1.75	84434.40
22	8.69	1.15	55.06	2.04	16.02	10.64	1.75	85278.24
23	13.17	7.49	57.91	2.49	15.34	10.83	1.73	83462.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.32	6.28	53.72	1.89	16.82	10.46	1.73	84618.89
最大值	13.17	13.56	58.61	2.49	18.14	10.84	1.77	88195.81
發生時間	23	9	18	23	18	9		6
最小值	5.42	1.15	45.28	1.60	15.34	9.93	1.68	81242.47
發生時間	16	22	19	5	23	19		19
零點偏移(率)	-0.01 %	0.00 %	-0.04 %	-0.02 %		0.01	0.00	0.00 %
全幅偏移(率)	1.60 %	0.27 %	-0.40 %	0.10 %		0.49	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								