

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.34	10.34	39.49	3.85	17.74	10.73	1.07	77449.19
1	10.01	6.14	45.70	3.23	18.42	11.58	1.11	71510.28
2	8.08	2.74	65.42	2.16	20.05	11.44	1.05	71728.91
3	8.56	3.90	49.15	1.83	19.95	10.39	1.05	80059.86
4	9.63	2.12	50.47	3.18	15.57	11.55	1.05	74715.00
5	9.03	17.83	41.07	2.84	16.70	11.07	1.05	75501.93
6	9.11	3.28	41.86	2.80	16.39	11.29	1.09	76268.67
7	10.81	2.92	45.78	2.72	15.77	11.48	1.10	74208.62
8	10.41	4.93	51.05	2.44	16.15	11.43	1.05	74590.85
9	9.13	4.67	51.12	2.67	15.51	11.55	1.09	73404.00
10	8.75	5.89	65.99	2.58	15.62	12.41	1.07	67178.66
11	9.81	6.02	51.37	1.81	17.21	11.27	1.10	74555.05
12	9.78	6.85	55.48	2.33	16.36	11.24	1.07	75689.63
13	9.52	6.23	56.48	2.83	14.98	11.64	1.09	73041.98
14	8.81	5.74	56.80	2.62	15.36	11.66	1.08	72353.64
15	10.18	6.80	55.08	3.52	14.50	11.93	1.10	71474.43
16	6.94	6.69	61.57	2.14	16.02	11.79	1.09	72825.98
17	7.37	6.35	63.22	1.61	16.60	11.34	1.11	76315.84
18	9.36	7.81	57.41	2.18	16.45	11.38	1.06	76127.77
19	8.74	6.96	58.51	1.71	16.91	11.58	1.05	74483.02
20	8.47	7.85	65.74	1.70	17.39	11.49	1.07	74803.71
21	8.25	7.13	64.57	1.43	17.87	11.01	1.10	77790.51
22	4.85	6.33	54.28	1.26	18.20	11.19	1.12	76482.36
23	7.97	7.29	57.16	1.51	18.56	11.01	1.10	77770.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.87	6.37	54.37	2.37	16.84	11.39	1.08	74597.11
最大值	10.81	17.83	65.99	3.85	20.05	12.41	1.32	80059.86
發生時間	7	5	10	0	2	10		3
最小值	4.85	2.12	39.49	1.26	14.50	10.39	1.02	67178.66
發生時間	22	4	0	22	15	3		10
零點偏移(率)	-0.49 %	0.00 %	-0.26 %	-0.05 %		-0.02		0.00 %
全幅偏移(率)	-1.50 %	-0.49 %	0.32 %	-0.30 %		0.15		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.86	4.86	53.31	2.37	14.84	10.92	1.02	81822.31
1	9.70	5.87	38.52	1.92	18.48	9.92	1.04	86283.11
2	9.84	3.00	43.23	2.59	15.81	10.20	1.02	87419.81
3	9.11	2.01	45.88	2.66	15.01	10.64	1.01	84725.26
4	9.55	1.67	47.66	1.81	16.76	9.97	0.99	88364.13
5	9.78	4.92	43.74	2.87	15.04	10.56	0.99	84619.74
6	12.00	3.72	56.06	2.29	17.51	10.43	0.97	93339.50
7	9.24	3.81	49.38	1.63	16.91	10.38	0.97	84399.43
8	8.24	5.93	57.17	1.70	16.13	10.69	0.98	82275.72
9	9.57	2.54	54.36	1.37	18.03	10.09	1.01	84891.39
10	7.86	2.98	56.30	1.17	17.67	9.85	1.02	87679.43
11	10.17	3.21	45.95	2.20	16.07	10.14	1.00	85985.45
12	7.67	2.46	56.00	2.07	15.32	10.62	0.99	83061.87
13	6.79	2.26	55.53	2.85	14.01	10.98	1.00	80934.05
14	5.19	2.40	61.04	2.30	15.28	11.00	0.99	80537.19
15	6.87	2.61	64.87	1.31	17.49	10.70	0.99	80504.18
16	5.42	4.54	48.60	1.29	18.10	10.01	0.98	85327.25
17	2.79	8.82	42.35	1.58	18.30	9.61	0.99	88726.24
18	4.82	5.68	47.92	1.71	17.37	9.84	0.98	87319.44
19	5.39	4.80	52.77	1.21	19.05	9.76	0.97	86770.97
20	8.95	2.05	43.75	2.02	18.56	9.37	0.97	89618.02
21	9.88	3.39	50.18	1.68	18.57	9.38	0.98	89294.10
22	9.16	4.19	48.39	1.88	18.02	9.81	0.99	86799.43
23	9.82	6.91	52.91	1.53	19.00	9.43	1.00	89097.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.15	3.94	50.66	1.92	16.97	10.18	0.99	85824.82
最大值	12.00	8.82	64.87	2.87	19.05	11.00	1.05	93339.50
發生時間	6	17	15	5	19	14		6
最小值	2.79	1.67	38.52	1.17	14.01	9.37	0.97	80504.18
發生時間	17	4	1	10	13	20		15
零點偏移(率)	-0.02 %	0.00 %	-0.22 %	-0.03 %		0.04		-0.20 %
全幅偏移(率)	0.04 %	-0.02 %	-0.36 %	0.04 %		-0.13		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.40	9.90	57.64	3.07	14.33	10.95	0.98	76659.57
1	9.21	6.86	56.16	2.87	15.60	11.04	0.98	78687.31
2	8.99	2.12	62.10	2.93	15.47	11.12	0.99	78144.06
3	9.74	1.99	52.92	3.27	14.70	11.23	0.99	78726.78
4	8.72	3.38	47.21	3.35	14.73	10.70	0.97	77279.51
5	10.27	2.15	46.24	3.72	13.36	10.99	0.98	74725.29
6	8.72	5.49	63.15	3.05	14.82	10.46	0.98	78590.18
7	12.02	6.08	50.11	2.93	15.02	10.00	0.94	76220.53
8	9.62	3.42	55.43	2.86	13.64	10.51	0.94	77189.14
9	8.46	7.84	39.92	2.70	13.55	10.68	0.94	74796.21
10	7.23	5.45	53.33	2.12	13.93	11.06	0.94	72713.42
11	8.87	4.09	60.81	1.52	16.45	9.94	0.96	81979.43
12	9.55	3.27	62.50	2.20	15.28	10.10	0.94	78953.14
13	9.73	5.01	51.23	2.63	14.51	10.18	0.93	73280.53
14	9.41	4.81	50.62	2.89	13.49	10.94	0.95	73001.73
15	9.00	5.42	50.32	2.58	13.14	11.15	0.91	71956.38
16	8.67	6.12	56.87	2.95	12.52	11.70	0.94	74737.55
17	4.72	2.07	70.48	2.11	13.96	11.40	0.94	79896.87
18	4.56	2.56	60.19	1.37	16.11	10.97	0.94	79454.99
19	8.98	7.49	43.55	1.53	15.83	10.59	0.94	79029.81
20	8.98	5.23	53.37	1.31	16.57	10.63	0.93	78890.44
21	10.07	3.88	54.73	1.74	15.65	10.78	0.94	81231.33
22	7.85	2.59	57.81	1.70	15.34	11.26	0.94	80086.70
23	10.80	3.75	58.64	1.70	16.06	10.99	0.94	82201.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.86	4.62	54.81	2.46	14.75	10.81	0.95	77434.68
最大值	12.02	9.90	70.48	3.72	16.57	11.70	0.99	82201.53
發生時間	7	0	17	5	20	16		23
最小值	4.56	1.99	39.92	1.31	12.52	9.94	0.91	71956.38
發生時間	18	3	9	20	16	11		15
零點偏移(率)	-0.48 %	-0.01 %	-0.58 %	-0.06 %		0.03		0.00 %
全幅偏移(率)	-0.24 %	0.10 %	0.03 %	0.05 %		0.09		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								