

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.42	13.00	46.20	2.79	17.07	11.12	1.28	83495.86
1	9.87	13.20	52.36	2.98	16.90	11.37	1.29	81293.58
2	8.95	12.98	49.22	2.91	17.77	11.07	1.27	82848.86
3	13.80	12.99	51.93	3.29	16.21	11.30	1.25	81823.95
4	16.48	13.03	60.77	3.20	16.94	11.20	1.25	82551.55
5	7.59	14.32	55.11	3.45	15.53	11.56	1.25	83612.20
6	8.77	14.05	58.04	2.47	17.60	11.25	1.25	82279.09
7	8.52	13.64	52.86	2.45	17.11	11.03	1.25	82907.06
8	9.78	13.63	42.67	2.38	16.91	11.04	1.25	83360.49
9	8.91	13.75	54.82	2.13	17.88	10.99	1.26	83618.80
10	7.76	13.68	50.89	2.30	16.24	11.18	1.27	83144.92
11	11.23	13.77	57.87	2.11	16.85	11.17	1.29	82944.62
12	5.86	13.60	58.64	1.95	16.75	11.59	1.31	78838.80
13	11.76	12.96	49.74	1.81	18.27	10.98	1.29	82839.56
14	10.46	13.19	55.85	1.78	18.51	10.90	1.28	82819.76
15	12.66	12.75	54.07	1.80	18.16	10.87	1.28	83303.09
16	12.76	12.70	48.70	2.35	17.23	10.88	1.29	84562.35
17	6.24	12.65	51.16	1.59	17.98	10.84	1.28	84444.99
18	8.93	12.93	53.17	1.77	17.56	11.08	1.29	82770.06
19	8.63	13.30	48.84	0.76	18.96	11.17	1.29	81101.32
20	11.09	12.93	49.83	0.81	18.41	11.01	1.29	82814.67
21	9.65	12.88	49.60	1.62	18.35	10.93	1.29	83539.18
22	9.69	12.86	52.27	0.57	19.24	10.90	1.29	82761.63
23	8.30	12.94	46.03	0.84	19.70	10.72	1.28	83592.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.84	13.24	52.11	2.09	17.59	11.09	1.28	82802.89
最大值	16.48	14.32	60.77	3.45	19.70	11.59	1.33	84562.35
發生時間	4	5	4	5	23	12		16
最小值	5.86	12.65	42.67	0.57	15.53	10.72	1.25	78838.80
發生時間	12	17	8	22	5	23		12
零點偏移(率)	-0.03 %	-0.01 %	-0.01 %	-0.09 %		-0.06	-0.01	0.30 %
全幅偏移(率)	1.38 %	0.15 %	-0.28 %	-0.14 %		-0.06	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.73	11.85	52.93	1.47	17.35	10.48	1.03	79246.97
1	9.16	12.00	53.73	1.47	16.62	10.72	1.03	77767.82
2	9.72	12.00	56.85	1.95	16.91	10.66	1.02	78407.79
3	10.37	11.93	55.38	1.93	16.46	10.60	1.01	78390.42
4	9.61	11.89	56.59	1.52	16.19	10.71	1.00	78206.12
5	7.98	14.07	53.46	1.83	16.07	10.81	1.00	77679.91
6	8.80	12.71	57.57	1.74	16.57	10.74	1.02	79017.48
7	10.02	12.99	54.54	1.66	17.30	10.66	1.02	79896.36
8	8.87	13.10	54.66	1.90	16.89	10.79	1.02	80752.13
9	9.70	13.30	56.23	1.58	17.18	10.92	1.02	80229.85
10	8.90	13.04	53.65	1.40	16.86	10.73	1.03	81614.25
11	8.37	13.20	48.44	1.75	15.57	11.02	1.06	77679.76
12	7.92	12.13	51.65	0.83	16.96	10.65	1.05	78982.17
13	12.51	11.89	53.46	0.97	17.77	10.48	1.02	79859.35
14	7.11	12.16	59.12	1.14	17.74	10.73	1.02	77943.24
15	10.88	12.70	51.25	2.43	18.74	10.10	1.02	80609.41
16	9.00	11.59	46.89	2.27	18.93	9.81	1.02	81213.16
17	11.09	11.75	50.35	2.57	17.92	10.32	1.02	80415.75
18	7.13	11.75	48.24	1.59	20.09	9.67	1.02	82009.15
19	10.86	11.69	51.14	2.11	19.12	10.04	1.02	83160.16
20	10.59	11.68	44.49	1.43	19.16	10.06	1.04	83555.10
21	8.92	11.65	49.29	0.93	19.05	10.06	1.04	84196.17
22	11.72	12.44	49.34	0.93	19.19	10.21	1.04	80726.76
23	7.24	12.28	57.65	0.77	18.84	10.52	1.04	79652.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.43	12.32	52.79	1.59	17.65	10.48	1.02	80050.50
最大值	12.51	14.07	59.12	2.57	20.09	11.02	1.06	84196.17
發生時間	13	5	14	17	18	11		21
最小值	7.11	11.59	44.49	0.77	15.57	9.67	0.99	77679.76
發生時間	14	16	20	23	11	18		11
零點偏移(率)	-0.10 %	0.01 %	-0.04 %	-0.01 %		-0.06	-0.01	0.10 %
全幅偏移(率)	1.32 %	-1.90 %	0.05 %	-0.04 %		-0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.73	10.38	33.47	2.15	18.77	9.05	1.41	74668.71
1	14.01	10.48	41.80	3.43	18.34	9.23	1.41	74538.40
2	3.41	10.72	45.60	2.41	18.60	9.49	1.40	74090.45
3	10.94	10.65	46.40	3.16	17.12	9.62	1.41	72933.55
4	11.40	10.75	59.96	3.16	17.00	9.74	1.39	72810.39
5	7.91	13.10	64.09	2.81	17.14	9.81	1.40	73095.90
6	8.99	13.27	64.24	2.75	16.57	9.85	1.41	73441.84
7	9.76	11.85	48.11	3.03	18.12	9.49	1.42	76548.52
8	9.95	12.06	44.63	3.06	17.15	9.67	1.41	74218.46
9	9.75	12.24	47.04	2.86	16.30	10.00	1.41	73334.24
10	10.49	12.35	47.51	2.94	16.74	9.91	1.41	72410.61
11	6.99	11.98	55.60	2.56	17.04	9.71	1.41	73716.87
12	7.62	12.18	55.54	2.26	16.99	9.79	1.42	72829.13
13	14.31	12.34	56.52	3.11	17.53	9.61	1.41	74462.26
14	6.86	12.50	52.78	2.55	17.57	9.74	1.40	73557.50
15	7.10	12.73	58.30	2.55	18.44	10.07	1.41	72899.04
16	11.38	12.48	59.58	2.84	18.60	9.75	1.39	78134.65
17	8.42	12.60	58.78	2.63	17.64	9.92	1.41	75892.00
18	10.66	12.30	58.66	2.96	18.59	9.70	1.42	77228.95
19	8.72	12.78	55.92	3.06	19.19	9.65	1.42	78646.54
20	8.12	12.57	43.84	2.74	18.44	9.79	1.41	77705.91
21	11.78	12.79	53.50	2.84	18.16	9.81	1.40	78712.71
22	9.60	12.65	54.56	2.75	17.61	10.03	1.41	76362.02
23	8.73	11.95	56.69	2.90	19.62	9.56	1.40	75683.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.44	12.07	52.63	2.81	17.80	9.71	1.41	74913.42
最大值	14.31	13.27	64.24	3.43	19.62	10.07	1.43	78712.71
發生時間	13	6	6	1	23	15		21
最小值	3.41	10.38	33.47	2.15	16.30	9.05	1.39	72410.61
發生時間	2	0	0	0	9	0		10
零點偏移(率)	-0.04 %	-0.01 %	-0.03 %	-0.02 %		-0.06	-0.01	0.00 %
全幅偏移(率)	-1.68 %	0.15 %	0.26 %	-0.12 %		-0.14	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								