

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月23日

報表日期: 114年10月23日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.51	12.71	64.14	1.48	18.14	11.87	1.25	68920.60
1	1.70	12.30	47.82	1.96	18.63	11.50	1.25	71255.28
2	4.75	12.45	53.71	3.17	17.12	11.27	1.25	74599.94
3	8.64	13.07	50.24	4.33	15.61	11.55	1.25	75876.44
4	6.76	14.35	51.17	2.96	13.70	12.46	1.25	72612.49
5	6.09	12.81	58.76	2.45	16.70	11.30	1.25	71503.64
6	5.49	13.00	63.52	1.67	18.34	11.19	1.25	73805.26
7	7.71	12.90	45.66	2.46	17.88	10.95	1.26	76030.41
8	6.18	13.36	62.53	2.63	17.33	11.39	1.27	73626.73
9	3.82	12.86	48.61	1.86	17.37	11.23	1.27	75119.54
10	6.23	13.48	52.30	3.45	15.01	11.97	1.28	72119.48
11	8.58	13.27	49.43	2.29	17.10	11.51	1.27	74509.92
12	6.68	13.18	60.01	2.49	16.53	11.57	1.27	74022.23
13	4.65	13.23	50.23	2.07	16.23	11.65	1.27	73928.49
14	5.07	13.03	53.36	1.80	16.17	11.55	1.26	74425.23
15	5.87	13.54	65.07	2.40	16.20	11.82	1.27	72732.91
16	4.55	13.42	43.26	3.07	15.64	11.44	1.26	75693.35
17	5.21	13.59	48.06	2.81	15.70	11.89	1.26	72137.58
18	3.48	13.34	57.95	2.82	15.85	11.71	1.26	73552.27
19	7.28	13.06	55.37	3.20	16.05	11.46	1.27	74813.41
20	11.54	13.80	48.85	3.61	16.08	11.54	1.27	74400.51
21	11.24	13.38	52.88	3.58	15.58	11.66	1.27	74408.92
22	7.62	13.96	61.16	2.53	16.34	11.81	1.26	74738.42
23	13.14	13.36	50.39	3.64	15.92	11.59	1.25	74537.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.45	13.23	53.94	2.70	16.47	11.58	1.26	73723.79
最 大 值	13.14	14.35	65.07	4.33	18.63	12.46	1.29	76030.41
發生時間	23	4	15	3	1	4		7
最 小 值	1.70	12.30	43.26	1.48	13.70	10.95	1.24	68920.60
發生時間	1	1	16	0	4	7		0
零點偏移(率)	-0.02 %	0.00 %	-0.03 %	-0.03 %		0.03	-0.01	0.20 %
全幅偏移(率)	-0.30 %	-0.33 %	-0.38 %	-0.23 %		0.38	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月23日

報表日期: 114年10月23日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	4.03	12.50	48.92	0.59	19.97	10.16	0.94	86781.38
1	4.91	13.86	52.43	1.34	18.71	10.61	0.94	85118.65
2	4.83	13.68	56.08	0.71	20.11	9.85	0.94	89771.24
3	5.63	13.58	59.40	0.92	18.69	10.32	0.95	87230.25
4	7.65	13.22	56.52	0.89	18.87	10.17	0.94	88114.83
5	9.94	13.58	62.74	0.59	19.12	10.35	0.94	86257.73
6	5.52	11.99	47.91	0.42	19.59	10.13	0.99	84761.25
7	10.73	12.97	40.87	0.89	19.28	10.12	1.02	88729.11
8	8.63	13.33	55.37	0.51	19.54	10.22	1.02	86836.84
9	8.20	13.62	51.80	0.81	19.06	10.53	1.02	85948.14
10	8.19	13.74	50.14	0.69	18.70	10.47	1.01	86429.03
11	8.50	13.75	48.22	1.06	18.05	10.56	1.00	86472.73
12	6.78	13.69	54.55	0.66	18.90	10.66	1.00	84683.42
13	4.24	13.95	57.63	0.80	18.46	10.96	1.00	81886.43
14	3.90	12.86	49.75	0.75	17.96	10.69	1.02	83990.41
15	2.42	12.90	54.29	0.67	17.66	10.99	1.00	82090.46
16	2.81	12.11	58.44	0.47	19.64	10.25	1.02	86419.15
17	3.32	13.80	53.63	1.01	18.51	10.73	1.02	83895.43
18	2.60	13.49	55.57	1.17	18.05	11.38	1.05	79047.38
19	2.18	13.19	40.16	1.72	18.29	10.46	1.02	85957.68
20	3.04	12.94	40.06	1.11	19.50	10.01	1.02	87469.11
21	5.14	13.21	44.98	0.88	19.51	10.25	1.02	87083.97
22	4.09	12.51	55.42	0.36	19.81	10.54	1.03	83741.37
23	4.71	14.11	60.42	0.78	18.92	11.60	1.07	76541.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.50	13.27	52.30	0.83	18.95	10.50	1.00	85219.04
最 大 值	10.73	14.11	62.74	1.72	20.11	11.60	1.21	89771.24
發生時間	7	23	5	19	2	23		2
最 小 值	2.18	11.99	40.06	0.36	17.66	9.85	0.94	76541.09
發生時間	19	6	20	22	15	2		23
零點偏移(率)	0.00 %	-0.00 %	-0.04 %	0.00 %		0.01	-0.01	0.00 %
全幅偏移(率)	0.29 %	0.54 %	-0.27 %	1.06 %		-0.25	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

