

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月29日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO ₂ _C	#1-H ₂ O	#1-O ₂ _C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.86	6.12	51.77	2.53	16.80	12.10	1.28	73823.03
1	0.92	2.64	57.38	1.87	18.55	11.74	1.28	77200.38
2	1.60	6.93	49.23	3.58	15.48	12.05	1.29	76677.48
3	2.79	4.83	54.25	3.24	16.24	11.83	1.28	77381.28
4	1.22	2.91	56.91	2.56	15.79	12.28	1.28	73716.99
5	3.26	1.61	53.97	3.11	16.22	11.71	1.29	77070.22
6	1.00	2.29	46.54	3.14	15.30	11.87	1.29	77656.55
7	4.02	3.98	56.30	3.03	15.98	11.89	1.29	76787.28
8	5.80	3.89	57.77	3.08	16.11	11.99	1.31	75284.99
9	6.29	2.79	57.37	4.33	14.97	11.88	1.30	79244.67
10	5.92	2.98	59.56	3.48	16.30	11.95	1.29	77385.38
11	4.47	2.49	55.71	3.40	16.09	11.62	1.29	80090.54
12	4.94	2.80	56.24	3.18	16.35	11.60	1.29	79775.67
13	1.72	2.77	57.21	2.87	16.25	11.72	1.29	79255.38
14	3.26	2.31	65.12	2.30	17.08	11.84	1.29	77522.58
15	1.80	2.25	64.62	2.05	17.24	11.68	1.29	78598.51
16	1.60	2.34	54.76	2.79	16.25	11.65	1.29	79818.46
17	2.06	2.53	51.31	2.11	16.12	11.83	1.30	77912.60
18	3.35	2.42	54.81	2.47	16.50	11.68	1.30	79306.68
19	3.91	2.55	56.58	2.00	16.86	11.60	1.29	79944.87
20	2.63	2.65	61.00	1.49	17.31	11.10	1.29	83192.93
21	2.70	8.71	45.20	2.29	16.47	11.62	1.29	77121.48
22	2.97	3.93	58.64	1.66	16.90	11.45	1.30	79989.74
23	3.22	6.72	43.49	2.04	16.81	11.66	1.29	77333.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.10	3.56	55.24	2.69	16.42	11.76	1.29	78003.82
最 大 值	6.29	8.71	65.12	4.33	18.55	12.28	1.34	83192.93
發生時間	9	21	14	9	1	4		20
最 小 值	0.92	1.61	43.49	1.49	14.97	11.10	1.27	73716.99
發生時間	1	5	23	20	9	20		4
零點偏移(率)	-0.08 %	0.01 %	-0.02 %	-0.06 %		-0.03		0.00 %
全幅偏移(率)	0.00 %	0.00 %	-0.04 %	0.29 %		-0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月29日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO ₂ _C	#2-H ₂ O	#2-O ₂ _C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.55	2.25	54.16	1.57	19.01	10.36	1.06	81774.64
1	6.51	2.94	56.15	2.06	19.36	10.32	1.06	84538.44
2	7.09	1.83	53.76	1.43	20.42	10.26	1.06	83406.63
3	9.15	1.32	58.17	1.87	17.52	10.90	1.06	81385.53
4	8.10	2.90	59.93	2.22	17.19	11.18	1.06	79420.63
5	5.11	4.00	60.39	3.01	16.68	11.45	1.06	78145.76
6	10.25	1.06	52.77	2.02	17.11	11.16	1.06	86499.29
7	8.96	2.03	62.09	2.46	17.08	11.06	1.06	80701.51
8	8.22	4.70	63.66	2.31	18.23	10.82	1.07	80285.71
9	9.04	6.81	60.56	2.50	17.75	10.74	1.06	80024.01
10	6.85	1.78	66.22	2.34	17.07	11.18	1.06	79762.52
11	8.39	1.61	64.36	1.86	17.53	11.15	1.05	79674.62
12	9.02	2.09	55.16	2.79	17.17	10.94	1.06	78825.84
13	9.08	1.99	60.72	2.26	17.11	11.11	1.06	77472.71
14	8.90	2.71	68.20	2.16	17.86	10.76	1.05	82387.96
15	7.81	1.73	62.76	2.63	16.42	11.38	1.06	78962.95
16	6.33	1.70	49.86	2.27	16.64	11.25	1.06	79011.58
17	9.29	4.57	52.99	2.88	16.08	11.12	1.06	79395.62
18	10.97	4.30	54.17	2.98	14.99	11.38	1.06	76866.84
19	10.40	2.76	49.87	2.45	16.07	11.12	1.06	76937.15
20	6.17	1.62	47.92	2.54	16.92	10.88	1.06	79533.58
21	9.08	1.61	48.08	1.94	17.45	10.84	1.06	79961.42
22	8.42	1.46	51.39	1.57	18.15	10.62	1.08	81012.34
23	9.05	1.98	46.12	1.53	19.27	10.33	1.06	83991.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.32	2.57	56.64	2.24	17.46	10.93	1.06	80415.78
最 大 值	10.97	6.81	68.20	3.01	20.42	11.45	1.09	86499.29
發生時間	18	9	14	5	2	5		6
最 小 值	5.11	1.06	46.12	1.43	14.99	10.26	1.04	76866.84
發生時間	5	6	23	2	18	2		18
零點偏移(率)	-0.04 %	-0.01 %	-0.13 %	-0.09 %		-0.06		-0.10 %
全幅偏移(率)	0.13 %	0.63 %	-0.07 %	0.53 %		-0.19		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

