

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.26	11.55	33.99	0.83	18.96	10.95	1.10	76219.22
1	8.79	11.69	38.15	0.81	19.49	11.08	1.10	74965.46
2	6.10	12.67	41.80	0.64	19.89	11.38	1.08	72173.53
3	3.74	11.29	21.78	0.47	20.30	10.45	1.05	79158.91
4	9.15	13.56	25.25	0.87	18.89	11.14	1.05	74772.80
5	7.22	5.32	22.39	0.53	22.48	8.99	1.05	75911.74
6	8.93	6.00	36.48	2.47	20.23	8.82	1.05	75119.91
7	3.68	8.04	52.66	0.76	17.42	12.20	1.05	68759.02
8	4.68	9.12	62.23	0.28	21.24	10.90	1.06	75590.24
9	10.66	7.20	29.94	0.39	21.22	10.28	1.05	79398.32
10	9.40	7.17	32.97	0.37	20.14	10.53	1.05	78427.19
11	7.39	8.97	45.71	0.82	18.24	11.39	1.04	73452.65
12	1.83	10.02	59.97	0.38	18.90	11.65	1.07	70989.45
13	0.13	6.31	47.18	0.28	20.08	10.84	1.05	76088.08
14	6.39	11.60	40.76	0.49	20.49	10.36	1.06	79499.22
15	9.49	8.29	30.46	0.66	20.69	9.94	1.07	81172.75
16	7.23	6.60	38.09	0.80	19.18	10.90	1.05	75469.96
17	3.99	6.12	42.69	0.52	19.55	10.83	1.05	76707.84
18	7.55	5.99	44.24	0.40	20.73	10.31	1.07	80072.58
19	10.21	6.77	41.59	0.51	20.54	10.26	1.05	80566.30
20	8.96	7.00	45.36	0.96	19.93	10.68	1.07	77907.65
21	9.05	7.23	44.39	0.84	19.73	10.71	1.07	78694.36
22	8.14	7.89	49.10	0.63	20.01	10.90	1.05	76987.24
23	8.30	6.84	53.87	0.24	21.08	10.97	1.03	75606.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.05	8.47	40.88	0.66	19.98	10.69	1.06	76404.62
最大值	10.66	13.56	62.23	2.47	22.48	12.20	1.11	81172.75
發生時間	9	4	8	6	5	7		15
最小值	0.13	5.32	21.78	0.24	17.42	8.82	1.02	68759.02
發生時間	13	5	3	23	7	6		7
零點偏移(率)	-0.14 %	0.00 %	-0.02 %	-0.01 %		-0.13		0.00 %
全幅偏移(率)	0.00 %	-0.52 %	0.07 %	0.17 %		0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.39	7.80	43.97	2.38	17.78	10.12	1.02	86749.33
1	10.08	5.38	42.32	2.65	19.91	9.34	1.03	90033.03
2	9.00	3.21	50.37	2.81	17.58	9.71	1.04	90293.12
3	9.57	4.39	44.47	2.95	15.57	10.62	1.05	85256.77
4	9.12	5.86	41.03	4.63	15.91	10.19	1.05	87962.97
5	8.60	5.64	60.79	2.72	14.24	11.04	1.05	82066.90
6	9.21	6.69	57.71	2.55	16.23	10.01	1.05	85622.07
7	7.29	4.90	61.36	1.69	16.18	11.06	1.05	79193.85
8	9.38	4.99	35.26	1.31	18.60	9.91	1.04	85501.20
9	9.41	7.94	31.26	1.43	18.22	9.91	1.06	86212.69
10	9.15	8.10	51.23	2.19	15.06	10.43	1.06	85377.87
11	8.73	3.83	55.99	2.48	14.35	10.66	1.05	83965.99
12	6.61	6.21	55.95	1.21	16.69	10.42	1.05	83468.81
13	1.28	4.17	47.02	1.09	17.39	10.43	1.05	83138.09
14	7.70	7.55	49.79	1.32	17.53	10.24	1.05	83987.93
15	9.49	4.77	52.77	1.76	16.86	9.93	1.05	86828.61
16	8.57	1.09	52.16	1.48	16.55	10.29	1.05	84785.30
17	4.05	1.81	51.39	1.42	15.57	11.65	1.06	74569.28
18	0.16	1.89	35.85	0.69	17.44	10.78	1.07	80448.35
19	1.36	5.54	28.87	1.71	17.27	10.10	1.03	85702.74
20	3.01	6.95	59.06	1.99	15.89	10.81	1.01	81539.57
21	5.00	4.71	44.18	1.24	17.22	10.38	1.04	83683.45
22	8.27	4.17	57.57	1.23	17.23	10.74	1.05	81151.05
23	4.87	4.46	47.35	1.31	17.48	10.67	1.05	81053.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.05	5.09	48.24	1.93	16.78	10.39	1.05	84108.02
最大值	10.08	8.10	61.36	4.63	19.91	11.65	1.10	90293.12
發生時間	1	10	7	4	1	17		2
最小值	0.16	1.09	28.87	0.69	14.24	9.34	1.00	74569.28
發生時間	18	16	19	18	5	1		17
零點偏移(率)	-0.01 %	-0.02 %	-0.01 %	-0.01 %		0.02		-0.10 %
全幅偏移(率)	-0.05 %	-0.22 %	-0.11 %	0.24 %		-0.08		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.52	6.76	40.99	1.37	16.76	10.14	0.95	79015.46
1	10.69	5.61	53.05	1.32	18.97	10.07	0.97	80788.31
2	8.34	6.02	52.78	1.59	16.32	10.36	0.95	78140.86
3	9.14	7.31	61.54	1.61	16.87	9.90	0.94	78339.31
4	9.49	4.30	59.48	2.02	15.20	10.55	0.94	75477.90
5	9.30	4.93	56.07	1.95	15.07	10.31	0.94	74322.74
6	8.50	5.66	56.78	2.46	13.73	10.59	0.92	71090.13
7	11.02	3.04	64.23	2.54	15.64	10.34	0.97	71882.61
8	9.03	6.52	52.25	1.40	15.94	10.73	1.01	79113.67
9	10.99	6.10	58.20	1.60	16.46	10.40	1.02	85941.21
10	5.62	8.23	44.53	2.12	13.24	11.21	1.01	75415.53
11	9.14	8.63	53.78	1.94	14.12	11.08	1.04	76430.81
12	2.83	3.79	50.76	1.57	14.11	11.21	1.00	75502.66
13	5.76	5.44	53.87	1.73	14.44	11.07	0.99	76379.76
14	6.93	8.80	55.22	1.80	15.34	10.95	0.99	76884.25
15	10.06	5.84	46.57	1.51	15.77	10.54	1.03	79409.61
16	4.79	5.14	50.68	0.89	16.57	10.55	1.01	78635.34
17	3.18	5.54	53.53	0.84	16.28	10.75	0.99	75762.55
18	0.01	5.22	58.33	0.51	17.75	10.80	0.98	71907.71
19	1.02	7.38	34.61	0.58	18.27	9.64	0.97	81148.22
20	4.41	5.56	42.79	1.18	16.43	10.33	0.99	80900.58
21	7.67	3.57	52.43	1.74	16.18	10.73	0.97	79582.33
22	9.26	3.86	43.20	1.25	16.75	10.45	0.98	81126.85
23	4.61	1.99	61.81	0.98	17.25	10.96	0.98	77456.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.10	5.64	52.40	1.52	15.98	10.57	0.98	77527.28
最大值	11.02	8.80	64.23	2.54	18.97	11.21	1.05	85941.21
發生時間	7	14	7	7	1	10		9
最小值	0.01	1.99	34.61	0.51	13.24	9.64	0.91	71090.13
發生時間	18	23	19	18	10	19		6
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.06 %		0.01		0.00 %
全幅偏移(率)	0.04 %	0.03 %	-0.51 %	0.03 %		0.22		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								