

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月31日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.58	3.16	53.42	3.48	16.06	11.55	1.29	81333.88
1	4.20	3.01	68.01	3.23	16.69	11.52	1.29	81109.65
2	2.30	2.52	61.29	2.28	16.77	11.35	1.29	82853.41
3	5.06	2.86	45.10	3.20	16.17	11.49	1.29	81566.12
4	2.19	3.17	45.91	3.30	15.18	11.72	1.28	80863.99
5	0.94	5.94	55.26	3.61	14.00	11.92	1.29	85303.16
6	0.88	2.72	56.87	3.92	14.33	11.75	1.29	81300.34
7	1.13	8.69	59.78	3.43	15.37	11.67	1.29	80797.20
8	4.92	2.86	62.08	3.17	15.70	11.48	1.29	81807.82
9	10.64	7.32	55.76	2.44	14.29	11.78	1.27	79266.49
10	9.50	2.46	56.55	2.49	15.02	11.82	1.29	79490.76
11	1.53	2.89	59.30	1.81	16.05	11.86	1.27	78207.13
12	0.87	3.06	56.80	2.78	16.05	11.61	1.27	80535.13
13	0.17	2.94	60.58	2.91	15.30	11.85	1.28	79026.51
14	0.23	3.65	53.48	3.85	14.53	11.73	1.26	79571.17
15	5.49	3.01	58.28	2.80	14.21	11.74	1.26	79223.02
16	9.67	5.51	57.99	3.72	14.89	11.78	1.27	77576.52
17	13.82	2.36	60.91	2.65	15.29	11.56	1.27	79270.76
18	5.14	4.43	50.65	1.87	15.52	11.30	1.27	78961.97
19	8.38	1.56	55.35	2.15	15.28	11.53	1.25	76513.77
20	7.26	3.54	57.36	1.77	16.27	11.38	1.26	80237.38
21	5.04	3.24	61.68	1.15	17.70	11.43	1.28	79819.37
22	8.25	1.60	41.05	1.97	15.48	11.44	1.28	79295.22
23	5.64	1.78	44.09	1.17	17.10	11.45	1.27	79860.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.95	3.51	55.73	2.71	15.55	11.61	1.28	80157.98
最 大 值	13.82	8.69	68.01	3.92	17.70	11.92	1.30	85303.16
發生時間	17	7	1	6	21	5		5
最 小 值	0.17	1.56	41.05	1.15	14.00	11.30	1.25	76513.77
發生時間	13	19	22	21	5	18		19
零點偏移(率)	-0.03 %	-0.08 %	-0.16 %	-0.02 %		-0.01		0.20 %
全幅偏移(率)	-0.90 %	0.67 %	0.17 %	0.25 %		-0.03		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月31日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	5.63	6.56	62.41	2.40	17.51	9.80	1.46	79237.24
1	6.31	2.78	59.59	2.74	17.27	9.63	1.46	78151.50
2	7.85	4.83	59.41	2.77	16.44	9.45	1.45	78715.47
3	15.20	9.21	65.03	4.24	14.70	10.02	1.43	78085.41
4	13.14	7.39	62.75	3.25	15.13	10.04	1.43	79213.46
5	7.19	5.75	58.83	1.64	15.94	9.66	1.43	76603.67
6	6.92	9.45	59.96	2.81	15.99	9.63	1.43	78270.71
7	10.56	5.94	58.30	3.18	15.90	9.64	1.46	76460.67
8	2.97	6.22	57.41	2.86	15.40	9.71	1.44	76970.24
9	4.63	6.95	55.98	2.86	16.53	9.35	1.48	76464.38
10	3.72	4.39	60.96	2.68	18.30	9.15	1.44	79495.81
11	2.09	6.62	49.54	2.53	19.11	8.84	1.44	79385.49
12	0.71	5.72	45.76	2.48	19.90	8.33	1.45	76932.49
13	0.71	3.35	53.39	2.64	17.46	8.79	1.41	77296.53
14	0.49	2.23	54.59	2.36	18.26	8.91	1.43	75587.70
15	1.67	2.62	43.45	2.50	18.83	8.18	1.43	73641.18
16	2.91	3.33	47.66	2.15	18.93	8.12	1.42	76854.57
17	7.80	5.64	54.59	0.29	18.69	8.78	1.42	78591.11
18	9.45	2.79	49.80	0.29	18.78	8.65	1.42	78395.14
19	8.69	3.83	50.95	0.30	19.22	8.45	1.45	80099.83
20	5.30	1.83	54.39	0.23	17.88	8.90	1.42	77256.23
21	7.23	1.76	55.30	0.24	18.15	8.69	1.41	78932.14
22	3.49	2.64	59.03	0.23	18.13	9.06	1.42	78001.59
23	2.81	3.27	56.03	0.24	19.44	8.81	1.46	80849.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.73	4.80	55.63	2.00	17.58	9.11	1.44	77895.52
最 大 值	15.20	9.45	65.03	4.24	19.90	10.04	1.48	80849.82
發生時間	3	6	3	3	12	4		23
最 小 值	0.49	1.76	43.45	0.23	14.70	8.12	1.40	73641.18
發生時間	14	21	15	20	3	16		15
零點偏移(率)	-0.31 %	-0.02 %	-0.01 %	-0.01 %		-0.01		-0.10 %
全幅偏移(率)	-0.73 %	1.12 %	-0.88 %	0.02 %		0.21		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								