

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.11	1.15	3.92	5.35	2.13	21.09	0.94	4756.98
1	0.11	1.15	3.88	5.26	2.12	21.10	0.96	5264.16
2	0.11	1.12	3.60	5.15	2.09	21.10	0.95	5713.10
3	0.11	1.06	3.38	5.04	2.04	21.09	0.94	5469.70
4	0.11	1.00	3.24	4.99	2.03	21.10	0.94	5421.63
5	0.11	0.91	2.89	4.93	1.95	21.08	0.93	5052.37
6	0.11	0.97	3.06	4.91	2.00	21.08	0.94	5301.12
7	0.11	1.04	3.00	4.88	1.94	21.06	0.97	4871.02
8	0.11	1.05	3.49	5.07	2.00	21.05	1.05	5753.05
9	0.11	1.07	4.30	5.44	2.17	21.04	1.00	5689.19
10	0.11	1.04	3.92	5.29	2.08	21.04	0.97	5132.69
11	0.11	1.00	3.71	5.23	2.05	21.03	0.98	8481.36
12	0.11	0.94	3.37	5.00	2.00	21.05	0.99	8323.69
13	0.11	0.89	3.09	4.88	1.91	21.05	1.00	12351.27
14	0.11	0.87	3.01	4.77	1.90	21.06	0.99	11980.20
15	0.11	0.87	2.86	4.75	1.91	21.08	0.99	12760.27
16	0.11	0.90	2.74	4.71	1.89	21.06	0.99	11275.16
17	0.11	0.90	2.56	4.58	1.83	21.04	1.01	11028.70
18	0.11	0.88	2.25	4.43	1.79	21.02	1.02	10419.98
19	0.11	0.81	1.88	4.22	1.71	21.00	1.02	11149.99
20	0.11	0.79	1.65	4.09	1.66	20.99	0.99	11985.98
21	0.11	0.77	1.53	3.99	1.64	20.97	0.97	12118.81
22	0.11	0.77	1.36	3.94	1.62	20.98	0.97	13180.77
23	0.11	0.74	1.42	3.95	1.63	20.99	0.97	13825.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	0.11	0.95	2.92	4.79	1.92	21.05	0.98	8637.76
最大值	0.11	1.15	4.30	5.44	2.17	21.10	1.36	13825.13
發生時間	0	0	9	9	9	1		23
最小值	0.11	0.74	1.36	3.94	1.62	20.97	0.92	4756.98
發生時間	0	23	22	22	22	21		0
零點偏移(率)	-0.05 %	-0.04 %	-0.02 %	-0.00 %		-0.12	-0.01	0.20 %
全幅偏移(率)	-1.00 %	0.42 %	0.02 %	0.30 %		-0.18	0.04	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.89	13.15	54.54	0.26	19.93	11.19	1.09	76907.28
1	8.71	13.61	57.01	0.48	19.39	11.70	1.07	74075.33
2	8.76	14.00	59.07	0.61	17.55	12.12	1.06	72536.58
3	9.85	13.47	54.00	1.35	17.89	11.60	1.06	76213.73
4	10.21	12.57	50.94	1.89	17.36	11.15	1.04	79922.12
5	11.34	12.66	52.79	1.94	17.47	10.99	1.04	79382.10
6	8.01	12.46	56.10	0.77	19.04	10.89	1.02	78303.66
7	9.39	12.30	49.05	0.96	19.21	10.70	1.02	80747.09
8	11.43	11.97	52.59	0.84	19.93	10.29	1.02	83421.48
9	10.94	12.12	58.41	0.87	19.21	10.59	1.02	82236.45
10	11.27	12.35	60.80	1.02	19.28	10.65	1.02	82489.63
11	9.25	12.61	59.19	1.29	17.75	11.14	1.02	79349.68
12	11.73	12.40	52.63	0.99	18.74	10.90	1.02	79196.53
13	9.09	12.56	55.17	1.11	19.42	10.80	1.02	80093.61
14	14.56	12.33	58.34	1.00	18.57	10.86	1.02	81505.95
15	10.41	13.17	55.93	1.70	16.58	11.64	1.01	76388.62
16	11.75	12.24	49.96	1.27	18.11	10.86	1.00	80279.06
17	11.08	12.54	51.06	1.83	16.44	11.16	0.99	77535.65
18	9.73	12.36	48.70	1.26	17.46	11.02	1.00	78313.60
19	9.63	12.32	46.60	1.26	17.88	10.91	1.00	78946.34
20	12.27	12.91	47.75	1.30	19.78	10.69	0.99	81184.93
21	14.64	12.13	57.30	0.85	19.14	10.58	0.97	82124.33
22	9.67	13.06	61.33	1.25	18.43	11.36	0.98	78557.47
23	停機	停機	停機	停機	停機	停機	停機	停機
監測時數	23	23	23	23	23	23	23	23
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	23	23
平均值	10.59	12.66	54.32	1.13	18.46	11.03	1.02	79117.88
最大值	14.64	14.00	61.33	1.94	19.93	12.12	1.09	83421.48
發生時間	21	2	22	5	0	2		8
最小值	8.01	11.97	46.60	0.26	16.44	10.29	0.97	72536.58
發生時間	6	8	19	0	17	8		2
零點偏移(率)	-0.14 %	0.00 %	-0.08 %	-0.01 %		-0.11	-0.01	-0.20 %
全幅偏移(率)	1.35 %	2.75 %	0.45 %	2.31 %		-0.09	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.16	12.25	53.51	1.81	20.63	9.54	1.39	79530.96
1	8.01	11.38	53.10	2.17	20.96	9.72	1.41	81642.19
2	7.72	11.51	49.78	1.83	21.60	9.37	1.39	81331.24
3	8.72	11.24	52.05	2.46	17.82	9.93	1.36	77535.15
4	6.14	11.54	56.69	2.40	17.45	10.01	1.36	76434.39
5	9.72	11.44	53.59	2.60	17.11	9.91	1.34	77606.02
6	13.23	13.88	50.85	2.61	16.68	9.47	1.34	75239.53
7	4.48	11.03	43.79	2.45	18.83	9.16	1.35	78922.22
8	8.57	10.83	44.19	2.68	19.67	8.88	1.37	77391.46
9	9.27	11.06	45.14	2.73	19.18	9.05	1.38	76146.42
10	9.88	10.89	48.96	2.78	18.40	9.21	1.37	75387.94
11	4.83	10.82	54.32	2.53	18.99	9.30	1.33	75668.75
12	6.45	10.86	48.95	2.53	18.31	9.29	1.32	75699.15
13	8.24	11.11	47.17	2.66	18.96	9.14	1.35	77530.55
14	6.75	10.99	52.59	2.83	18.47	9.32	1.34	75270.21
15	8.05	11.05	54.84	2.95	18.73	9.58	1.32	77001.72
16	8.73	10.76	51.62	1.59	18.36	9.40	1.32	76795.55
17	8.02	11.87	45.04	1.53	17.55	9.25	1.34	75590.95
18	11.77	11.38	44.46	1.56	17.97	9.17	1.34	76293.26
19	8.48	12.01	39.77	1.61	18.33	8.87	1.35	77766.52
20	7.75	10.93	40.34	1.32	19.27	8.94	1.33	78161.46
21	9.70	11.73	42.19	1.53	19.81	9.05	1.31	78379.88
22	10.29	10.68	47.29	1.59	17.73	9.28	1.33	77281.55
23	7.42	11.52	51.39	1.98	17.51	9.19	1.34	80569.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.31	11.37	48.82	2.20	18.68	9.33	1.35	77465.68
最大值	13.23	13.88	56.69	2.95	21.60	10.01	1.41	81642.19
發生時間	6	6	4	15	2	4		1
最小值	4.48	10.68	39.77	1.32	16.68	8.87	1.31	75239.53
發生時間	7	22	19	20	6	19		6
零點偏移(率)	-0.13 %	0.01 %	-0.03 %	0.00 %		-0.16	-0.01	-0.10 %
全幅偏移(率)	0.90 %	2.30 %	0.02 %	-0.56 %		0.25	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								