

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.64	12.99	36.75	1.24	18.27	11.31	1.20	72395.70
1	8.64	14.41	58.51	1.66	17.55	12.34	1.20	65377.58
2	7.93	13.45	47.82	1.23	18.88	11.44	1.19	70617.14
3	7.65	12.66	63.25	1.21	18.90	10.98	1.18	74820.80
4	7.89	13.53	48.58	1.60	17.42	11.50	1.19	71867.27
5	3.50	12.18	48.37	2.31	19.08	10.44	1.18	81359.63
6	9.51	12.57	58.63	3.73	17.39	11.00	1.18	75844.98
7	10.47	13.01	60.31	3.01	17.02	11.41	1.18	72388.69
8	6.51	13.11	55.23	2.51	15.80	11.68	1.19	69787.19
9	10.67	13.35	59.85	2.93	15.65	11.91	1.18	68666.78
10	5.01	13.41	60.57	2.30	16.67	11.82	1.19	69453.56
11	9.68	13.37	55.83	2.70	15.98	11.67	1.18	70180.80
12	6.69	12.99	55.71	2.18	17.27	11.35	1.18	71316.95
13	4.76	12.75	50.59	1.98	16.68	11.46	1.18	70110.31
14	6.76	12.87	54.15	1.64	16.73	11.50	1.18	70470.52
15	11.08	13.35	48.85	3.05	16.36	11.45	1.18	68869.04
16	18.46	13.64	47.83	3.60	16.31	11.23	1.18	70561.41
17	3.14	13.17	47.91	1.78	17.21	11.11	1.19	72542.98
18	2.99	13.30	53.40	1.29	17.28	11.55	1.18	69961.91
19	11.97	13.04	54.70	4.57	17.70	10.98	1.17	76157.16
20	14.83	12.92	52.09	4.59	16.94	11.33	1.18	73568.07
21	7.05	13.51	50.69	1.57	17.02	11.26	1.19	74365.62
22	1.16	13.41	61.56	0.84	17.56	11.62	1.18	70523.26
23	10.72	13.60	45.92	3.28	16.79	11.45	1.18	72102.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.20	13.19	53.21	2.37	17.19	11.41	1.18	71804.57
最大值	18.46	14.41	63.25	4.59	19.08	12.34	1.21	81359.63
發生時間	16	1	3	20	5	1		5
最小值	1.16	12.18	36.75	0.84	15.65	10.44	1.15	65377.58
發生時間	22	5	0	22	9	5		1
零點偏移(率)	-0.02 %	-0.00 %	-0.07 %	0.00 %		-0.10	-0.01	0.20 %
全幅偏移(率)	0.51 %	0.08 %	0.76 %	-0.43 %		-0.14	0.10	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.46	11.55	36.45	1.62	18.25	10.26	1.04	79674.22
1	5.61	12.86	53.03	1.29	17.90	11.41	1.05	69048.54
2	4.18	13.02	47.40	1.76	17.17	11.42	1.05	69096.66
3	8.89	11.56	40.03	2.35	17.49	10.43	1.06	80947.45
4	7.87	11.79	42.38	2.80	17.27	10.66	1.06	80728.98
5	8.87	11.74	47.15	2.08	17.54	10.59	1.06	80290.90
6	12.38	12.27	50.03	3.90	17.08	10.57	1.07	83706.56
7	7.72	12.03	53.20	2.82	16.85	10.79	1.06	78816.45
8	9.94	12.15	55.98	2.28	16.74	10.99	1.06	78380.50
9	10.52	11.87	55.13	2.66	17.06	10.62	1.06	78025.86
10	9.50	11.85	51.42	3.13	16.85	10.65	1.06	78671.95
11	12.08	11.85	57.71	2.47	17.84	10.44	1.06	80123.06
12	6.38	11.87	57.01	2.92	16.19	10.80	1.06	76121.14
13	8.70	11.91	51.91	3.04	15.80	10.83	1.06	75584.67
14	12.04	11.86	63.30	2.47	16.70	10.64	1.06	76782.65
15	8.38	12.61	55.97	2.95	16.48	10.51	1.05	76524.90
16	14.16	11.77	59.52	1.74	16.82	10.51	1.06	79564.05
17	10.47	13.24	55.96	1.70	17.26	10.51	1.06	79432.84
18	8.37	13.35	64.06	1.10	17.96	10.04	1.05	80707.14
19	9.83	13.22	50.00	1.20	17.90	9.90	1.06	78922.84
20	10.21	13.69	50.94	1.62	17.50	9.98	1.06	79074.32
21	6.30	12.93	42.16	0.86	18.07	9.93	1.05	77763.34
22	9.56	13.87	69.23	1.12	17.38	10.70	1.06	80252.56
23	7.73	13.47	56.70	0.94	17.28	10.56	1.06	82027.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.13	12.43	52.78	2.12	17.22	10.57	1.06	78344.55
最大值	14.16	13.87	69.23	3.90	18.25	11.42	1.08	83706.56
發生時間	16	22	22	6	0	2		6
最小值	4.18	11.55	36.45	0.86	15.80	9.90	1.04	69048.54
發生時間	2	0	0	21	13	19		1
零點偏移(率)	-0.71 %	-0.00 %	-0.14 %	-0.00 %		-0.09	-0.01	0.00 %
全幅偏移(率)	1.93 %	-0.96 %	0.56 %	-0.64 %		-0.05	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.36	11.52	52.75	3.94	16.80	10.47	1.34	73420.39
1	4.45	11.51	59.90	3.62	19.19	10.16	1.32	74937.71
2	4.81	11.44	52.52	2.06	16.65	10.42	1.31	73408.22
3	6.87	11.49	57.43	2.22	18.01	10.32	1.31	75232.94
4	7.52	11.48	49.62	2.24	16.22	10.49	1.29	73509.71
5	8.05	11.52	51.58	2.26	16.04	10.49	1.29	74203.69
6	5.95	11.73	55.44	2.13	16.39	10.71	1.30	72323.32
7	4.74	11.73	58.91	3.22	16.67	10.56	1.36	71280.24
8	8.09	11.74	62.50	2.74	16.90	10.36	1.36	72962.20
9	5.72	11.28	56.09	1.96	17.38	10.04	1.34	71992.10
10	6.03	12.41	50.48	1.56	16.06	9.91	1.32	68430.33
11	5.05	11.92	61.91	1.38	15.79	10.26	1.36	70608.33
12	4.54	11.24	60.36	1.43	17.37	9.95	1.34	74268.07
13	3.72	11.30	59.84	1.47	16.66	10.03	1.36	72669.93
14	2.21	11.69	45.64	1.39	17.52	9.21	1.31	70739.19
15	6.16	11.11	45.06	2.30	17.22	9.30	1.35	68362.69
16	10.26	11.52	49.01	2.64	17.37	9.25	1.32	71126.71
17	10.09	12.14	60.14	2.66	16.19	9.69	1.31	72546.38
18	10.30	11.26	62.49	0.53	16.63	10.17	1.34	71772.21
19	10.61	13.16	64.64	1.85	17.88	9.88	1.32	73572.22
20	10.35	13.51	58.37	2.77	16.44	10.19	1.32	72196.42
21	10.12	13.54	57.38	2.79	16.00	10.16	1.34	72416.91
22	10.15	13.43	56.63	2.80	16.52	10.00	1.34	70843.06
23	10.05	13.22	58.44	2.73	16.84	9.87	1.31	73171.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.09	11.95	56.13	2.28	16.86	10.08	1.33	72333.10
最大值	10.61	13.54	64.64	3.94	19.19	10.71	1.39	75232.94
發生時間	19	21	19	0	1	6		3
最小值	2.21	11.11	45.06	0.53	15.79	9.21	1.27	68362.69
發生時間	14	15	15	18	11	14		15
零點偏移(率)	-0.21 %	0.00 %	-0.24 %	0.00 %		-0.11	-0.01	-0.20 %
全幅偏移(率)	-2.45 %	-0.17 %	0.52 %	-0.26 %		0.21	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								