

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月05日

報表日期: 115年07月05日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月05日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.11	12.46	49.52	0.83	18.72	10.76	0.95	85971.72
1	1.47	12.93	58.71	0.99	19.83	11.18	0.95	81181.12
2	1.59	12.38	47.67	1.41	18.24	10.81	0.94	85365.79
3	1.61	12.98	48.53	1.91	17.05	11.54	0.95	80379.45
4	2.61	12.91	49.92	1.27	18.31	11.34	0.95	81167.21
5	2.92	14.20	49.39	1.26	19.50	10.96	0.96	82153.23
6	1.75	12.60	60.23	2.75	18.46	11.19	0.94	79612.74
7	2.94	13.25	61.49	1.85	18.85	11.40	0.94	79497.33
8	2.26	13.47	52.67	1.49	18.66	10.89	0.94	83809.45
9	3.68	13.56	57.76	1.57	18.00	11.01	0.94	83248.48
10	2.87	13.96	59.19	2.07	17.11	11.38	0.94	81357.79
11	2.08	14.52	61.80	2.41	17.36	11.44	0.94	80725.96
12	2.82	14.17	50.32	1.50	18.07	11.15	0.94	82068.46
13	2.16	13.44	49.03	1.55	18.66	10.81	0.94	83719.70
14	2.92	13.52	55.20	1.57	18.85	10.83	0.93	83564.17
15	3.72	13.20	57.55	1.13	18.24	11.12	0.94	81952.98
16	3.53	12.56	60.23	1.46	19.34	10.71	0.94	84597.13
17	4.51	14.16	56.52	1.48	20.82	9.86	0.94	88988.20
18	3.84	13.10	47.88	0.33	19.72	10.31	0.94	86543.90
19	5.87	13.40	51.47	0.72	18.73	10.34	0.94	87721.38
20	9.58	13.86	58.64	1.33	17.99	11.13	0.94	81934.00
21	4.28	13.67	60.56	0.60	18.76	10.94	0.94	82585.33
22	3.40	14.20	63.26	1.22	18.27	11.35	0.94	79802.12
23	5.94	13.62	51.77	0.89	18.80	10.82	0.94	84373.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.35	13.42	54.97	1.40	18.60	10.97	0.94	83013.38
最 大 值	9.58	14.52	63.26	2.75	20.82	11.54	0.97	88988.20
發生時間	20	11	22	6	17	3		17
最 小 值	1.47	12.38	47.67	0.33	17.05	9.86	0.93	79497.33
發生時間	1	2	2	18	3	17		7
零點偏移(率)	-0.12 %	-0.04 %	-0.03 %	0.00 %		-0.03	-0.01	-0.10 %
全幅偏移(率)	-2.78 %	-0.28 %	0.29 %	0.64 %		0.12	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月05日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.24	11.28	60.83	3.34	19.46	9.57	1.27	74966.38
1	4.32	11.52	49.75	3.00	21.02	9.67	1.27	71339.43
2	4.08	11.18	40.94	3.18	20.48	9.29	1.27	74651.14
3	3.31	11.05	45.00	3.37	19.96	9.35	1.28	73983.17
4	6.56	10.79	43.55	3.39	19.27	9.21	1.30	77201.99
5	4.55	11.32	41.49	3.18	18.58	9.37	1.31	74366.84
6	5.97	11.34	45.90	3.11	17.91	9.99	1.31	69460.37
7	2.78	10.74	52.00	2.92	18.18	9.49	1.27	75553.24
8	3.26	11.35	54.91	2.38	17.37	10.01	1.26	69341.29
9	2.83	11.57	55.82	1.44	17.88	9.66	1.27	72270.47
10	3.55	11.36	55.14	1.40	16.98	9.83	1.30	72746.67
11	3.19	11.09	56.91	1.39	17.25	9.80	1.27	72459.20
12	5.62	12.44	58.54	1.59	18.00	9.62	1.29	74252.79
13	4.65	11.56	62.62	1.53	18.07	9.66	1.31	75450.61
14	9.93	11.43	63.68	1.64	17.64	9.86	1.31	74661.50
15	5.42	11.25	60.81	2.13	16.94	10.06	1.30	72924.41
16	8.42	11.26	60.35	3.05	17.26	9.82	1.29	74914.07
17	3.90	12.32	60.42	2.84	17.22	9.92	1.28	73356.23
18	6.70	12.29	55.47	3.06	18.45	9.53	1.26	74422.11
19	5.18	12.20	54.43	3.02	18.53	9.47	1.30	73894.26
20	8.04	12.69	48.22	3.49	20.09	8.83	1.30	77793.04
21	4.81	12.30	60.07	3.33	19.28	9.44	1.29	75220.11
22	7.82	13.22	59.97	3.38	19.07	9.55	1.27	75467.79
23	5.89	12.21	53.65	2.88	19.30	9.11	1.27	76205.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.29	11.66	54.19	2.67	18.51	9.59	1.29	74037.60
最 大 值	9.93	13.22	63.68	3.49	21.02	10.06	1.31	77793.04
發生時間	14	22	14	20	1	15		20
最 小 值	2.78	10.74	40.94	1.39	16.94	8.83	1.24	69341.29
發生時間	7	7	2	11	15	20		8
零點偏移(率)	-0.01 %	0.00 %	-0.05 %	-0.01 %		-0.03	-0.01	-0.20 %
全幅偏移(率)	0.91 %	-1.43 %	-0.73 %	-0.80 %		0.42	-0.06	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								