

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月27日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.59	13.05	55.06	1.13	16.40	12.28	1.29	74067.97
1	9.37	11.82	47.80	1.22	17.32	11.24	1.29	82121.59
2	9.82	12.72	33.68	1.61	16.01	11.25	1.29	83523.36
3	10.23	11.78	43.96	1.98	14.89	11.57	1.29	81950.04
4	8.96	12.07	50.10	1.61	15.22	11.83	1.29	79130.53
5	7.65	11.70	36.94	1.98	15.54	11.25	1.26	83804.57
6	11.48	11.93	43.20	1.65	15.61	11.51	1.26	80897.89
7	10.50	11.53	51.15	2.30	15.48	11.43	1.26	82045.08
8	10.87	11.89	47.65	2.44	13.90	11.84	1.29	80083.27
9	9.38	12.40	53.75	1.47	15.38	12.04	1.29	77567.34
10	11.23	11.69	51.49	1.74	15.21	11.47	1.29	82530.46
11	10.75	12.31	41.80	1.76	14.87	11.67	1.29	80755.34
12	10.61	12.90	48.68	1.99	14.59	12.07	1.29	77842.54
13	14.24	12.43	54.50	2.21	14.98	11.50	1.30	82015.27
14	12.70	16.59	36.65	2.16	14.65	11.49	1.31	82301.16
15	11.30	13.97	32.11	3.47	12.76	12.18	1.30	78239.75
16	13.62	11.91	48.85	2.96	13.09	12.11	1.29	79320.77
17	10.61	12.16	47.50	2.61	14.46	11.86	1.28	80403.50
18	11.12	12.28	44.04	4.07	13.46	11.89	1.27	80617.79
19	8.54	12.58	50.23	3.39	13.60	12.21	1.25	78162.02
20	9.12	13.79	47.80	2.76	14.51	11.88	1.25	80376.70
21	14.06	12.63	51.99	4.01	13.26	12.03	1.28	79717.17
22	10.48	13.01	53.63	2.77	14.22	12.34	1.29	75897.69
23	11.14	11.83	45.40	1.52	15.20	11.54	1.28	81849.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.68	12.54	46.58	2.28	14.78	11.77	1.28	80217.57
最 大 值	14.24	16.59	55.06	4.07	17.32	12.34	1.31	83804.57
發生時間	13	14	0	18	1	22		5
最 小 值	7.65	11.53	32.11	1.13	12.76	11.24	1.25	74067.97
發生時間	5	7	15	0	15	1		0
零點偏移(率)	-0.28 %	-0.02 %	-0.01 %	-0.01 %		-0.08	-0.01	0.30 %
全幅偏移(率)	0.59 %	0.84 %	-0.85 %	0.47 %		0.19	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月27日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.31	11.84	58.34	1.70	16.97	10.60	1.37	72039.35
1	7.70	11.47	45.86	2.21	17.77	10.16	1.37	73318.45
2	8.53	11.37	51.03	2.31	16.08	10.31	1.36	73146.49
3	7.80	11.45	51.97	2.15	15.56	10.45	1.36	73456.20
4	7.87	11.79	51.29	2.38	15.27	10.44	1.36	74531.87
5	8.01	12.03	50.65	2.63	14.62	10.56	1.36	73132.58
6	7.35	11.53	49.07	2.04	15.69	10.21	1.36	72095.78
7	9.32	11.34	40.13	2.11	15.88	9.66	1.36	71324.43
8	6.34	11.60	41.76	2.09	14.78	9.78	1.36	69427.16
9	5.83	12.17	42.77	1.89	16.16	9.65	1.36	69997.89
10	8.08	11.14	42.06	1.73	16.23	9.44	1.36	71103.91
11	7.45	10.92	48.95	1.83	16.68	9.54	1.36	70256.38
12	9.22	11.55	41.24	2.67	16.07	9.04	1.36	73427.12
13	3.04	12.98	43.44	2.67	14.33	9.23	1.36	70032.44
14	7.28	12.11	38.23	2.40	16.53	9.19	1.36	70185.80
15	7.61	11.28	33.74	2.10	15.68	9.14	1.36	70338.06
16	7.36	11.58	35.28	2.10	16.10	9.00	1.36	70475.42
17	8.12	12.06	29.00	2.09	16.96	8.71	1.36	72500.26
18	6.88	11.21	34.49	1.97	17.46	8.81	1.36	73461.44
19	6.97	11.98	40.66	2.52	14.63	9.46	1.35	70468.96
20	8.50	11.71	43.35	2.20	15.11	9.58	1.35	69806.90
21	8.65	11.09	41.48	1.99	15.34	9.54	1.33	72123.87
22	6.24	12.48	43.67	2.39	14.29	9.88	1.36	70198.93
23	8.35	12.21	45.94	1.89	16.96	9.59	1.36	75190.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.53	11.70	43.52	2.17	15.88	9.67	1.36	71751.69
最 大 值	9.32	12.98	58.34	2.67	17.77	10.60	1.38	75190.97
發生時間	7	13	0	12	1	0		23
最 小 值	3.04	10.92	29.00	1.70	14.29	8.71	1.32	69427.16
發生時間	13	11	17	0	22	17		8
零點偏移(率)	-0.12 %	-0.01 %	-0.02 %	-0.01 %		-0.09	-0.01	0.20 %
全幅偏移(率)	-1.09 %	1.09 %	-0.23 %	0.38 %		0.15	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								