

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月17日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	3.63	9.98	59.87	2.62	14.98	12.15	1.25	69196.44
1	2.65	10.65	59.05	3.03	14.99	12.19	1.25	68759.89
2	1.91	10.87	59.92	3.05	14.42	12.53	1.25	66671.04
3	1.31	10.51	60.31	2.91	14.66	12.21	1.25	68492.60
4	1.46	10.23	56.15	2.88	14.66	12.02	1.25	69860.15
5	0.21	8.79	53.92	3.07	13.86	12.05	1.25	70471.87
6	2.19	9.08	60.26	3.51	13.25	12.38	1.25	68448.39
7	2.25	9.21	59.32	3.57	13.32	12.42	1.25	67294.10
8	0.23	8.96	57.88	3.22	14.10	12.21	1.25	68845.31
9	1.98	9.29	62.94	3.02	14.55	12.12	1.24	69175.52
10	2.86	9.70	53.91	4.12	13.00	12.38	1.25	67598.66
11	1.86	9.10	60.38	3.58	13.69	12.29	1.25	67663.43
12	0.84	8.98	61.31	3.14	14.26	12.11	1.24	68963.85
13	1.85	9.31	55.43	3.67	13.75	12.34	1.23	67590.53
14	7.13	9.96	69.29	3.02	15.50	12.38	1.23	66592.54
15	6.60	11.35	62.34	2.76	16.22	11.57	1.25	72006.34
16	2.72	12.99	49.42	3.59	13.78	12.32	1.24	68219.48
17	5.28	10.98	65.11	2.80	14.32	12.27	1.23	68462.04
18	8.03	9.16	63.47	3.10	13.50	12.32	1.25	68628.24
19	9.28	8.91	65.06	2.47	15.56	11.92	1.23	70475.85
20	9.24	9.65	52.40	3.02	14.24	12.00	1.23	70259.99
21	8.81	10.03	62.97	2.52	15.17	11.84	1.24	71198.80
22	7.05	9.62	58.01	2.84	13.98	12.18	1.24	69149.95
23	9.39	9.75	61.31	2.99	14.16	12.09	1.25	69682.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均値	4.11	9.88	59.58	3.10	14.33	12.18	1.24	68904.46
最大値	9.39	12.99	69.29	4.12	16.22	12.53	1.26	72006.34
發生時間	23	16	14	10	15	2		15
最小値	0.21	8.79	49.42	2.47	13.00	11.57	1.21	66592.54
發生時間	5	5	16	19	10	15		14
零點偏移(率)	-0.02 %	-0.03 %	-0.01 %	-0.02 %		-0.01		0.00 %
全幅偏移(率)	0.00 %	-0.17 %	-0.29 %	0.01 %		0.26		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月17日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.30	8.37	57.52	1.51	17.04	10.57	1.04	80243.12
1	1.98	8.43	56.01	1.69	18.40	10.34	1.04	79174.86
2	2.16	11.31	62.28	1.64	17.10	10.89	1.04	77301.18
3	2.37	12.27	52.92	2.94	15.57	11.04	1.04	76913.82
4	4.75	11.99	57.86	3.31	15.23	10.96	1.04	79510.07
5	4.31	10.38	58.79	3.89	14.46	11.34	1.04	79472.50
6	7.57	10.39	62.86	3.44	14.08	11.34	1.04	79281.20
7	8.60	9.27	59.23	2.20	15.60	11.13	1.04	80176.10
8	4.35	10.47	55.21	3.04	14.69	11.30	1.05	76160.73
9	3.86	10.18	57.21	3.11	15.12	11.03	1.04	77877.30
10	1.99	11.89	59.40	3.05	14.62	11.25	1.04	78056.47
11	3.86	11.02	63.27	3.31	13.88	11.83	1.04	77441.12
12	0.83	10.77	58.76	3.41	14.55	11.61	1.04	78378.12
13	0.28	10.85	60.96	2.33	15.89	11.32	1.03	79908.22
14	1.05	10.42	57.16	3.22	14.72	11.62	1.03	78372.80
15	6.54	8.22	63.53	3.34	14.60	11.69	1.03	77836.98
16	6.23	8.24	59.68	2.60	15.61	11.42	1.03	79473.29
17	4.41	9.96	60.49	2.82	16.66	11.09	1.04	79093.04
18	3.10	8.77	59.59	2.83	15.85	11.34	1.03	79117.92
19	3.31	9.47	59.51	3.67	14.54	11.52	1.04	79530.95
20	4.15	8.68	68.06	2.93	15.82	11.36	1.03	79585.42
21	5.87	8.63	59.64	3.45	14.88	11.31	1.03	81552.17
22	8.94	8.05	58.21	2.65	15.96	10.91	1.04	82541.18
23	5.10	7.90	59.31	2.16	16.33	11.01	1.04	79159.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.04	9.83	59.48	2.86	15.47	11.22	1.04	79006.59
最 大 值	8.94	12.27	68.06	3.89	18.40	11.83	1.05	82541.18
發生時間	22	3	20	5	1	11		22
最 小 值	0.28	7.90	52.92	1.51	13.88	10.34	1.02	76160.73
發生時間	13	23	3	0	11	1		8
零點偏移(率)	-0.07 %	-0.01 %	-0.01 %	0.00 %		-0.08		-0.10 %
全幅偏移(率)	0.14 %	0.05 %	-0.43 %	0.13 %		0.09		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月17日

報表日期: 114年08月17日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.01	9.67	53.53	2.71	17.06	9.39	1.42	76253.60
1	9.93	10.42	59.24	3.08	18.66	9.22	1.42	80421.17
2	13.60	8.78	57.80	2.15	15.59	9.90	1.41	76112.68
3	15.19	8.60	62.54	2.10	16.03	10.06	1.43	77772.27
4	10.88	9.29	56.39	2.08	15.54	10.01	1.43	76255.27
5	9.36	10.69	58.73	2.36	14.57	10.25	1.42	75431.16
6	2.32	10.83	58.70	2.57	14.69	10.13	1.43	75891.11
7	2.38	7.80	56.55	2.95	16.80	9.83	1.43	73445.19
8	0.69	8.42	53.41	3.33	15.12	10.07	1.46	75235.82
9	0.67	8.54	53.66	3.24	15.20	10.00	1.42	75108.22
10	7.71	7.89	53.07	4.00	15.29	9.78	1.44	74053.86
11	2.25	8.54	55.19	3.22	15.69	9.76	1.45	74948.49
12	0.25	7.73	56.54	2.98	15.74	9.77	1.41	74862.53
13	0.41	8.29	55.44	3.09	16.05	9.69	1.40	74839.48
14	5.40	8.19	59.05	3.69	16.94	9.49	1.41	76831.93
15	6.69	10.97	51.62	3.49	15.80	9.83	1.45	74357.15
16	2.66	11.36	50.96	3.24	15.64	9.75	1.43	74553.12
17	0.03	7.73	62.92	2.79	16.39	9.48	1.39	75343.26
18	0.62	8.32	59.24	2.95	17.49	9.17	1.42	78380.49
19	0.77	9.00	64.37	3.13	16.32	9.50	1.43	75690.05
20	1.36	7.27	59.98	2.96	15.98	9.56	1.43	76318.38
21	1.43	7.64	60.59	2.90	16.73	9.34	1.43	77449.27
22	0.71	7.75	57.65	2.95	17.09	9.19	1.42	79123.41
23	0.83	10.85	63.26	2.95	16.57	9.32	1.41	76019.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.42	8.94	57.52	2.95	16.12	9.69	1.42	76029.05
最 大 值	15.19	11.36	64.37	4.00	18.66	10.25	1.48	80421.17
發生時間	3	16	19	10	1	5		1
最 小 值	0.03	7.27	50.96	2.08	14.57	9.17	1.38	73445.19
發生時間	17	20	16	4	5	18		7
零點偏移(率)	-0.01 %	-0.01 %	-0.09 %	-0.04 %		-0.03		-0.20 %
全幅偏移(率)	0.02 %	0.02 %	-0.22 %	0.02 %		0.39		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								