

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.54	4.37	55.00	4.06	15.62	11.36	1.39	67963.01
1	6.56	3.33	60.80	3.93	16.56	11.31	1.38	68635.85
2	7.84	3.03	49.61	4.21	16.51	10.95	1.38	68963.46
3	6.52	4.55	57.22	4.46	15.28	11.41	1.39	67979.22
4	9.38	3.18	55.18	4.39	16.48	10.85	1.38	71532.25
5	9.31	3.77	59.19	3.72	19.65	10.10	1.41	72182.49
6	8.05	4.43	55.64	3.89	19.62	9.10	1.41	75295.51
7	8.23	4.81	52.02	4.75	14.92	11.20	1.41	67900.12
8	9.35	5.14	55.81	4.23	15.73	11.49	1.41	68653.72
9	8.06	4.16	49.30	4.31	15.43	11.27	1.42	69188.56
10	9.78	2.86	63.45	3.94	19.52	10.07	1.41	73073.66
11	9.14	2.61	48.21	5.09	15.56	11.17	1.41	67128.92
12	9.22	2.54	59.03	4.30	16.51	11.18	1.41	68178.32
13	7.65	3.51	59.82	4.55	18.21	10.45	1.43	70849.47
14	9.94	9.25	52.61	5.68	14.77	11.66	1.44	67957.79
15	9.41	2.58	55.23	4.55	15.80	11.40	1.42	68029.75
16	9.20	1.67	58.44	4.51	16.17	11.19	1.41	68422.51
17	10.62	2.21	58.52	4.72	15.24	11.70	1.41	66675.29
18	8.29	1.51	55.99	3.87	18.10	10.40	1.43	74095.12
19	9.06	1.77	56.20	3.99	18.26	10.67	1.45	72752.27
20	9.52	3.85	49.04	3.84	18.33	10.25	1.42	74155.83
21	6.15	1.66	60.78	3.28	18.36	10.82	1.41	68911.11
22	4.69	1.73	53.74	3.16	18.32	11.02	1.41	70522.60
23	7.16	2.24	54.03	3.23	18.88	10.44	1.41	74937.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.28	3.36	55.62	4.19	16.99	10.89	1.41	70165.99
最大值	10.62	9.25	63.45	5.68	19.65	11.70	1.46	75295.51
發生時間	17	14	10	14	5	17		6
最小值	4.69	1.51	48.21	3.16	14.77	9.10	1.37	66675.29
發生時間	22	18	11	22	14	6		17
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	-0.22 %	1.09 %	0.05 %	0.43 %		-0.11	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.90	6.58	43.44	1.70	18.10	9.52	1.38	77176.68
1	8.68	3.43	40.96	1.78	18.77	9.51	1.38	77756.52
2	9.06	4.21	43.07	2.62	16.30	9.86	1.38	78229.20
3	1.69	3.56	57.43	1.77	16.77	10.25	1.39	76838.43
4	6.64	2.39	56.46	2.39	15.69	10.12	1.40	82906.93
5	7.64	3.24	54.19	2.14	17.20	10.05	1.40	83800.01
6	4.09	3.90	55.53	2.32	15.52	10.26	1.45	76563.34
7	6.20	5.32	51.95	2.05	16.97	9.55	1.46	80924.25
8	9.80	3.88	57.29	2.75	16.18	9.67	1.46	79920.59
9	6.67	4.59	39.02	2.58	16.10	9.18	1.47	80047.07
10	0.71	3.51	42.54	1.34	18.04	9.65	1.49	77457.81
11	2.58	3.23	55.63	1.44	18.32	9.63	1.50	78832.43
12	0.92	1.91	45.99	1.42	17.75	10.04	1.49	76465.25
13	0.11	2.60	56.60	1.47	17.55	10.74	1.48	72803.21
14	0.17	1.86	51.01	1.11	18.99	9.68	1.47	80698.35
15	4.10	1.90	49.65	1.80	18.13	9.71	1.47	81713.73
16	9.25	2.28	49.99	2.23	17.52	9.71	1.47	81125.31
17	8.59	2.65	48.22	2.39	16.71	9.82	1.47	80137.07
18	6.14	1.73	59.62	2.25	17.64	10.17	1.47	77836.52
19	0.38	1.75	56.37	1.35	17.68	10.11	1.47	78154.13
20	0.79	1.77	53.22	0.98	19.29	9.57	1.47	81360.66
21	2.70	2.55	42.97	1.16	18.88	9.31	1.48	84822.71
22	0.33	1.70	60.86	1.13	18.51	10.59	1.49	74487.28
23	0.07	2.09	55.27	0.60	20.64	9.76	1.49	80935.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.30	3.03	51.14	1.78	17.64	9.85	1.45	79208.06
最大值	9.80	6.58	60.86	2.75	20.64	10.74	1.51	84822.71
發生時間	8	0	22	8	23	13		21
最小值	0.07	1.70	39.02	0.60	15.52	9.18	1.37	72803.21
發生時間	23	22	9	23	6	9		13
零點偏移(率)	-0.02 %	-0.01 %	-0.02 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.03 %	0.13 %	0.06 %	0.04 %		-0.06	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.40	2.61	57.09	3.23	16.04	10.26	1.39	79334.16
1	10.75	3.74	47.65	3.33	16.11	10.32	1.38	74985.60
2	9.86	3.22	56.68	3.72	15.99	9.97	1.38	78375.00
3	10.13	2.75	58.61	4.42	14.50	10.59	1.40	78109.83
4	5.41	2.34	52.80	3.08	16.70	10.17	1.41	81310.30
5	9.13	4.97	58.71	3.24	17.25	9.83	1.41	83619.61
6	9.73	5.35	60.00	3.11	17.47	9.54	1.39	86033.70
7	9.55	3.88	54.65	2.85	17.15	9.94	1.38	87025.76
8	9.69	3.63	56.57	3.32	15.09	10.94	1.40	78667.08
9	10.13	3.38	56.49	3.31	14.79	11.07	1.40	76748.22
10	4.97	6.71	59.28	2.89	15.65	10.94	1.39	78402.54
11	3.79	3.03	61.61	2.60	16.14	10.92	1.41	77622.09
12	4.44	2.25	63.89	2.80	15.77	11.18	1.41	75903.75
13	3.67	2.27	62.38	2.65	16.55	11.19	1.42	77974.38
14	10.02	2.25	64.50	3.26	15.87	11.03	1.43	81243.19
15	9.23	2.15	60.01	3.15	16.05	10.84	1.43	82534.17
16	7.77	1.89	64.45	3.18	15.02	11.22	1.43	79667.55
17	7.85	2.25	62.95	2.72	17.18	10.75	1.43	81415.80
18	8.11	2.32	61.43	2.89	16.43	10.66	1.42	81719.49
19	6.52	2.29	62.88	2.61	18.25	10.28	1.41	82986.86
20	4.44	4.23	62.26	2.46	18.49	10.38	1.42	86192.11
21	5.61	6.45	55.66	2.56	18.84	10.05	1.42	90087.72
22	8.05	5.37	59.61	2.63	18.83	9.90	1.38	88371.60
23	5.06	3.22	58.85	2.48	18.70	10.26	1.38	81807.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.64	3.44	59.13	3.02	16.62	10.51	1.41	81255.74
最大值	10.75	6.71	64.50	4.42	18.84	11.22	1.44	90087.72
發生時間	1	10	14	3	21	16		21
最小值	3.67	1.89	47.65	2.46	14.50	9.54	1.38	74985.60
發生時間	13	16	1	20	3	6		1
零點偏移(率)	-0.06 %	0.00 %	-0.07 %	-0.05 %		-0.01	0.00	0.00 %
全幅偏移(率)	3.32 %	1.03 %	-0.35 %	0.35 %		0.00	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								