

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.11	5.46	49.65	0.99	17.98	11.22	1.02	84208.87
1	8.33	5.52	49.28	0.92	18.26	11.29	1.02	83529.39
2	6.92	5.51	50.15	0.94	17.62	11.63	1.02	81513.85
3	8.02	5.19	57.40	0.88	17.66	11.51	1.02	82965.21
4	8.77	6.69	39.12	1.86	16.33	11.75	1.02	83250.22
5	5.25	9.63	66.15	0.44	16.25	12.72	1.02	77701.48
6	6.53	9.43	46.83	0.50	17.97	11.37	1.02	83425.53
7	8.67	8.67	63.62	0.57	18.27	11.32	1.02	83400.88
8	9.50	7.04	40.03	1.38	16.57	11.97	0.96	81195.91
9	9.81	6.30	52.03	1.91	16.94	11.85	0.94	83153.33
10	5.63	7.11	48.69	1.52	16.20	11.94	0.94	83967.64
11	7.80	6.64	52.47	1.79	16.54	12.09	0.94	82631.19
12	4.13	7.15	56.94	0.95	15.97	12.60	0.96	79035.33
13	6.13	7.43	57.49	1.05	15.63	12.77	0.97	77925.65
14	4.87	7.76	59.49	0.88	16.02	12.83	0.97	76831.02
15	5.77	7.86	60.96	1.58	15.56	12.97	0.97	75680.73
16	5.39	7.41	61.74	0.83	16.59	12.50	0.97	78915.56
17	9.06	8.00	55.13	0.94	17.09	11.79	0.97	84883.60
18	8.42	6.55	54.57	0.68	16.50	11.84	0.97	84281.31
19	5.95	5.56	47.58	1.82	15.39	12.28	0.97	78877.31
20	7.54	5.13	49.10	0.75	17.36	11.79	0.98	81296.91
21	8.48	4.44	50.26	0.31	18.11	11.30	0.99	84309.23
22	8.97	4.28	46.36	0.66	17.30	11.29	1.01	85020.95
23	8.76	4.60	39.78	0.69	17.19	11.31	1.00	84905.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.41	6.64	52.28	1.03	16.89	11.91	0.99	81787.78
最大值	9.81	9.63	66.15	1.91	18.27	12.97	1.03	85020.95
發生時間	9	5	5	9	7	15		22
最小值	4.13	4.28	39.12	0.31	15.39	11.22	0.94	75680.73
發生時間	12	22	4	21	19	0		15
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.01 %		-0.15		0.20 %
全幅偏移(率)	-0.75 %	0.00 %	-0.03 %	0.00 %		-0.05		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.36	5.85	50.29	2.35	17.56	10.73	0.98	82009.49
1	2.86	3.33	47.94	2.18	16.91	11.28	0.97	78517.55
2	4.83	2.88	56.33	2.53	15.35	11.59	0.97	76991.98
3	6.40	2.68	57.05	2.49	16.27	11.35	0.96	78940.06
4	7.33	3.03	56.71	2.51	17.47	11.04	0.97	80126.53
5	8.82	3.57	55.43	2.40	17.27	10.91	0.98	81461.75
6	12.72	5.11	51.20	2.86	17.01	11.46	1.02	76983.06
7	6.48	4.67	44.54	1.72	17.87	11.05	1.00	79998.40
8	6.39	4.20	40.73	2.24	16.88	11.17	1.00	79411.98
9	2.55	4.14	48.40	1.88	17.03	11.45	0.98	78023.39
10	2.89	4.12	51.38	1.44	17.53	11.19	1.00	79016.82
11	8.48	5.90	43.10	3.48	15.22	11.48	1.02	79043.25
12	5.37	4.61	49.39	2.43	15.93	11.80	1.02	75828.92
13	2.31	4.55	56.03	1.79	16.43	11.55	1.02	77594.23
14	1.92	4.39	56.09	1.38	17.24	11.29	1.02	79005.65
15	1.81	4.64	50.62	1.49	17.68	11.06	1.02	80349.06
16	4.54	4.88	46.09	2.46	16.13	11.35	1.02	79503.09
17	8.56	5.95	50.96	3.65	15.88	11.24	0.99	80349.97
18	9.99	5.14	44.18	2.72	16.85	11.17	0.98	80354.53
19	7.71	4.84	37.28	1.84	17.73	10.80	0.97	82705.99
20	6.10	6.05	27.54	2.47	15.66	11.21	0.97	80265.11
21	10.61	5.78	56.80	3.14	15.46	11.35	0.97	80319.86
22	5.67	4.96	52.55	2.69	15.67	11.89	0.98	75233.18
23	5.30	4.65	52.47	2.04	16.20	11.67	0.98	77001.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.21	4.58	49.30	2.34	16.63	11.30	0.99	79126.47
最大值	12.72	6.05	57.05	3.65	17.87	11.89	1.02	82705.99
發生時間	6	20	3	17	7	22		19
最小值	1.81	2.68	27.54	1.38	15.22	10.73	0.94	75233.18
發生時間	15	3	20	14	11	0		22
零點偏移(率)	-0.06 %	-0.01 %	-0.03 %	0.00 %		-0.05		-0.20 %
全幅偏移(率)	0.55 %	0.57 %	0.29 %	0.50 %		-0.23		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.35	3.45	58.67	0.41	16.69	10.98	0.98	79473.13
1	1.36	4.59	56.78	0.76	16.18	11.18	0.99	78375.66
2	1.37	3.99	56.79	0.73	15.76	10.99	0.97	80170.96
3	1.95	4.68	54.70	0.77	16.22	10.91	0.96	78638.91
4	2.59	4.17	50.83	0.39	17.42	10.33	0.97	80480.13
5	1.41	3.71	53.19	0.47	16.35	10.70	0.96	77656.99
6	1.38	4.36	51.79	0.44	16.29	10.51	0.97	78167.45
7	1.09	6.72	52.37	0.16	18.85	10.06	0.97	78623.08
8	1.15	6.64	39.19	0.18	17.00	10.50	0.95	77457.53
9	1.13	6.56	40.55	0.23	16.70	10.29	0.98	78262.63
10	1.37	7.76	44.82	0.24	16.71	10.66	0.98	75949.95
11	1.18	6.31	46.76	0.30	16.17	10.82	1.00	75091.91
12	1.18	5.81	53.02	0.18	16.92	10.76	0.98	76392.31
13	1.17	6.44	51.40	0.26	17.08	10.67	0.97	78607.36
14	1.19	6.49	54.27	0.26	17.68	10.78	0.98	78910.01
15	1.30	6.10	58.47	0.18	17.51	11.49	1.05	74337.76
16	3.15	6.22	40.69	0.70	16.21	10.57	0.99	83105.31
17	5.75	1.67	49.19	1.24	14.99	11.13	0.98	79518.80
18	8.60	6.21	46.47	2.87	16.58	10.65	0.98	81479.33
19	5.71	5.06	45.94	0.46	18.51	10.19	0.99	81804.85
20	1.58	5.53	48.76	0.56	16.10	11.38	0.99	74233.50
21	2.88	5.32	45.43	0.52	16.39	10.73	0.99	80344.61
22	5.26	7.98	43.50	1.04	15.33	11.04	0.99	76170.41
23	4.83	5.66	45.90	0.52	16.07	11.03	0.99	74618.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.50	5.48	49.56	0.58	16.65	10.76	0.98	78244.64
最大值	8.60	7.98	58.67	2.87	18.85	11.49	1.30	83105.31
發生時間	18	22	0	18	7	15		16
最小值	1.09	1.67	39.19	0.16	14.99	10.06	0.92	74233.50
發生時間	7	17	8	7	17	7		20
零點偏移(率)	-0.15 %	0.00 %	-0.02 %	0.00 %		-0.15		0.00 %
全幅偏移(率)	0.02 %	-0.09 %	-0.54 %	0.57 %		-0.29		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								