

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.27	15.55	53.64	1.20	18.78	11.72	0.97	74902.05
1	3.11	13.43	52.44	0.97	20.40	11.25	0.97	77644.12
2	2.76	13.30	50.52	1.36	18.84	11.63	0.97	76032.86
3	2.73	12.88	49.89	1.06	19.87	11.10	0.97	79957.16
4	4.41	13.26	53.82	1.76	17.97	11.72	0.97	76713.48
5	4.91	12.27	50.08	1.33	18.50	11.37	0.97	80556.00
6	3.35	13.86	52.32	0.99	18.59	11.55	0.97	76798.12
7	4.70	11.27	45.68	1.32	18.75	11.31	0.97	76727.10
8	7.38	10.14	47.31	1.05	19.45	11.10	0.98	78087.34
9	9.29	10.72	40.92	1.50	18.50	11.17	0.99	76448.41
10	7.61	7.63	51.77	0.63	20.62	10.88	0.98	77776.76
11	8.82	7.49	42.90	1.61	18.86	10.49	1.00	83366.65
12	5.85	9.35	53.09	1.36	18.25	11.93	1.00	71589.06
13	7.00	9.45	48.34	1.25	18.56	11.12	0.99	78321.09
14	6.75	6.43	42.05	1.41	17.96	11.54	1.01	76706.01
15	4.74	9.23	56.65	0.74	19.69	11.18	1.02	78560.50
16	7.76	9.71	49.92	1.45	18.03	11.57	0.99	77259.93
17	8.20	8.59	44.43	1.61	18.74	11.31	0.98	78769.86
18	6.96	8.83	45.43	1.46	18.15	11.50	0.97	77662.12
19	7.23	13.46	45.46	1.50	17.78	11.69	0.98	76402.80
20	6.74	13.41	54.99	1.02	19.56	11.25	0.99	78755.94
21	7.17	14.94	51.48	1.59	18.46	11.49	0.99	77406.40
22	8.11	13.49	60.26	0.89	19.92	11.24	0.98	78496.63
23	4.91	15.23	56.28	0.87	19.26	11.39	0.97	78082.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.99	11.41	49.99	1.25	18.90	11.35	0.98	77625.95
最大值	9.29	15.55	60.26	1.76	20.62	11.93	1.04	83366.65
發生時間	9	0	22	4	10	12		11
最小值	2.73	6.43	40.92	0.63	17.78	10.49	0.95	71589.06
發生時間	3	14	9	10	19	11		12
零點偏移(率)	-0.24 %	-0.01 %	-0.02 %	-0.02 %		-0.04		0.00 %
全幅偏移(率)	0.02 %	0.03 %	0.01 %	0.03 %		-0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.14	9.98	39.31	0.84	20.81	9.22	1.00	89064.40
1	3.38	9.61	45.05	1.76	18.71	9.90	1.01	86100.78
2	3.51	8.40	59.39	1.40	17.83	10.26	1.02	85450.39
3	3.43	11.45	42.03	1.71	18.91	9.89	1.01	85996.21
4	3.39	7.07	48.24	1.19	18.63	9.91	1.02	86211.22
5	3.33	8.30	45.02	1.77	16.89	10.22	1.02	84788.53
6	5.26	5.71	41.26	2.18	16.60	9.90	1.03	87773.13
7	4.62	7.77	49.60	1.96	17.83	10.02	1.03	84103.95
8	8.91	4.94	57.08	2.38	17.12	10.17	1.03	83735.22
9	8.03	7.72	53.61	2.37	17.87	10.17	1.04	85148.02
10	8.95	5.52	52.09	1.83	18.08	9.96	1.04	87062.15
11	9.48	5.48	67.17	2.13	17.70	10.26	1.05	83929.81
12	9.10	5.56	52.96	2.84	15.72	10.62	1.04	81533.41
13	2.14	5.78	50.07	1.64	16.63	10.66	1.02	80569.86
14	0.27	5.81	56.31	1.88	15.90	11.29	1.03	77172.54
15	0.09	4.51	51.34	0.99	18.43	10.07	1.04	84419.13
16	1.11	4.08	54.07	1.46	17.66	10.53	1.05	82830.49
17	0.47	4.74	55.23	2.15	17.16	10.50	1.04	84525.17
18	0.44	3.36	53.58	1.56	17.67	10.39	1.02	84606.82
19	0.27	4.23	49.99	1.66	17.34	10.46	1.02	84160.90
20	1.85	4.66	53.90	2.13	17.06	10.51	1.02	84086.89
21	0.86	5.27	52.48	2.05	17.24	10.45	1.03	84975.12
22	0.20	6.16	51.67	2.09	16.90	10.58	1.02	83683.70
23	0.10	6.70	52.80	1.73	18.07	10.49	1.00	83431.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.43	6.37	51.43	1.82	17.61	10.27	1.03	84389.97
最大值	9.48	11.45	67.17	2.84	20.81	11.29	1.05	89064.40
發生時間	11	3	11	12	0	14		0
最小值	0.09	3.36	39.31	0.84	15.72	9.22	0.99	77172.54
發生時間	15	18	0	0	12	0		14
零點偏移(率)	-0.05 %	-0.01 %	-0.03 %	-0.03 %		0.00		-0.20 %
全幅偏移(率)	-0.04 %	-0.46 %	0.13 %	0.01 %		-0.30		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								